



Florida Department of  
Environmental Protection  
Hazardous Waste Inspection Report

Draft

**FACILITY INFORMATION:**

**Facility Name:** Raider Environmental Services  
**On-Site Inspection Start Date:** 03/14/2011      **On-Site Inspection End Date:** 03/14/2011  
**ME ID#:** 83539      **EPA ID#:** FLR000143891  
**Facility Street Address:** 4103 NW 132nd St, Opa Locka, Florida 33054-4510  
**Contact Mailing Address:** 4103 northwest 132nd st, Opa Locka, Florida 33054  
**County Name:** Miami-Dade      **Contact Phone:** (305) 994-9949

**NOTIFIED AS:**

Non-Handler  
Transporter  
Used Oil

**INSPECTION TYPE:**

Complaint Inspection for Used Oil Processor facility  
Complaint Inspection for Used Oil Transporter facility  
Complaint Inspection for Transporter facility

**INSPECTION PARTICIPANTS:**

Principal Inspector: Kathy R. Winston, Inspector  
Other Participants:

**LATITUDE / LONGITUDE:** Lat 25° 53' 41.924" / Long 80° 15' 51.6958"

**SIC CODE:** 4959 - Trans. & utilities - sanitary services, nec

**TYPE OF OWNERSHIP:** Private

**New Potential Violations and Areas of Concern:**

**Used Oil Processor**

Type: Violation  
Rule: 62-710.850(5)(a)  
Question Number: 28.90  
Question: Are the filters stored in above ground containers which are (All of the following checkboxes must be checked for this question to be marked Ok, otherwise this question must be marked as Not Ok.):  
Explanation: There were at least three drums of used oil filters in the storage area that needed proper labeling.  
Corrective Action: Please send picture of used filter containers properly labeled.

---

Type: Area Of Concern

Inspection Date: 03/14/2011

Rule: 279.54(c)

Question Number: 28.180

Question: Are containers provided with secondary containment consisting of walls and floor at a minimum?

Explanation: Facility had some leakage from the heat exchanger inside the secondary containment.

Corrective Action: Please send picture showing area has been cleaned up.

Type: Violation

Rule: 279.54(f)

Question Number: 28.190

Question: Are ASTs, UST tank fill lines and containers labeled "used oil"?

Explanation: Tank # 5 was not properly label.

Corrective Action: Please send picture showing tank #5 has been properly label.

Type: Area Of Concern

Rule: 279.52(a)(1)

Question Number: 28.210

Question: Is the facility maintained and operated to prevent a fire, explosion or planned or unplanned release of used oil to the air, soil, or water which could threaten human health or the environment?

Explanation: Facility needs to prepare general facility inspection log that meets the standards of Part 279.52.

Corrective Action: Please establish a log that meets the appropriate standards,keep log for three weeks and send copies to Department.

Type: Violation

Rule: 279.52(b)(2)

Question Number: 28.340

Question: Does the plan include the following?

Explanation: Secondary emergency coordinator needs to be updated.

Corrective Action: Please update all relevant pages of Contingency Plan with new secondary emergency coordinator information. Supply copies to Department. Correction were provided on site.

**Summary of Potential Violations and Areas of Concern:**

Potential Violations

Rule Number	Area	Date Cited	Explanation
Used Oil Processor 62-710.850(5)(a)		03/14/2011	There were at least three drums of used oil filters in the storage area that needed proper labeling.

Inspection Date: 03/14/2011

Draft

<b>Rule Number</b>	<b>Area</b>	<b>Date Cited</b>	<b>Explanation</b>
279.54(f)		03/14/2011	Tank # 5 was not properly label.
279.52(b)(2)		03/14/2011	Secondary emergency coordinator needs to be updated.

Areas of Concern

<b>Rule Number</b>	<b>Area</b>	<b>Date Cited</b>	<b>Explanation</b>
Used Oil Processor			
279.54(c)		03/14/2011	Facility had some leakage from the heat exchanger inside the secondary containment.
279.52(a)(1)		03/14/2011	Facility needs to prepare general facility inspection log that meets the standards of Part 279.52.

**Conclusion:**

The facility was not in compliance at the time of the inspection. The facility was given 21 days to return compliance.

Inspection Date: 03/14/2011

Draft

**Signed:**

A hazardous waste compliance inspection was conducted on this date, to determine your facility's compliance with applicable portions of Chapters 403 & 376, F.S., and Chapters 62-710, 62-730, 62-737, & 62-740 Florida Administrative Code (F.A.C.). Portions of the United States Environmental Protection Agency's Title 40 Code of Federal Regulations (C.F.R.) 260 - 279 have been adopted by reference in the state rules under Chapters 62-730 and 62-710, F.A.C. The above noted potential items of non-compliance were identified by the inspector(s).

This is not a formal enforcement action and may not be a complete listing of all items of non-compliance discovered during the inspection.

Kathy R. Winston  
\_\_\_\_\_  
**PRINCIPAL INSPECTOR NAME**

Inspector  
\_\_\_\_\_  
**PRINCIPAL INSPECTOR TITLE**

NO SIGNATURE  
\_\_\_\_\_  
**PRINCIPAL INSPECTOR SIGNATURE**

\_\_\_\_\_  
**DATE**

NOTE: By signing this document, the Site Representative only acknowledges receipt of this Inspection Report and is not admitting to the accuracy of any of the items identified by the Department as "Potential Violations" or areas of concern.