



**CURTIS F. McKNIGHT  
TESTING LABORATORIES, INC.**

TESTING and INSPECTION

7708 E. BROADWAY  
TAMPA, FL 33619  
www.mcknighttesting.com  
Phone: (813) 626-0287  
Fax: (813) 621-9610

(to verify validity of this document you may call the originator at (813) 626-0287. Many forms such as these are altered and may have differently appearing type in the fields for names, dates, etc. if in doubt contact originator).

**INSPECTION REPORT**

Date May 27, & June 14, 2011  
Customer Safety Kleen WO# 11-6588  
Address 5309 24th Ave. Type of Inspection Visual & Ultrasonic Inspection  
Tampa, Fl. 33605 Applicable Specifications Per Customer Specification  
Customer Purchase Order No. Customer  
Description and/or Serial No. Dirty Parts Washer Solvent Tank

**RESULTS OF INSPECTION**

A site visit was made to perform Visual and Ultrasonic Thickness inspection on the 15,000 Gallon Tank listed above. This tank appears in good condition with no leaks noted and minor coating breakdown found on Tank Top. All nozzles showed no corrosion or indications of leakage. Ultrasonic Thickness measurements were taken on Shell, Tank Bottom and Tank Top using a Digiwork UM-1D device. Overall, tank condition is GOOD due to coating breakdown on Tank Top.

Prepared by

Matthew D. Watford  
Matthew D. Watford Level II Technician

Approved by

Ken C. McKnight  
Ken C. McKnight, CWI, Level III Technician

Page: \_\_\_\_\_ of \_\_\_\_\_