

Ricky's Oil & Env Services, LLC



P.O. Box 669295 - Miami, FL 33166
Phone: (305) 822-2253 * Fax: (305) 887-2800
Email: chris@rickysoil.com
www.rickysoil.com

Date: 8/8/11 Time: 11:12
To: F.D.E.P.
Attn: Kathy Winston
Phone: 561-681-6756 Fax: 561-681-6770
From: Chris Ricci - President

Fax Page 1 of 11

Kathy,

Here's the information you requested
from your Visit on July 14, 2011. I'm
emailing the pictures to you from Item
#2 on the Violations Form. Please Let
me know that you have received them
and everything is in order.

Thanks!

Chris Ricci

SYNERGY RECYCLING LLC

RECYCLE / TRANSPORTATION /
RECEIVING MANIFEST

MANIFEST DOCUMENT NO.

7261101

☐ Corporate/Mailing Address:
P.O. Box 88
Sharpsburg, GA 30277

☒ Facility Address:
105 Industrial Park Dr.
Kingsland, GA 31548
EPA ID# GAR000048009

SERVICE HOTLINE
(866) 492-6789

Generator Name SYNERGY RECYCLING		EPA# 000000	Customer # 9820
Location 105 INDUSTRIAL PARK DR		City KINGSLAND	State GA
Billed To <i>Ricky's Oil Service</i>		City	
Business Mailing Address <i>7209 N.W. 66th St Miami</i>		State <i>FL</i>	Zip <i>33166</i>
Date Shipped	Time	Telephone #	
Description / Classification: Non-Hazardous			
☐ Used Lubricants, Flash Greater than 200F No Placard Required	Quantity Gallons _____	Halogen Test Method: (Circle Result)	
☐ Used Antifreeze, Flash Greater than 200F No Placard Required	Quantity Gallons _____	Halogen Leak Detector	
☐ Oily Water, Flash Greater than 200F No Placard Required	Quantity Gallons _____	Pass	Fail
☒ Used Oil Filter, Flash Greater than 200F No Placard Required	Quantity Drums <i>160 Empty Drums</i>	Dexsil	
☐ Spent Absorbents, Flash Greater than 200F No Placard Required	Quantity Drums _____	Pass	Fail
ADD'L DESCRIPTION/SPECIAL HANDLING INSTRUCTIONS: Used Oil is subject to regulation by the Florida DEP Statute 403, Florida Administrative Code 62-710 and The United States EPA 40 CFR Part 279 Avoid Skin & Tissue Contact. Wear Gloves & Eye Protection. In case of emergency contact the Florida Department of Environmental Protection and Synergy Recycling at (866) 492-6879 GENERATOR CERTIFICATION: We the generator of this product, hereby certify that we have not mixed any hazardous waste with this product being collected by Synergy Recycling. This product is being transported to Synergy Recycling to be recycled in accordance with all federal, state, and local laws. We the generator also certify that this product does not contain any detectable levels of PCB's (53 Fed. Reg. 24206, June 27, 1988). I hereby declare that the contents of this shipment are fully and accurately described above by proper shipping name and are classified, packed, marked and labeled, and are in all respects in proper condition for transport by highway according to applicable international, national, and state regulations. Unless I am a small generator who has been exempted by statute or regulation from the duty to make a waste minimization certification under Section 3002(b) of RCRA, I also certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and I have selected the method of treatment, storage, or disposal			
Printed Name <i>Mike McFaire</i>	Signature <i>[Signature]</i>	Date <i>7-26-11</i>	
TRANSPORTER ACKNOWLEDGEMENT OF RECEIPT OF MATERIALS			
Printed Name <i>Garrett Wejr</i>	Signature <i>[Signature]</i>	Date <i>7-26-11</i>	
RECEIVING FACILITY ACKNOWLEDGEMENT OF RECEIPT OF MATERIALS			
Printed Name	Signature	Date	
SPECIAL BILLING INFORMATION OR COMMENTS:			

NON-HAZARDOUS WASTE MANIFEST		1. Generator ID Number FLD 981-019-755		2. Page 1 of	3. Emergency Response Phone		4. Waste Tracking Number 7261101	
5. Generator's Name and Mailing Address Ricky's Oil Service, Inc. P.O. Box 669295 Miami, FL 33166				Generator's Site Address (if different than mailing address)				
Generator's Phone:								
6. Transporter 1 Company Name Synergy Recycling				U.S. EPA ID Number GAR000048009				
7. Transporter 2 Company Name				U.S. EPA ID Number				
8. Designated Facility Name and Site Address Synergy Recycling 105 Industrial Park Dr. Kingsland, GA 31518				U.S. EPA ID Number GAR000048009				
Facility's Phone:								
9. Waste Shipping Name and Description				10. Containers		11. Total Quantity	12. Unit Wt./Vol.	
				No.	Type			
1. Used Oil Filters				152	Dr.			
2.								
3.								
4.								
13. Special Handling Instructions and Additional Information								
14. GENERATOR'S/OFFEROR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name, and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations.								
Generator's/Offor's Printed/Typed Name <i>[Signature]</i>				Signature <i>[Signature]</i>		Month Day Year 7 27 11		
15. International Shipments ☐ Import to U.S. ☐ Export from U.S.				Port of entry/exit: Date leaving U.S.:				
Transporter Signature (for exports only):								
16. Transporter Acknowledgment of Receipt of Materials								
Transporter 1 Printed/Typed Name Gravett M. Weir				Signature <i>[Signature]</i>		Month Day Year 7 27 11		
Transporter 2 Printed/Typed Name				Signature		Month Day Year		
17. Discrepancy								
17a. Discrepancy Indication Space ☐ Quantity ☐ Type ☐ Residue ☐ Partial Rejection ☐ Full Rejection								
17b. Alternate Facility (or Generator) Manifest Reference Number: U.S. EPA ID Number								
Facility's Phone:								
17c. Signature of Alternate Facility (or Generator) Month Day Year								
18. Designated Facility Owner or Operator: Certification of receipt of materials covered by the manifest except as noted in Item 17a Printed/Typed Name Signature Month Day Year								

Manifest #
7261101

FILTER INVOICES

Please write all invoice numbers used for the filter pick ups

211746	211042	211730	
211657	211045	212649	
211797	211047	211160	
211807	211040		
211814	211049		
211754	209632		
211836	211856		
211845	211458		
211761	211180		
211837	211274		
211711	211052		
172288	211050		
211913	211055		
211720	211279		
211038	211857		

152

152

Manifest #
7261101

FILTER INVOICES

Please write all invoice numbers used for the filter pick ups

206995	211618	211 662	211068
206996	211228	211 235	211069
206997	211607	2 11 647	211070
209641	211 590	211 704	211071
206998	211 331	211 234	211073
211510	211 578	211039	211 320
206986	211 500	211041	211 322
211499	211 596	211043	211324
211501	211 481	211044	211 624
211602	211 514	211046	211709
209630	211 564	211048	211 566
211606	211 570	211053	211 698
211605	211 233	211054	211 631
211227	211 668	211057	211 870
211229	211 733	211063	209 629



2011
**ABOVEGROUND STORAGE TANK
MONTHLY VISUAL INSPECTION LOG**

UT# _____

Facility Name: Ricky's Oil Services Facility Address: 7209 NW 66th Ave, Miami
Facility Contact: Chris Ricci Phone No. 305 822-2253

TANK#: 8-11 YEAR: 2011 SIZE: 2000 gals CONTENT: waste oil, waste water, Air, Freeze
to 25,000 gal

CHOOSE ONLY ONE OF THE FOLLOWING

N = NO PROBLEM OBSERVED, Y = PROBLEM OBSERVED, or
N/A = NOT APPLICABLE

Section I

Tank/Secondary Containment

MONTH	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Signs of Damage	NO	NO	NO	NO	NO	NO	NO	NO				
Wetting	NO	NO	NO	NO	NO	NO	NO	NO				
Discoloration	NO	NO	NO	NO	NO	NO	NO	NO				
Blistering	NO	NO	NO	NO	NO	NO	NO	NO				
Corrosion	NO	NO	NO	NO	NO	NO	NO	NO				
Leak Site Gauge	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Interstices	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Other												

If the tank is double walled and lacks an electronic leak sensor between the inner & outer tank walls, or lacks a site gauge leak detector, then the space between the walls must be physically examined for evidence of a discharge each month as part of the routine inspection.

Section II

Piping

MONTH	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Signs of Damage	NO	NO	NO	NO	NO	NO	NO	NO				
Wetting	NO	NO	NO	NO	NO	NO	NO	NO				
Discoloration	NO	NO	NO	NO	NO	NO	NO	NO				
Blistering	NO	NO	NO	NO	NO	NO	NO	NO				
Corrosion	NO	NO	NO	NO	NO	NO	NO	NO				
Sumps	NO	NO	NO	NO	NO	NO	NO	NO				
Other	NO	NO	NO	NO	NO	NO	NO					

Section III

Electronic Leak Detection System

MONTH	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Power Problem	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				
Alarm Indicated	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A				

IF PROBLEMS ARE OBSERVED, SEE PAGE 2

2011

Aboveground tank monthly visual inspection log

2000 gal To
25,000 gals

Facility name: Rickys Oil Service

Tank # 11

Year: 2011

MONTH	Tank Condition.	Piping condition.	Annular space or Sec. containment or Electronic device.	Fill port bucket.	Comments
January	good	good	Clean and Dry	Clean Dry	
February	good	good	Clean and Dry	Clean Dry	Remove OOT and cleaned
March	good	good	Clean and Dry	Clean Dry	Check ALL Valves Replace TKS 5 New Unloaded Station
April	good	good	Clean Dry	Clean Dry	1, 2, 3
May	good	good	Clean Dry	Clean Dry	Replaced Hoses 4, 9, 10
June	good	good	Clean Dry	Clean Dry	New Valve TKS New Hoses 10, 9, 8, 9
July	good	good	Clean Dry	Clean Dry	New gauge for LOAD Rack Tank side
August	good	good	Clean Dry	Clean Dry	New gas kit For Loading Hoses TANK 4 + 8
Sept.					
Oct.					
Nov.					
Dec.					

Tank and associated piping need to be maintained in good condition and protected from corrosion (PAINTED)

Secondary containment of the tank needs to be free of liquid.

Fill port bucket needs to be free of liquid and labeled (DIESEL) or color-coded (YELLOW)

If the secondary containment or annular space is being monitored with an electronic device, the system needs to be tested annu.

Ricky's Oil & Env Services, LLC


Aboveground Tank Weekly Visual Inspection Log

2000 gal to 25,000 gals

Facility name: Rickys Oil Service Tank: 1 - 2 - 3 - 4 - 5 - 6 - 7 - 8 - 9 - 10 - 11

Date: 7-25-11

Day	Tank Condition	Piping Condition	Annular space or Sec. containment of Electronic device	Fill port bucket	Comments
Monday	good	good	N/A	OK	new Strainers/Baskets ON Pumping Station
Tuesday	good	good	N/A	OK	
Wednesday	good	good	N/A	OK	new # on Back side
Thursday	good	good	N/A	OK	OF TKS 1-10
Friday	good	good	N/A	Drained	
Saturday					
Sunday					



Tank and associated piping need to be maintained in good condition and protected from corrosion (PAINTED)

Secondary containment of the tank needs to be free of liquid.

Fill port bucket needs to be free of liquid and labeled (DIESEL) or color-coded (YELLOW)

If the secondary containment or annular space is being monitored with an electronic device, the system needs to be tested annually

Ricky's Oil & Env Services, LLC

Aboveground Tank Weekly Visual Inspection Log

2000 gal to 25,000 gals

Facility name: Rickys Oil Service Tank: 1-2-3-4-5-6-7-8-9-10-11

Date: 7-18-11

Day	Tank Condition	Piping Condition	Annular space or Sec. containment of Electronic device	Fill port bucket	Comments
Monday	good	good	N/A	OK	Put new Valve on
Tuesday	good	good	N/A	OK	TANK #4
Wednesday	good	good	N/A	Drained	
Thursday	good	good	N/A	OK	
Friday	good	good	N/A	Drained	
Saturday					
Sunday					

Tank and associated piping need to be maintained in good condition and protected from corrosion (PAINTED)

Secondary containment of the tank needs to be free of liquid.

Fill port bucket needs to be free of liquid and labeled (DIESEL) or color-coded (YELLOW)

If the secondary containment or annular space is being monitored with an electronic device, the system needs to be tested annually

Ricky's Oil & Env Services, LLC

Aboveground Tank Weekly Visual Inspection Log

2000 gal to 25,000 gals

Facility name: Ricky's Oil Service Tank: 1-2-3-4-5-6-7-8-9-10-11
 Date: 7-11-11

Day	Tank Condition	Piping Condition	Annular space or Sec. containment of Electronic device	Fill port bucket	Comments
Monday	good	good	N/A	OK	check all valves
Tuesday	good	good	N/A	Drained	Everything OK
Wednesday	good	good	N/A	OK	
Thursday	good	good	N/A	OK	
Friday	good	good	N/A	Drained	
Saturday					
Sunday					

Tom Swann

Tank and associated piping need to be maintained in good condition and protected from corrosion (PAINTED)

Secondary containment of the tank needs to be free of liquid.

Fill port bucket needs to be free of liquid and labeled (DIESEL) or color-coded (YELLOW)

If the secondary containment or annular space is being monitored with an electronic device, the system needs to be tested annually

Ricky's Oil & Env Services, LLC

Aboveground Tank Weekly Visual Inspection Log

2000 gal to 25,000 gals

Facility name: Rickys oil Service Tank: 1-2-3-4-5-6-7-8-9-10-11

Date: 7-4-11

Day	Tank Condition	Piping Condition	Annular space or Sec. containment of Electronic device	Fill port bucket	Comments
Monday	good	good	NA	OK	NEW gas kit on TK 3
Tuesday	good	good	NA	OK	
Wednesday	good	good	N/A	OK	
Thursday	good	good	N/A	OK	
Friday	good	good	N/A	OK	
Saturday	good	good	N/A	Dripped	
Sunday					

[Signature]

Tank and associated piping need to be maintained in good condition and protected from corrosion (PAINTED)

Secondary containment of the tank needs to be free of liquid.

Fill port bucket needs to be free of liquid and labeled (DIESEL) or color-coded (YELLOW)

If the secondary containment or annular space is being monitored with an electronic device, the system needs to be tested annually