



- HORIZONTAL INSTALLATION -

NOTE: WHEN HORIZONTAL TANKS ARE USED A 3" NIPPLE IS REQUIRED BETWEEN THE INTERNAL EMERGENCY & GATE VALVE

- EQUIPMENT/FIXTURE SCHEDULE -

MARK	SIZE	DESCRIPTION	SK PART NO.	REMARKS
1	3/8"	3/8" AUTOMATIC VACUUM BREAKERS MORRISON BROS. FIG. 134-A	5274	—
2	3"	3" SCREWED PRESSURE/VACUUM VENT MORRISON BROS. FIG. 548 (2 OZ. PRESSURE - 1 OZ. VACUUM)	5339	—
3		TANK GAUGE - MOORMAN BROS. MODEL NO. 7-S	5277	SEE INSTALLATION DETAILS ON SAFETY- KLEEN DWG. A10243
4	3"	3" INTERNAL EMERGENCY VALVE MORRISON BROS. FIG. 272-HD W/212" FUSIBLE LINK	5267	SEE INSTALLATION DETAILS ON SAFETY- KLEEN DWG. C11302
5	3"	3" DUCTILE IRON GATE VALVE W/ROUND FLANGED ENDS - MORRISON BROS. FIG. 234-DI	5276	SEE INSTALLATION DETAILS ON SAFETY- KLEEN DWG. C11302
6	3"	3" BRONZE CHECK VALVE - MORRISON BROS. FIG. 246-A	5266	—
7	3"	3" BRONZE GATE VALVE - MORRISON BROS. FIG. 235-B LOCKING TYPE	5265	—
8	3"	3" ALUMINUM CAMLOCK QUICK COUPLING - MORRISON BROS. MALE ADAPTOR PART F W/DUST CAP & CHAIN	5264	COUPLING TO BE INSTALLED SIX (6) INCHES ABOVE DIKE WALL
9	—	NFPA MATERIAL IDENTIFICATION PLACARD	2452	DISPLAY IN PLAIN SIGHT ABOVE DIKE WALL
10	—	"COMBUSTIBLE-KEEP FIRE AWAY" SIGN	81207	DISPLAY IN PLAIN SIGHT ABOVE DIKE WALL

- GENERAL NOTES -

- (A) THIS DRAWING SUPERCEDES SAFETY-KLEEN CORP. DRAWINGS C10235 & C10236.
- (B) SEE INDIVIDUAL SERVICE CENTER SITE PLANS FOR DIKE DIMENSIONS AND RELATED INFORMATION AND ALSO LOCATION AND ARRANGEMENT OF THESE PIPING DETAILS.
- (C) ALL PIPING TO BE SCHEDULE 40 GALVANIZED AND BE SUPPORTED EVERY (8) RUNNING FEET - CONTRACTOR TO SUPPLY ALL BRACKETS, CLAMPS, ETC. AS REQUIRED FOR SUPPORTING PIPE - ALL EXPOSED THREADS AT JOINTS TO BE PAINTED WITH A RUST RESISTANT EXTERIOR GRADE PAINT. PIPING SUPPORT HARDWARE TO BE UNISTRUT BRAND OR APPROVED EQUIVALENT.
- (D) ALL DIRECTION CHANGES IN DIRTY SOLVENT LINES TO BE MADE USING A COMBINATION OF 45° ELBOWS OR LONG SWEEP 90° ELBOWS.
- (E) THIS INSTALLATION TO BE MADE WHERE NEW TANKS ARE TO BE INSTALLED AT ANY LOCATIONS PRONE TO FREEZING. SEE INSTALLATION DETAILS ON SAFETY-KLEEN DWG. C11302.
- (F) ALL ITEMS WITH SAFETY-KLEEN PART NO. REFERENCES WILL BE SUPPLIED TO CONTRACTOR.

REVISIONS				FOR BRANCH SERVICE CENTER			
NO.	DESCRIPTION	BY	DATE	SCALE	NTS	DATE	REV.
1	ADDED NOTE	C.S.	8/13/98				
2	CHANGED PART NO. 5273 TO 5339	J.S.H.	5/4/98				
3	ADDED "COMBUSTIBLE" SIGN	B.D.	1/27/98				
4	REV. GEN. NOTES NO. SYSTEM TO LETTERS	C.S.	3/26/97				
5	REMOVED 3" FLUE-ADDED VALVE/CAMLOCK	W.L.J.	3/20/95				
6	ADDED ITEM 9 TO SCHEDULE & DWG.	W.L.J.	11/3/94				
7	ADDED NOTE F	W.L.J.	10/23/94				
8	REVISED DETAIL IN NOTE E SHOWN ON DWG.	W.L.J.	12/5/93				
9	ADDED NOTE E TO NOTES & TO DWG.	W.L.J.	8/26/93				

8-24-89

BD2
PBG

USED SOLVENT STORAGE
TANK INSTALLATION DETAILS

SAFETY-KLEEN CORP.
777 ONE THREE ROAD, ELLEN, ILLINOIS 60120 PHONE 708/987-8499

11/12/98

1