

FF-02/86

CHRONOLOGICAL ENTRY FORM FOR FOLDERS

[illegible]



Lawton Chiles
Governor

Florida Department of Environmental Protection

Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33619

Virginia B. Wetherell
Secretary

DATE: 3/19/96

TIME: 1:45 pm


SUBJECT: SAFETY - KLEEN (Pre-meeting for Operating Permit renewal)
- 24th AVE.

A T T E N D E E S

Name	Affiliation	Telephone
<u>Roger Evans</u>	<u>FDEP</u>	<u>813-744-6100 x388</u>
<u>Jon ERCOLE</u>	<u>S-K</u>	<u>407-84-2560 DIRECT</u>
<u>Kim Alderman</u>	<u>Delta</u>	<u>(813)289-5218</u>
<u>Dan Phelps</u>	<u>Delta Environmental Group</u>	<u>(813)289-5218</u>
<u>Bill Crawford</u>	<u>FDEP</u>	<u>813-744-6100 ext 572</u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>

TPA-02
06/93

file 9-f
19/95



Department of Environmental Protection

Lawton Chiles
Governor

Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33619

Virginia B. Wetherell
Secretary

CERTIFIED MAIL

AUG 25 1995

Mr. Al Seyfer
Regional Manager
Safety-Kleen, Corporation
129 S. Kentucky Avenue, Suite 701
Lakeland, Florida 33801

Re: ***Safety-Kleen Corporation, FLD 980 847 271
Construction Permit HC29-210802 Tampa Facility
Approval of Class 1 Permit Modification Request for HC29-267389***

Dear Mr. Seyfer:

We are in receipt of your request for minor modifications of the permit conditions. The conditions are changed as follows:

CONDITION

Construction of a 15,000 gallon capacity hazardous waste ethylene glycol storage tank.

FROM


As stated in the issued permit and permit application.

TO

Installation of a 15,000 gallon capacity tank, and ancillary equipment, to store fresh parts washer solvent.

This letter must be attached to your permit and shall become a part of that permit.

Sincerely,


Richard D. Garrity, Ph.D.
Director of District Management
Southwest District

cc: Alan Farmer, Chief RCRA Branch, EPA Region IV
Satish Kastury, Administrator, FDEP - Tallahassee
Jon Ercole, Safety-Kleen Corporation

skmod1.doc

Memorandum

Florida Department of Environmental Protection

To: Satish Kastury
Administrator, Tallahassee

Thru: Bill Crawford, Engineer, Tampa WC
Hazardous Waste Regulation

From: Roger Evans, Engineer, Tampa RE
Hazardous Waste Regulation

Date: August 14, 1995

Subject: *Safety-Kleen Corporation, FLD 980 847 271*
Construction Permit HC29-210802 & Operating Permit HO29-158820
Minor Modification Nos. 267389, 267390, 268511, 268512
Second Response to Notice of Deficiency

Attached, please find correspondence dated August 7, 1995, which was discussed in a meeting on July 12, 1995, and is subject to the referenced permit. The package includes the following items:

1. One single page cover letter.
2. One page of instructions for updating the permit application.
3. Summary pages of revised corrections to the application.

Please incorporate this information into the application.

Attachments

cc: Alan Farmer, Chief RCRA Branch, EPA Region IV

File 9-f
12/95



August 7, 1995

RECEIVED
AUG 09 1995

Department of Environmental Protection
SOUTHWEST DISTRICT
BY _____


Mr. Roger Evans
Florida Department of
Environmental Protection
3804 Coconut Palm Drive
Tampa, FL 33619-8318

RE: Safety-Kleen Corp., Tampa, Florida FLD 980847271

Dear Mr. Evans:

Enclosed are the revised pages as agreed to during the July meeting. We are hopeful that these revisions will meet all of your requirements for use of the new tank at the Tampa facility. If you have any additional questions, please contact Mr. Jon Ercole at (407) 734-2560.

Sincerely,



Al Seyfer
Regional Manager

c: C. Norton - ERM

13113.19\01\RE080795.LTR\3

File 9-5
11/95

Instructions for Updating
Permit Application
Tampa, Florida
08/07/95

Please replace the following pages:

I.D.2-5
Table I.D.3-1
II.A.5-3
II.A.5-9
II.C.2-1
II.C.2-3
II.C.7-1C
II.C.7-1D
II.C.9-1
II.C.9-2
Subattachment II.C.1-1

Please add additional photographs to Attachment I.B.3



Lawton Chiles
Governor

Florida Department of Environmental Protection

Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33619

Virginia B. Wetherell
Secretary

DATE: 7/12/95
TIME: 10:00 AM
SUBJECT: Safety-Kleen : Discussion of responses to NOD.

A T T E N D E E S

Name	Affiliation	Telephone
<u>Cynthia Norton</u>	<u>ERM-South</u>	<u>813-622-8727</u>
<u>Jon Goble</u>	<u>Safety-Kleen</u>	<u>305-346-2171</u>
<u>Bill Crawford</u>	<u>FDEP</u>	<u>813-744-6100-382</u>
<u>Roger Evans</u>	<u>FDEP</u>	<u>744-6100 x 388</u>

Requested additional information to be submitted to the Department
with 30 days of this meeting.

RE.



June 5, 1995

RECEIVED
JUN 06 1995

Department of Environmental Protection
SOUTHWEST DISTRICT

BY _____

Mr. Roger Evans
Florida Department of
Environmental Protection
Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33619

Re: Safety-Kleen Corp., FLD980847271, Tampa Facility

Dear Mr. Evans:

Safety-Kleen Corp. (SK) is in receipt of your letter dated April 14, 1995. We have prepared the following responses to the letter.

Permit No. HC29-210802

Modification No. 267389

- i. The figures and text in the Operating Permit Application have all been changed to reflect the 15,000-gallon capacity of the new tank.
- ii. The March 13, 1995 letter was a modification to the Operating Permit Application **only**. A subsequent letter dated March 23, 1995 addressed the Construction Permit Application. The March 23, 1995 letter indicated the change in contents for the new tank. However, no replacement pages or references to revision of the Construction Permit Application were made. SK believes that, since the Construction Permit predominantly focused on the construction of the tank and not its operation, updating the Operating Permit Application prior to use of the tank system should meet the agency's need for the Permit Application to be reflective of the operation of the facility.

13113.19\01\RE060595.LTR

File 4-5
9/95

Permit No. HO29-158820

Modification No. 267390

- i. The Operating Permit Application has been reviewed for references to the management of spent antifreeze. All references have been clarified to indicate that spent antifreeze, if hazardous, is managed as a transfer waste. Revised pages are included with this submittal.
- ii. The facility still has adequate secondary containment after the addition of the third tank and installation of the canopy. Revised secondary containment calculations are included with this submittal (Figure II.C.7-2).
- iii. Spent antifreeze, if hazardous, will be managed as a transfer waste. Attachment II.A.5 - "Waste Reports" of the Operating Permit Application has been updated to reflect this information. Attachment II.A.6 - "Waste Analysis Plan" has not been updated to include spent antifreeze, since the Waste Analysis Plan addresses only those materials which are permitted for storage.

Permit No. HO29-158820

Modification No. 268511

Drawings in Attachment II.C.2 and II.C.7 have been updated to reflect the new tank and piping layout. Attachment II.C.1 is the P.E. certified tank assessment; therefore, drawings within this assessment have not been updated since the assessment is reflective of the facility at the time of the assessment. The piping layout changes, etc. do not substantially affect the tank system integrity and therefore no new assessment of the existing tanks has been conducted. An assessment has been conducted of the new tank system and is included with submittal (Sub-attachment II.C.1-1).

Permit No. HO29-158820

Modification No. 268512

Page II.C.2-3 has been updated to reflect additional information about the fabric cover. Vendor information regarding the cover is being provided as Sub-attachment II.C.2-1.

Mr. Roger Evans
June 5, 1995
Page -3-

Instructions for updating the Operating Permit Application and replacement pages for the Operating Permit Application are included with this submittal. If you have any questions, please contact Jon Ercole at (407) 734-2560.

Sincerely,



Al Seyfer
Regional Manager

chn/pjh

Enclosure(s)

c: C. Norton - ERM

Chief, Waste Management Division
U.S. EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30365

Environmental Administrator
Hazardous Waste Regulation Section
Bureau of Solid and Hazardous Waste
Department of Environmental Protection
2600 Blair Stone Road
Tallahassee, Florida 32399-2400


TABLE 1

INSTRUCTIONS FOR UPDATING THE
OPERATING PERMIT APPLICATION
TAMPA (24th AVENUE), FLORIDA
FLD 980847271
JUNE 2, 1995

Replace the following pages:

Figure I.B.3-1
Figure I.B.3-2
I.D.2-5
Table I.D.3-1
Figure II.A.1(a)-2
Figure II.A.1(a)-4
Figure II.A.1(a)-5
Figure II.A.1(c)-1
Figure II.A.4(a)-1
II.A.4(b)-2
Figure II.A.4(b)-1
Figure II.A.4(b)-3
Figure II.A.4(d)-1
Figure II.A.4(d)-3
Figure II.A.4(d)-5
II.A.5-3
Add subattachment II.C.1-1
Add subattachment II.C.2-1
Figure II.C.2-1
II.C.2-3
Figure II.C.7-1
Figure II.C.7-2

This is to certify that the modifications incorporated on this list have been examined by me and found to conform to engineering principles applicable to such facilities.


Robert W. Fox, P.E. 6-5-95
License No. 40980



Department of Environmental Protection

Lawton Chiles
Governor

Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33619

Virginia B. Wetherell
Secretary

April 14, 1995

Mr. Al Seyfer
Regional Sales Manager
Safety-Kleen Corporation
129 South Kentucky Ave., Suite 701
Lakeland, Florida 33801

Re: *Safety Kleen Corporation, FLD 980 847 271 -Tampa Facility
Minor Modification Request to Construction Permit HC29-210802
and Opertaing Permit HO29-158820
Notice of Deficiency*

Dear Mr. Seyfer:

The Florida Department of Environmental Protection (FDEP) has carefully examined your requested modifications to the above referenced permits. This review revealed several items which need clarification. Please submit a response to the following incompleteness items within 30 days of receipt of this notice:

Permit No. HC29-210802

Modification No. 267389

- i. During a site visit on April 11, 1995, DEP inspectors observed that the newly installed tank was the same height and width as the existing 15,000-gallon tanks. Please provide specifications and calculations that verify the capacity of the new tank to be 12,000-gallons.
- ii. Your cover letter, of March 13, 1995, identified that "references to the management of spent ethylene glycol (antifreeze) in a tank has been removed". If this statement refers to the construction permit, please list all pages that have either been removed, changed or replaced.

Permit No. HO29-158820

Modification No. 267390

- i. Item 6 (page II.A.5-3) states on the third line that the facility is being permitted to store antifreeze as a hazardous waste. The last sentence states that antifreeze is managed as a transfer waste. In several places throughout the application this same contradiction occurs. Please clarify this inconsistency.

- ii. Please verify that the secondary containment calculations for the current operating permit are still valid after the addition of the third tank.
- iii. A modification of the waste analysis plan for the operating permit will be required if antifreeze is managed as a hazardous waste.

Permit No. HO29-158820

Modification No. 268511

Please revise drawings, as needed, for the tank farm to include the new tank, piping layout, flow control devices, and drip pan location. An example of one such diagram that requires modification is Plate 7 of Attachment II.C.1 in the operating permit.

Permit No. HO29-158820


Modification No. 268512

Your modification request identifies that "a fabric cover has been installed over the tank farm." Please include, in the current operating permit application, a more detailed discussion of the fabric cover and its support frame.

Approval of the modifications you requested is contingent upon submittal of the above information and a satisfactory tank tightness test result for the new tank.

Please note that the new fresh parts washer solvent tank has to be registered in accordance with Chapter 62-762 F.A.C.

Sincerely,



Roger Evans
District Permitting Engineer
Hazardous Waste Section
Division of Waste Management

cc: Alan Farmer, Chief RCRA Unit, EPA Region IV
Satish Kastury, Administrator, FDEP - Tallahassee
Jon Ercole, Safety-Kleen Corporation



March 23, 1995

D.E.P.
MAR 29 1995
SOUTHWEST DISTRICT
TAMPA

Mr. Bill Crawford
Florida Department of
Environmental Protection
3804 Coconut Palm Drive
Tampa, FL 33619-8318

RE: Construction Permit Modifications, Safety-Kleen Corp., Tampa (24th Avenue), Florida;
FLD 980947271

Dear Mr. Crawford:

Safety-Kleen Corp. (Safety-Kleen) is providing the following modification to its Construction Permit for the above-referenced facility.

- Per discussions between you and Jon Ercole, a 12,000-gallon tank has been placed where the 15,000-gallon tank (for spent ethylene glycol) was proposed. The new tank will be designated for fresh parts washer solvent. All other engineering specifications for the tank remain unchanged. Modifications to the Operating Permit Application have been provided under separate cover.

Enclosed is the required \$500 permit modification fee.


13113.19/01/BC032395.LTR/1

File 9-5
2/95

Mr. Bill Crawford
March 23, 1995
Page -2-

If you have any questions or comments, please do not hesitate to contact Jon Ercole at
(407) 734-2560.

Sincerely,

A handwritten signature in black ink, appearing to read 'Al Seyfer', with a long horizontal flourish extending to the right.

Al Seyfer
Regional Sales Manager

pjh

Enclosure(s)

c: J. Ercole - Safety-Kleen
J. Grill - ERM
C. Norton - ERM

Chief, Waste Management Division
U.S. EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30365

Environmental Administrator
Hazardous Waste Regulation Section
Bureau of Solid and Hazardous Waste
Department of Environmental Protection
2600 Blair Stone Road
Tallahassee, Florida 32399-2400



Sent via Fax
Hard Copy via Postal Service

14 November 1994

Page 1 of 2

Mr. William Crawford
Florida Department of Environmental
Protection
3804 Coconut Palm Drive
Tampa, Florida 33619-8218

Re: Installation of 12,000 Gallon Product Solvent Tank @ Safety-Kleen-
Tampa Branch

Dear Mr. Crawford:

Per our recent conversations you indicated that Safety-Kleen may proceed with installing a 12,000 gal. tank at our Branch in Tampa under the current construction permit for the facility. The construction permit contains provisions for installing a 15,000 gal tank for use in storing waste ethylene glycol. To date this tank has not been installed. Current plans involve installation of a 12,000 gal. tank for storage of our 150 product solvent. During our discussions you indicated that this would not represent a significant variance to the construction permit and we could proceed with placing the tank after providing decontamination information on the tank (the proposed tank was previously used at another Safety-Kleen Facility).

Additional work beyond the placement of the tank will require a modification to the Tampa Part B Application. The modification submittal will require the following information.

- o Revised Part B Application drawings and figures showing a 12,000 gal. product solvent storage tank with the associated ancillary equipment.

- o Revised narrative pages in the Part B Application to reflect the addition of the tank and deletions of references to the ethylene glycol waste storage tank.

- o Plan for water testing the tank and the associated ancillary equipment.

- o A modification fee check in the amount of \$1,000.

File 9-f
6/94

14 November 1994

Page 2 of 2

It is our understanding that this permit modification will not require public notification. Registration of the tank with the State will be made.

If you have any additional comments concerning this Part B modification please call me at (904) 576-5979. Please acknowledge receipt of this letter by signing in block below and sending/fax a copy of the letter back to me for our records in order that we may proceed with this project. Our fax number is (904) 576-8060. Thanks.

Sincerely,




Richard R. Morris
Environmental Engineer

rrm

cc: John Ercole- S-K Environmental Engineer
Dave Paquette- S-K Engineering
Della Ridley- S-K Regional Environmental Manager

Acknowledgment of Receipt
Please Return/Fax Copy of Letter with Signature



William Crawford
Florida Dept. of Environmental Protection

Note - fees have been revised to be a couple of minor modification per each revision some to construction permit some to operating permit.

** TOTAL PAGE.03 **

PERMIT COVER MEMO

TO: RICK GARRITY, DIRECTOR OF DISTRICT MANAGEMENT

FROM/THROUGH:

WK
William Kutash,
Gary Santti,
Lynne R. Milanian,

PROGRAM ADMINISTRATOR
PROFESSIONAL ENGINEER II
DISTRICT PERMITTING ENGINEER

June 8/12

DATE: August 11, 1993

FILE NAME: Safety Kleen Corporation
PROGRAM : Hazardous Waste

PERMIT #: HC29-210802
COUNTY : Hillsborough

g-f

TYPE OF PERMIT ACTION: X MODIFY

PUBLIC NOTICE PERIOD CLOSED? N/A PETITIONS FILED? N/A

PERMIT SUMMARY: The Tampa Service Center is currently authorized to store hazardous wastes in containers and tanks. The center acts as a storage location for the various waste types until enough material has been gathered from customers to warrant a shipment to the Corporate treatment recycling facility. Safety Kleen has proposed storage of waste anti-freeze (ethylene glycol) at the center and has submitted plans to construct a 15,000 gallon tank to contain this new waste stream.

PROFESSIONAL RECOMMENDATION: X APPROVE DENY

EVALUATION SUMMARY: This permit authorizes Safety-Kleen to construct a new storage tank to contain ethylene glycol. Due to economic hardships, Safety-Kleen has been unable to construct the tank system and has requested an extension in time to begin the construction activities.

RCRA permit modifications are not subject to any time clocks.

skcovm5.doc

P 827 903 140

RECEIPT FOR CERTIFIED MAIL

NO INSURANCE COVERAGE PROVIDED
NOT FOR INTERNATIONAL MAIL
(See Reverse)

PS Form 3800, June 1985

Sent to <i>Victor San Agustin</i>	
Street and No. <i>Safety Kleen</i>	
P.O., State and ZIP Code	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt showing to whom and Date Delivered	
Return Receipt showing to whom, Date, and Address of Delivery	
TOTAL Postage and Fees	\$
Postmark or Date <i>8-20-93</i>	

*Fold at line over top of envelope to the right
of the return address*

SENDER: Complete items 1 and 2 when additional services are desired, and complete items 3 and 4.

Put your address in the "RETURN TO" Space on the reverse side. Failure to do this will prevent this card from being returned to you. The return receipt fee will provide you the name of the person delivered to and the date of delivery. For additional fees the following services are available. Consult postmaster for fees and check box(es) for additional service(s) requested.

1. ☐ Show to whom delivered, date, and addressee's address. 2. ☐ Restricted Delivery (Extra charge)

3. Article Addressed to:

**Mr. Victor San Agustin, P.E.
Regional Environmental Manager
Safety-Kleen, Corporation
129 S. Kentucky Ave, Suite 701
Lakeland, Florida 33801**

4. Article Number

P 827 903 140

Type of Service:

- ☐ Registered ☐ Insured
☒ Certified ☐ COD
☐ Express Mail ☐ Return Receipt for Merchandise

Always obtain signature of addressee or agent and DATE DELIVERED.

5. Signature — Addressee

X

6. Signature — Agent

X

7. Date of Delivery

8/23/93

8. Addressee's Address (ONLY if requested and fee paid)

UNITED STATES POSTAL SERVICE

OFFICIAL BUSINESS



SENDER INSTRUCTIONS

Print your name, address and ZIP Code in the space below.

- Complete items 1, 2, 3, and 4 on the reverse.
- Attach to front of article if space permits, otherwise affix to back of article.
- Endorse article "Return Receipt Requested" adjacent to number.



PENALTY FOR PRIVATE
USE, \$300

RETURN
TO



Print Sender's name, address, and ZIP Code in the space below.

Lynne Milamian

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION
3804 COCONUT PALM
TAMPA, FLORIDA 33619



Lawton Chiles
Governor

CERTIFIED MAIL

Florida Department of Environmental Protection

Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33619

Virginia B. Wetherell
Secretary

AUG 20 1993

Mr. Victor San Agustin, P.E.
Regional Environmental Manager
Safety-Kleen, Corporation
129 S. Kentucky Ave, Suite 701
Lakeland, Florida 33801

Re: ***Safety-Kleen Corporation, FLD 980 847 271
Construction Permit HC29-210802 Tampa Facility
Request to Modify Permit Conditions***

Dear Mr. San Agustin:

We are in receipt of your request for minor modifications of the permit conditions. The conditions are changed as follows:

<u>CONDITION</u>	<u>FROM</u>	<u>TO</u>
Date of Expiration	12/31/93	12/31/95

This letter must be attached to your permit and shall become a part of that permit.

Sincerely,

Richard D. Garrity, Ph.D.
Director of District Management
Southwest District

lrm

cc: Alan Farmer, Chief RCRA Branch, EPA Region IV
Satish Kastury, Administrator, FDEP - Tallahassee

SKmodlet.doc

State of Florida
DEPARTMENT OF ENVIRONMENTAL PROTECTION

Interoffice Memorandum

TO: Satish Kastury
Administrator, Tallahassee

THRU: Gary Santti, Professional Engineer II, Tampa
Hazardous Waste Regulation

FROM: Lynne R. Milanian, District Permitting Engineer, Tampa
Hazardous Waste Regulation *Leone 8/10*

DATE: August 6, 1993

SUBJECT: *Safety-Kleen Corporation, FLD 980 847 271*
Operating Permit File No. HC29-210802
Proof of Publication for Major Permit Modification

Attached, please find correspondence dated July 22, 1993 and submitted July 23, 1993 which is subject to the referenced permit. The package includes the following items:

1. One single page cover letter.
2. One proof of publication.
3. One affidavit.

Should you have any comments, please provide your oral response within ten days.

Attachments

cc Alan Farmer, Chief RCRA Branch, EPA Region IV

lrm

sktran.doc

State of Florida
DEPARTMENT OF ENVIRONMENTAL PROTECTION

Interoffice Memorandum

TO: Satish Kastury
Administrator, Tallahassee

THRU: *JS* Gary Santti, Professional Engineer II, Tampa
Hazardous Waste Regulation

FROM: Lynne R. Milanian, District Permitting Engineer, Tampa
Hazardous Waste Regulation *42002 8/5*

DATE: August 2, 1993

SUBJECT: *Safety-Kleen Corporation, FLD 980 847 271*
Operating Permit File No. HC29-210802
Request to Extend Permit Expiration Date

Attached, please find correspondence dated August-2, 1993 and submitted August 1, 1993 (How about that) which is subject to the referenced permit. The package includes the following items:

1. One single page cover letter requesting that the Contruction Permit be extended. The District will inform Safety-Kleen that the expiration date can be extended if the appropriate processing fee is received.

Should you have any comments, please provide your oral response within ten days.

Attachments

cc Alan Farmer, Chief RCRA Branch, EPA Region IV

lrm

sktran.doc




August 2, 1993

Hand Delivered

Ms. Lynn Milanian
Hazardous Waste Section
Florida Department of Environmental
Protection - Southwest District Office
3804 Coconut Palm Drive
Tampa, FL 33619

Subject: Request for Extension;
Construction Permit HC29-210802;
Tampa Facility, Hillsborough County;
EPA ID No. FLD 980 847 271



Dear Ms. Milanian:

Per my discussion with Mr. Gary Santti of your office on July 30, 1993, the purpose of this letter is to request that the expiration date of the referenced construction permit be extended one year, from December 31, 1993 to December 31, 1994.

We currently have not yet installed the tank mainly due to financial reasons. At this time, we are still in the process of obtaining funds to initiate and complete the installation. Although we cannot guarantee the installation of the tank this year or even next year, we still would like to have the ability to install the tank should funds become available between now and the proposed expiration date.

Your cooperation and understanding in this regard is requested. If you have any questions, please call me at (813)682-8094.

Sincerely,

Victor L. San Agustin, P.E.
Regional Environmental Manager
Tampa Region



January 8, 1993

SENT VIA FEDERAL EXPRESS
MAIL - January 8, 1993

g-f

210802

Mr. Gary Santti, P.E.
Hazardous Waste Section
Florida Department of
Environmental Regulation
Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33619-8218

RECEIVED
JAN 11 1993

Department of Environmental Regulation
SOUTH WEST DISTRICT

RE: Safety-Kleen, Corp., Tampa FLD 980 847 271
Operating Permit H029-158820
Construction Permit HC29-210802
Emergency Contact List

BY _____

Dear Mr Santti:

information placed in each application

Enclosed are four copies each of pages iii and II.A.4.(b)-3C of the Contingency Plan in the application for permit H029-158820 and page II.A.4.(b)-3 of the Contingency Plan in the application for permit HC29-210802 for the referenced facility (revised contacts and addresses). These pages should replace the pages currently in the applications.

Please contact me at (813)682-8094 should you have any questions.

Sincerely,

Victor L. San Agustin, P.E.
Regional Environmental Manager
Tampa Region

Enclosure

c: C. Norton - ERM, South
F. Blickle - Blasland, Bouck & Lee

State of Florida
DEPARTMENT OF ENVIRONMENTAL REGULATION

Interoffice Memorandum

TO: Satish Kastury
Administrator, Tallahassee

THRU: *gl* Gary Santti, Professional Engineer II, Tampa
Hazardous Waste Regulation

FROM: Lynne R. Milanian, District Permitting Engineer, Tampa
Hazardous Waste Regulation *Lynne 12/22*

DATE: December 22, 1992

SUBJECT: Safety-Kleen Corporation, FLD 980 847 271
Construction Permit Application File No. HC29-210802 *9 - f*
Tampa Service Center
Submittal Concerning Wind Loads and Internal Pressure

Attached, please find correspondence dated December 14, 1992 and submitted December 14, 1992 which is subject to the referenced application. The package includes the following items:

1. One single page cover letter.
2. One two page letter from Safety-Kleen's consultant.
3. Five pages of calculations and three pages of references.

Should you have any comments, please provide your written response within thirty days.

Attachments

cc Alan Farmer, Chief RCRA Branch, EPA Region IV

lrm



(4mm)
Pl. put with
permit application.

December 14, 1992

Hand Delivery -
December 14, 1992

Mr. Gary Santti, P.E.
Hazardous Waste Section
Florida Department of Environmental
Regulation - Southwest District
3804 Coconut Palm Drive
Tampa, FL 33619-8318

Subject: Additional Information for Waste Antifreeze Tank
Tampa Facility, Hillsborough County
EPA ID # FLD 984 171 165

Dear Mr. Santti:

This letter is in response to additional information which
you requested regarding Safety-Kleen's proposed waste
antifreeze tank for our Tampa facility.

↑ PLACED IN active application
(TANK SECTION)

Specifically, you wanted us to demonstrate that the proposed
tank can withstand significant wind loads and that the tank
as designed is able to withstand internal pressures when
full. Enclosed are six copies of calculations made by our
consultant, Blasland, Bouck, and Lee showing that the tank
can withstand both conditions.

We hope that you find our response sufficient. If you have
any questions or need additional information, please call me
at (813)682-8094.

Sincerely,

Victor L. San Agustin
Victor L. San Agustin, P.E.
Regional Environmental Manager
Tampa Region

RECEIVED
DEC 14 1992

Department of Environmental Regulation
SOUTH WEST DISTRICT
BY _____

cc: Satish Kastury, BSHW
Allan Farmer, USEPA IV

PERMIT COVER MEMO

Permit PLACED IN 9-e

TO: X RICK GARRITY, DIRECTOR OF DISTRICT MANAGEMENT

FROM/THROUGH:

William Kutash, PROGRAM ADMINISTRATOR
Gary Santti, PROFESSIONAL ENGINEER II *JS*
Lynne R. Milanian, DISTRICT PERMITTING ENGINEER *Lynne 11/5*

DATE: NOVEMBER 5, 1992

FILE NAME: Safety Kleen Corporation
PROGRAM : Hazardous Waste

PERMIT #: HC29-210802
COUNTY : Hillsborough

TYPE OF PERMIT ACTION: X ISSUE

PUBLIC NOTICE PERIOD CLOSED? YES PETITIONS FILED? NO

PERMIT SUMMARY: The Tampa Service Center is currently authorized to store hazardous wastes in containers and tanks. The center acts as a storage location for the various waste types until enough material has been gathered from customers to warrant a shipment to the Corporate treatment recycling facility. Safety Kleen has proposed storage of waste anti-freeze (ethylene glycol) at the center and has submitted plans to construct a 15,000 gallon tank to contain this new waste stream.

PROFESSIONAL RECOMMENDATION: X APPROVE DENY

EVALUATION SUMMARY: This permit authorizes Safety-Kleen to construct a new storage tank to contain ethylene glycol. As Safety-Kleen has submitted drawings and calculations demonstrating that the proposed installation will comply with Chapter 17-730 requirements permit issuance is recommended. Specific conditions have been drafted into the construction permit to include actual operation of the tank, prior to modifying the operating permit, as long as certification of completion of construction is demonstrated.

This permit was deemed complete on July 17, 1992. The public comment period ended October 26, 1992.

DAY 135 FOR THIS ACTION IS December 31, 1992.

skcovm.doc