From: Knauss, Elizabeth
To: BOSEK, JOHN E
Subject: Used Oil Secondary Containment Requirement - 40 CFR 279.45(d)
Date: Thursday, May 24, 2018 1:36:00 PM

Hi, John –

To follow up on my inspection earlier this month, have you had a chance to determine how Clean Harbors will ensure that tankers loaded with used oil are provided with secondary containment if they are parked more than 24 hours at the facility? If there is an impervious parking area with adequate containment volume, please let me know where that is, and provide the volume calculations.

Thanks,

Eizabeth Knauss
Environmental Consultant
Southwest District
Florida Department of Environmental Protection
813/470-5902