From: Igoe, Amber <amber.Igoe@dep.state.fl.us>

Sent: Friday, March 08, 2019 8:53 AM

To: Desha, David A. < <u>David.Desha@safety-kleen.com</u>> **Cc:** BOSEK, JOHN E < <u>bosek.john@cleanharbors.com</u>>

Subject: RE: Tank UT Notification

Good Morning Gentlemen,

I've spoken with the Department's Tank section and all the necessary information needed is captured in the inspection reports that were provided. Depending on the type of tank, the product that is being stored etc. triggers different notification requirements to the Department but based on the construction of the tanks and what is being stored in the tanks, the notification requirement has been met and there are no additional notifications needed at this time. In addition, the plan of conducting additional thickness measurements in the areas where the subject tank wall thickness measurements were detected at <0.1801" during its next annual UT/STI inspections and in the event any tank is determined to be not fit for use it will be emptied, taken out of service pending certified repairs or replacement and the Department will be notified is approved.

Thank you, Amber

Amber Igoe, CHMM Environmental Consultant Hazardous Waste Program and Permitting 2600 Blair Stone Rd MS 4560 Florida Department of Environmental Protection Tallahassee, FL 32399 850-245-8783

Amber.igoe@floridadep.gov

Please note: Florida has a broad public records law. Most written communications to or from state employees are public records and may be made available to the public or media upon request. This email communication, and future emails to my attention may therefore be subject to public disclosure.

From: Desha, David A. < <u>David.Desha@safety-kleen.com</u>>

Sent: Thursday, March 7, 2019 5:40 PM

To: Igoe, Amber <amber.Igoe@dep.state.fl.us>
Cc: BOSEK, JOHN E <bosek.john@cleanharbors.com>

Subject: Tank UT Notification

Good afternoon Amber,

As we discussed during our phone conversation today, the referenced facility recently completed its annual tank thickness testing. The facility received the associated tank testing reports and pursuant to Part II, Subpart B2, Condition 8., of the site's RCRA Part B Permit I provided notice that tanks T103, T104, T105 and T107 have some wall thickness measurements detected at <0.1801". The tank thickness testing was conducted by a qualified STI inspector who has certified that according to SPI SP001 these tanks are fit for use – see attachments.

The facility plans to conduct additional thickness measurements in the areas where the subject tank wall thickness measurements were detected at <0.1801" during its next annual UT/STI inspections. In the event any tank is determined to be not fit for use it will be emptied and taken out of service pending certified repairs or replacement, and the Department will be notified. As stipulated in the RCRA Part B Permit, tanks requiring extensive repairs will require certification and subsequent approval by the Department prior to being returned to service. Please contact me with any questions or comments concerning this matter.

Best regards,

Safety Starts with Me: Live It 3-6-5


David DeSha

Sr. Environmental Compliance Manager Clean Harbors Environmental Services, Inc.

Mobile: 423.413.1218

Email: desha.david@cleanharbors.com

Web: www.cleanharbors.com





"People and Technology Creating a Better Environment"

BW - Bartow, FL Facility Bartow, FL

STI SP001 Formal External Inspection of Tank 103

Inspection Date: February 13, 2019





"People and Technology Creating a Better Environment"

	Tank Information									
Unit #:	Tank Farm	Tank #:	103							
Construction Date:	1995	Design Temperature:	200°F							
In Service Date:	1995	Operating Temperature:	Ambient							
Manufacturer:	Bethlehm Steel Corp.	Bottom Material:	Carbon Steel							
Manufacturer Serial #:	Unknown	Ring Material:	N/A							
Design Standard:	UL	Shell Material:	A-36							
Cont. Release Detection Method:	RPB	Roof Material:	Carbon Steel							
Release Prevention Barrier:	Concrete	Shell Diameter:	8' 0"							
Spill Control:	Dike/Berm	Tank Height:	15' 5"							
Type of Foundation:	Concrete	Max. Design Liquid Level:	14' 0"							
Orientation:	Vertical	Product Type:	Hazardous Waste							
Bottom Type:	Cone	Specific Gravity:	1.000							
Tank Insulated:	No	Est. Capacity:	6,601 gal (US)							
CML's in Insulation:	NA	Name Plate Condition:	None							
No. of Shell Courses:	3	Plates per Shell Course:	1							

Next External Inspection: Next Internal Inspection:

Summary

Conclusion:

The thickness on the upper shell course falls below the Clean Harbors Florida RCRA permit minimum thickness which requires notification to FLDEP, but does not fall below the calculated minimum required thickness to remain in operation. As determined by the condition found during the inspection of tank# 103, the tank appears to be in suitable condition at the time of this inspection for continued operation under normal operating parameters that the tank was designed and manufactured to.

Recommendations:

1. Facility personnel should perform periodic inspections in accordance with STI SP001.



"People and Technology Creating a Better Environment"

Corrision Rates

*The below calculations are based on the average measured thickness and previous inspection thicknesses. If there is no previous measured thickness then an assumed or nominal thickness is utilized to establish a corrosion rate. The assumed thickness is based upon industry standard thickness for rolled plate steel. Remaining life could not be determined on courses where the actual thickness was greater than or equal to the past thickness readings.

*Please note that without established Condition Monitoring Location (CML) points, data collection locations may vary between inspections.

	Shell Courses											
Course Year Of Construction Measured Thickness Thickness Corrosion Rate (in./yr.) Corrosion Allowance Required Life (y												
1	1995	0.22"	0.218"	0.00008"	0.118"	0.1"	738					
2	1995	0.217"	0.205"	0.00050"	0.105"	0.1"	105					
3	1995	0.19"	0.177"	0.00054"	0.077"	0.1"	72					

	Cone											
Plate	Year Of Construction	2015 Measured Thickness	2019 Measured Thickness	Corrosion Rate (in./yr.)	Corrosion Allowance	Minimum Required	Remaining Life (yrs.)					
1	1995	0.371"	0.362"	0.00038"	0.262"	0.1"	345					
2	1995	0.375"	0.364"	0.00046"	0.264"	0.1"	287					
3	1995	0.392"	0.363"	0.00121"	0.263"	0.1"	109					
4	1995	0.384"	0.364"	0.00083"	0.264"	0.1"	159					

	Roof										
Plata Maasiirad Maasiirad						Remaining Life (yrs.)					
1	1 1995 0.322" 0.302" 0.0008" 0.202" 0.1" 127										



"People and Technology Creating a Better Environment"

External Visual Inspection

Foundation	General Condition						
Item	Acceptable	ble Findings N/I N/A Comments					
Coating condition	\boxtimes						
Concrete condition	\boxtimes						
Concrete pad				\boxtimes			
Dike walls / Containment	\boxtimes						
Drain opening in ring	\boxtimes						
Elastomeric liner				\boxtimes			
Levelness	\boxtimes						
Seal	\boxtimes						
Signs of settlement around tank	\boxtimes						
Site drainage	\boxtimes						
			•				

Foundation Support		General Condition				
Item	Acceptable	Findings	N/I	N/A	Comments	
Base Support Type					Concrete Pylons	
Coating						
Corrosion						
Fireproofing				\boxtimes		
Welds						

Shell		General Condition					
Item	Acceptable	ceptable Findings N/I N/A Comments					
Attachments							
Bottom projection plate				\boxtimes			
Coating condition							
Corrosion / Pitting		\boxtimes			Moderate corrosion or pitting		
Deformation (bulges/buckling)		\boxtimes			Minor Deformation		
Floor to shell weld				\bowtie			
Insulation				\boxtimes			
Overflow vents / piping							
Repair(s)				\boxtimes			
UT measurements		\boxtimes			Meets minimum requirement		
Weld condition							



1 eople and Technology Creating a Detter Environment									
Cathodic Protection				Gener	ral Condition				
Item	Acceptable	Findings	N/I	N/A	Comments				
Galvanized anode system				⊠					
Impressed current system				\boxtimes					
Manways / Nozzles	General Condition								
Item	Acceptable	Findings	N/I	N/A	Comments				
Bolting condition									
Coating condition	\boxtimes								
Corrosion, pitting	\boxtimes								
Flange condition	\boxtimes								
Insulation				\boxtimes					
Repad condition				\boxtimes					
UT measurements	⊠								
Weld condition	×								
Roof				Gener	ral Condition				
Item	Acceptable	Findings	N/I	N/A	Comments				
Coating condition									
Corrosion, pitting	\boxtimes								
Insulation				\boxtimes					
Proper drainage	\boxtimes								
UT measurements	×								
Weld condition									
Roof Appurtenances				Gener	ral Condition				
Item	Acceptable	Findings	N/I	N/A	Comments				
Bolting condition	\boxtimes								
Condition of hatch(s), manway(s)	\boxtimes								
Condition of pressure/vacuum vents	\boxtimes								
Condition of screens on vents	\boxtimes								
Emergency venting	\boxtimes								
Insulation seal condition				\boxtimes					
Mixer agitator	\boxtimes								
Normal venting	\boxtimes								
Appurtenances	General Condition								
Item	Acceptable	Findings	N/I	N/A	Comments				
Anchors	\boxtimes								
Gauges, Sight glass (damage)	\boxtimes								
Grounding (tightness & corrosion)	\boxtimes								



Handrails		General Condition					
Item	Acceptable	Acceptable Findings N/I N/A Comments					
Attachment welds	\boxtimes						
Coating condition	\boxtimes						
Corrosion, pitting	\boxtimes						
Safety drop bar	\boxtimes						

Platforms/Stairs/Ladders		General Condition							
Item	Acceptable	Acceptable Findings N/I N/A Comments							
Attachment weld condition	\boxtimes								
Bolting condition	\boxtimes								
Cage condition	\boxtimes								
Coating condition	\boxtimes								
Concrete base condition	\boxtimes								
Corrosion, pitting	\boxtimes								
Rung condition	\boxtimes								
Stairway tread condition	\boxtimes								

Grating		General Condition					
Item	Acceptable	cceptable Findings N/I N/A Comments					
Coating condition	\boxtimes						
Condition of grating welds	\boxtimes						
Thinning on grating bars	\boxtimes						
Tie down clips	\boxtimes						



"People and Technology Creating a Better Environment"

Measured Thicknesses Summary

	Shell Courses											
Course	Minimum	Average	Maximum	Standard Deviation								
1	0.21"	0.218"	0.232"	0.008"								
2	0.19"	0.205"	0.222"	0.009"								
3	0.117"	0.177"	0.215"	0.029"								

	Cone									
Plate	Minimum	Average	Maximum	Standard Deviation						
1	0.361"	0.362"	0.363"	0.001"						
2	0.363"	0.364"	0.364"	0"						
3	0.362"	0.363"	0.364"	0.001"						
4	0.363"	0.364"	0.365"	0.001"						

Roof							
Plate	Minimum	Average	Maximum	Standard Deviation			
1	0.249"	0.302"	0.336"	0.032"			

Measured Thicknesses

	Shell Courses									
Course #	0 °	90°	180°	270°						
	0.232"	0.220"	0.227"	0.221"						
1	0.222"	0.210"	0.217"	0.212"						
	0.228"	0.210"	0.210"	0.211"						
	0.222"	0.200"	0.190"	0.203"						
2	0.202"	0.200"	0.200"	0.202"						
	0.211"	0.193"	0.216"	0.215"						
	0.178"	0.170"	0.196"	0.200"						
3	0.153"	0.117"	0.197"	0.202"						
	0.138"	0.162"	0.198"	0.215"						



Cone						
Plate #	0°					
	0.363"					
1	0.363"					
	0.361"					
	0.364"					
2	0.363"					
	0.364"					
	0.362"					
3	0.364"					
	0.363"					
	0.365"					
4	0.363"					
	0.365"					
	Roof					
Plate #						
	0.249"					
1	0.318"					
1	0.304"					
	0.336"					



"People and Technology Creating a Better Environment"

Images



Foundation - Dike walls / Containment



Foundation Support - Coating



Roof Appurtenances - Condition of hatch(s), manway(s)



Shell - Attachments



Shell - Coating condition



"People and Technology Creating a Better Environment"

Inspection Certification Statement

Tony Gutierrez under direct supervision of Taylor Sudol (Certified Inspector) has performed an STI SP001 Formal External Inspection of Tank# 103. The tank is located at the BW - Bartow, FL Facility facility in Bartow, FL.

The thickness on the upper shell course falls below the Clean Harbors Florida RCRA permit minimum thickness which requires notification to FLDEP, but does not fall below the calculated minimum required thickness to remain in operation. As determined by the condition found during the inspection of tank# 103, the tank appears to be in suitable condition at the time of this inspection for continued operation under normal operating parameters that the tank was designed and manufactured to.

The services performed, documentation of inspection, identification of deterioration, and the generation of a report was performed within the generally accepted principles and practices of STI SP001 Standard for the inspection of above ground storage tanks 6th Edition January 2018, and Clean Harbors' Written Practice and Inspection procedures.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of the individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fines and imprisonment. My status as a Certified Inspector can be verified on the American Petroleum Institute and Steel Tank Institute websites.

API: http://directorysearch.api.org/Search.aspx

STI: https://www.steeltank.com/SP001StandardFAQs/tabid/463/Default.aspx Within question #9.

Taylor Sudol API 510# 61515 API 570# 71792

API 653# 56977

Taylor Sudal

STI SP001# AC44096 Designated Corporate Level III



"People and Technology Creating a Better Environment"

Warranty

Clean Harbors Inspection Services, Inc ("Company") has performed inspection services on the equipment designated by BW - Bartow, FL Facility (owner/operator) and has evaluated its condition based on observations and measurements made by Company's inspectors. While our evaluation accurately describes the condition of the equipment at the time of inspection, the owner/operator must independently assess the inspection information/report provided by Company and any conclusions reached by owner/operator and any action taken or omitted to be taken are the sole responsibility of the owner/operator. With respect to inspection and testing, Company warrants only that the services have been performed in accordance with accepted industry practice. If any such services fail to meet the foregoing warranty, Company shall reperform the service to the same extent and on the same conditions as the original service.

Company makes no warranty, express or implied, regarding goods or services provided by Company other than those warranties set forth herein. The preceding paragraph sets forth the exclusive remedy for claims based on failure or of defect in materials or services, whether such claim is made in contract or tort (including negligence) and however instituted, and, upon expiration of the warranty period, all such liability shall terminate. The foregoing warranty is exclusive and in lieu of all other warranties, whether written, oral, implied or statutory. NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE SHALL APPLY, nor shall Company be liable for any loss or damage whatsoever by reason of its failure to discover, report, repair or modify latent defects or defects inherent in the design of any equipment inspected. In no event, whether a result of breach of contract, warranty or tort (including negligence) shall Company be liable for any consequential or incidental damages including, but not limited to, loss of profit or revenues, loss of use of equipment tested or services by Company or any associated damage to facilities, down-time costs or claims of other damages.



"People and Technology Creating a Better Environment"

BW - Bartow, FL Facility Bartow, FL

STI SP001 Formal External Inspection of Tank 104

Inspection Date: February 13, 2019





"People and Technology Creating a Better Environment"

	Tank Information							
Unit #:	Tank Farm	Tank #:	104					
Construction Date:	1995	Design Temperature:	200°F					
In Service Date:	1995	Operating Temperature:	Ambient					
Manufacturer:	Bethlehm Steel Corp.	Bottom Material:	Carbon Steel					
Manufacturer Serial #:	Unknown	Ring Material:	N/A					
Design Standard:	UL	Shell Material:	A-36					
Cont. Release Detection Method:	RPB	Roof Material:	Carbon Steel					
Release Prevention Barrier:	Concrete	Shell Diameter:	8' 0"					
Spill Control:	Dike/Berm	Tank Height:	15' 5"					
Type of Foundation:	Concrete	Max. Design Liquid Level:	14' 0"					
Orientation:	Vertical	Product Type:	Hazardous Waste					
Bottom Type:	Cone	Specific Gravity:	1.000					
Tank Insulated:	No	Est. Capacity:	6,601 gal (US)					
CML's in Insulation:	NA	Name Plate Condition:	None					
No. of Shell Courses:	3	Plates per Shell Course:	1					

Next External Inspection: 1 year Next Internal Inspection: 1 year

Summary

Conclusion:

The thickness on the upper shell course falls below the Clean Harbors Florida RCRA permit minimum thickness which requires notification to FLDEP, but does not fall below the calculated minimum required thickness to remain in operation. As determined by the condition found during the inspection of tank# 104, the tank appears to be in suitable condition at the time of this inspection for continued operation under normal operating parameters that the tank was designed and manufactured to.

Recommendations:

1. Facility personnel should perform periodic inspections in accordance with STI SP001.



"People and Technology Creating a Better Environment"

Corrision Rates

*The below calculations are based on the average measured thickness and previous inspection thicknesses. If there is no previous measured thickness then an assumed or nominal thickness is utilized to establish a corrosion rate. The assumed thickness is based upon industry standard thickness for rolled plate steel. Remaining life could not be determined on courses where the actual thickness was greater than or equal to the past thickness readings.

*Please note that without established Condition Monitoring Location (CML) points, data collection locations may vary between inspections.

Shell Courses									
Course	Year Of Construction	2015 Measured Thickness	2019 Measured Thickness	Corrosion Rate (in./yr.)	Corrosion Allowance	Minimum Required	Remaining Life (yrs.)		
1	1995	0.227"	0.225"	0.00008"	0.125"	0.1"	782		
2	1995	0.219"	0.217"	0.00008"	0.117"	0.1"	732		
3	1995	0.22"	0.202"	0.00075"	0.102"	0.1"	68		

	Floor										
Plate	Year Of Construction	2015 Measured Thickness	2019 Measured Thickness	Corrosion Rate (in./yr.)	Corrosion Allowance	Minimum Required	Remaining Life (yrs.)				
1	1995	0.367"	0.35"	0.00071"	0.250"	0.1"	176				
2	1995	0.367"	0.342"	0.00104"	0.242"	0.1"	117				
3	1995	0.354"	0.365"	Undetermined	0.265"	0.1"	8				
4	1995	0.361"	0.353"	0.00033"	0.253"	0.1"	384				

Roof								
Plate	Year Of Construction	2015 Measured Thickness	2019 Measured Thickness	Corrosion Corrosion Minimum Remaining Rate (in./yr.) Allowance Required Life (yrs.)				
1	1995	0.34"	0.305"	0.00146"	0.205"	0.1"	70	



"People and Technology Creating a Better Environment"

External Visual Inspection

Foundation				General Condition			
Item	Acceptable	Findings	N/I	N/A	Comments		
Coating condition	\boxtimes						
Concrete condition	\boxtimes						
Concrete pad				\boxtimes			
Dike walls / Containment	\boxtimes						
Drain opening in ring	\boxtimes						
Elastomeric liner				\boxtimes			
Levelness	\boxtimes						
Seal	\boxtimes						
Signs of settlement around tank	\boxtimes						
Site drainage	\boxtimes						
			•				

Foundation Support		General Condition					
Item	Acceptable	Findings	N/I	N/A	Comments		
Base Support Type					Concrete Pylons		
Coating							
Corrosion							
Fireproofing				\boxtimes			
Welds							

Shell		General Condition						
Item	Acceptable	Findings	N/I	N/A	Comments			
Attachments								
Bottom projection plate				\boxtimes				
Coating condition								
Corrosion / Pitting		\boxtimes			Minor corrosion or pitting			
Deformation (bulges/buckling)		\boxtimes			Minor Deformation			
Floor to shell weld				×				
Insulation				\boxtimes				
Overflow vents / piping								
Repair(s)								
UT measurements					Meets minimum requirement			
Weld condition								



Cathodic Protection				Gener	ral Condition			
Item	Acceptable	Findings	N/I	N/A	Comments			
Galvanized anode system				\boxtimes				
Impressed current system				\boxtimes				
Manways / Nozzles	General Condition							
Item	Acceptable	Findings	N/I	N/A	Comments			
Bolting condition				N/11	Comments			
Coating condition								
Corrosion, pitting								
Flange condition	\boxtimes							
Insulation				\boxtimes				
Repad condition				\boxtimes				
UT measurements	\boxtimes							
Weld condition	\boxtimes							
Roof				Gener	ral Condition			
Item	Acceptable	Findings	N/I	N/A	Comments			
Coating condition	×							
Corrosion, pitting	\boxtimes							
Insulation				\boxtimes				
Proper drainage	\boxtimes							
UT measurements	⊠							
Weld condition	\boxtimes							
Roof Appurtenances				Gener	ral Condition			
Item	Acceptable	Findings	N/I	N/A	Comments			
Bolting condition	\boxtimes							
Condition of hatch(s), manway(s)	\boxtimes							
Condition of pressure/vacuum vents	\boxtimes							
Condition of screens on vents	\boxtimes							
Emergency venting	\boxtimes							
Insulation seal condition				\boxtimes				
Mixer agitator	×							
Normal venting	⊠							
Appurtenances	General Condition							
Item	Acceptable	Findings	N/I	N/A	Comments			
Anchors	×							
Gauges, Sight glass (damage)	×							
Grounding (tightness & corrosion)	\boxtimes							
	<u> </u>							



Handrails		General Condition					
Item	Acceptable	Findings	N/I	N/A	Comments		
Attachment welds	\boxtimes						
Coating condition	\boxtimes						
Corrosion, pitting	\boxtimes						
Safety drop bar	\boxtimes						

Platforms/Stairs/Ladders		General Condition					
Item	Acceptable	Findings	N/I	N/A	Comments		
Attachment weld condition	\boxtimes						
Bolting condition	\boxtimes						
Cage condition	\boxtimes						
Coating condition	\boxtimes						
Concrete base condition	\boxtimes						
Corrosion, pitting	\boxtimes						
Rung condition	\boxtimes						
Stairway tread condition	\boxtimes						

Grating		General Condition					
Item	Acceptable	Findings	N/I	N/A	Comments		
Coating condition	\boxtimes						
Condition of grating welds	\boxtimes						
Thinning on grating bars	\boxtimes						
Tie down clips	\boxtimes						



"People and Technology Creating a Better Environment"

Measured Thicknesses Summary

Shell Courses									
Course	Minimum	Average	Maximum	Standard Deviation					
1	0.222"	0.225"	0.23"	0.003"					
2	0.2"	0.217"	0.232"	0.011"					
3	0.164"	0.202"	0.22"	0.016"					

	Floor									
Plate	Minimum	Average	Maximum	Standard Deviation						
1	0.349"	0.35"	0.352"	0.001"						
2	0.34"	0.342"	0.344"	0.002"						
3	0.363"	0.365"	0.367"	0.002"						
4	0.351"	0.353"	0.354"	0.001"						

Roof							
Plate	Minimum	Average	Maximum	Standard Deviation			
1	0.29"	0.305"	0.326"	0.013"			

Measured Thicknesses

	Shell Courses										
Course #	0 °	90°	180°	270°							
	0.229"	0.229"	0.230"	0.222"							
1	0.226"	0.222"	0.224"	0.222"							
	0.225"	0.225"	0.222"	0.222"							
	0.209"	0.232"	0.229"	0.200"							
2	0.219"	0.227"	0.230"	0.211"							
	0.208"	0.217"	0.215"	0.202"							
	0.202"	0.200"	0.218"	0.180"							
3	0.192"	0.213"	0.217"	0.200"							
	0.201"	0.216"	0.220"	0.164"							



Cone								
Plate #	0°							
	0.350"							
1	0.349"							
	0.352"							
	0.340"							
2	0.344"							
	0.341"							
	0.366"							
3	0.367"							
	0.363"							
	0.354"							
4	0.353"							
	0.351"							
	Roof							
Plate #								
	0.304"							
1	0.300"							
1	0.290"							
	0.326"							



"People and Technology Creating a Better Environment"

Images



Foundation Support - Coating



Manways / Nozzles - Bolting condition



Roof Appurtenances - Condition of hatch(s), manway(s)



Shell - Coating condition



"People and Technology Creating a Better Environment"

Inspection Certification Statement

Tony Gutierrez under direct supervision of Taylor Sudol (Certified Inspector) has performed an STI SP001 Formal External Inspection of Tank# 104. The tank is located at the BW - Bartow, FL Facility facility in Bartow, FL.

The thickness on the upper shell course falls below the Clean Harbors Florida RCRA permit minimum thickness which requires notification to FLDEP, but does not fall below the calculated minimum required thickness to remain in operation. As determined by the condition found during the inspection of tank# 104, the tank appears to be in suitable condition at the time of this inspection for continued operation under normal operating parameters that the tank was designed and manufactured to.

The services performed, documentation of inspection, identification of deterioration, and the generation of a report was performed within the generally accepted principles and practices of STI SP001 Standard for the inspection of above ground storage tanks 6th Edition January 2018, and Clean Harbors' Written Practice and Inspection procedures.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of the individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fines and imprisonment. My status as a Certified Inspector can be verified on the American Petroleum Institute and Steel Tank Institute websites.

API: http://directorysearch.api.org/Search.aspx

STI: https://www.steeltank.com/SP001StandardFAQs/tabid/463/Default.aspx Within question #9.

Taylor Sudol API 510# 61515 API 570# 71792

API 653# 56977 STI SP001# AC44096

Taylor Sudal

Designated Corporate Level III



"People and Technology Creating a Better Environment"

Warranty

Clean Harbors Inspection Services, Inc ("Company") has performed inspection services on the equipment designated by BW - Bartow, FL Facility (owner/operator) and has evaluated its condition based on observations and measurements made by Company's inspectors. While our evaluation accurately describes the condition of the equipment at the time of inspection, the owner/operator must independently assess the inspection information/report provided by Company and any conclusions reached by owner/operator and any action taken or omitted to be taken are the sole responsibility of the owner/operator. With respect to inspection and testing, Company warrants only that the services have been performed in accordance with accepted industry practice. If any such services fail to meet the foregoing warranty, Company shall reperform the service to the same extent and on the same conditions as the original service.

Company makes no warranty, express or implied, regarding goods or services provided by Company other than those warranties set forth herein. The preceding paragraph sets forth the exclusive remedy for claims based on failure or of defect in materials or services, whether such claim is made in contract or tort (including negligence) and however instituted, and, upon expiration of the warranty period, all such liability shall terminate. The foregoing warranty is exclusive and in lieu of all other warranties, whether written, oral, implied or statutory. NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE SHALL APPLY, nor shall Company be liable for any loss or damage whatsoever by reason of its failure to discover, report, repair or modify latent defects or defects inherent in the design of any equipment inspected. In no event, whether a result of breach of contract, warranty or tort (including negligence) shall Company be liable for any consequential or incidental damages including, but not limited to, loss of profit or revenues, loss of use of equipment tested or services by Company or any associated damage to facilities, down-time costs or claims of other damages.




"People and Technology Creating a Better Environment"

BW - Bartow, FL Facility Bartow, FL

STI SP001 Formal External Inspection of Tank 105

Inspection Date: February 13, 2019





"People and Technology Creating a Better Environment"

	Tank Information								
Unit #:	Tank Farm	Tank #:	105						
Construction Date:	1995	Design Temperature:	200°F						
In Service Date:	1995	Operating Temperature:	Ambient						
Manufacturer:	Bethlehm Steel Corp.	Bottom Material:	Carbon Steel						
Manufacturer Serial #:	Unknown	Ring Material:	N/A						
Design Standard:	UL	Shell Material:	A-36						
Cont. Release Detection Method:	RPB	Roof Material:	Carbon Steel						
Release Prevention Barrier:	Concrete	Shell Diameter:	8' 0"						
Spill Control:	Dike/Berm	Tank Height:	15' 5"						
Type of Foundation:	Concrete	Max. Design Liquid Level:	14' 0"						
Orientation:	Vertical	Product Type:	Hazardous Waste						
Bottom Type:	Cone	Specific Gravity:	1.000						
Tank Insulated:	No	Est. Capacity:	6,601 gal (US)						
CML's in Insulation:	NA	Name Plate Condition:	None						
No. of Shell Courses:	3	Plates per Shell Course:	1						

Next External Inspection: 1 year Next Internal Inspection: 1 year

Summary

Conclusion:

The thickness on the upper shell course falls below the Clean Harbors Florida RCRA permit minimum thickness which requires notification to FLDEP, but does not fall below the calculated minimum required thickness to remain in operation. As determined by the condition found during the inspection of # 105, the appears to be in suitable condition at the time of this inspection for continued operation under normal operating parameters that the was designed and manufactured to.

Recommendations:

1. Facility personnel should perform periodic inspections in accordance with STI SP001.



"People and Technology Creating a Better Environment"

Corrision Rates

*The below calculations are based on the average measured thickness and previous inspection thicknesses. If there is no previous measured thickness then an assumed or nominal thickness is utilized to establish a corrosion rate. The assumed thickness is based upon industry standard thickness for rolled plate steel. Remaining life could not be determined on courses where the actual thickness was greater than or equal to the past thickness readings.

*Please note that without established Condition Monitoring Location (CML) points, data collection locations may vary between inspections.

Shell Courses									
Course	Year Of Construction	2015 Measured Thickness	2019 Measured Thickness	Corrosion Rate (in./yr.)	Corrosion Allowance	Minimum Required	Remaining Life (yrs.)		
1	1995	0.23"	0.225"	0.00021"	0.125"	0.1"	298		
2	1995	0.208"	0.205"	0.00013"	0.105"	0.1"	404		
3	1995	0.217"	0.214"	0.00013"	0.114"	0.1"	439		

	Cone									
Plate	Year Of Construction	2015 Measured Thickness	2019 Measured Thickness	Corrosion Rate (in./yr.)	Corrosion Allowance	Minimum Required	Remaining Life (yrs.)			
1	1995	0.365"	0.355"	0.00042"	0.255"	0.1"	304			
2	1995	0.369"	0.355"	0.00058"	0.255"	0.1"	220			
3	1995	0.367"	0.35"	0.00071"	0.250"	0.1"	176			
4	1995	0.365"	0.362"	0.00013"	0.262"	0.1"	1008			

Roof								
Plate	Year Of Construction	2015 Measured Thickness	2019 Measured Thickness	Corrosion Rate (in./yr.)	Corrosion Allowance	Minimum Required	Remaining Life (yrs.)	
1	1995	0.351"	0.322"	0.0012"	0.222"	0.1"	93	



"People and Technology Creating a Better Environment"

External Visual Inspection

Foundation	General Condition				
Item	Acceptable	Findings	N/I	N/A	Comments
Coating condition	\boxtimes				
Concrete condition	\boxtimes				
Concrete pad				\boxtimes	
Dike walls / Containment	\boxtimes				
Drain opening in ring	\boxtimes				
Elastomeric liner				\boxtimes	
Levelness	\boxtimes				
Seal	\boxtimes				
Signs of settlement around tank	\boxtimes				
Site drainage	\boxtimes				
				-	1.0 101

Foundation Support		General Condition				
Item	Acceptable	Findings	N/I	N/A	Comments	
Base Support Type					Concrete Pylons	
Coating						
Corrosion						
Fireproofing				\boxtimes		
Welds						

Shell	General Condition				
Item	Acceptable	Findings	N/I	N/A	Comments
Attachments	\boxtimes				
Bottom projection plate				\boxtimes	
Coating condition	\boxtimes				
Corrosion / Pitting		\boxtimes			Minor corrosion or pitting
Deformation (bulges/buckling)		\boxtimes			Minor Deformation
Floor to shell weld				\bowtie	
Insulation				\boxtimes	
Overflow vents / piping	\boxtimes				
Repair(s)				\boxtimes	
UT measurements		\boxtimes			Meets minimum requirement
Weld condition	\boxtimes				



	eopie unu	rechhology	Creatii			
Cathodic Protection				Gener	ral Condition	
Item	Acceptable	Findings	N/I	N/A	Comments	
Galvanized anode system				⊠		
Impressed current system				\boxtimes		
Manways / Nozzles	General Condition					
Item	Acceptable	Findings	N/I	N/A	Comments	
Bolting condition						
Coating condition	\boxtimes					
Corrosion, pitting	\boxtimes					
Flange condition	\boxtimes					
Insulation				\boxtimes		
Repad condition				\boxtimes		
UT measurements	⊠					
Weld condition	×					
Roof				Gener	ral Condition	
Item	Acceptable	Findings	N/I	N/A	Comments	
Coating condition						
Corrosion, pitting	\boxtimes					
Insulation				\boxtimes		
Proper drainage	\boxtimes					
UT measurements	×					
Weld condition						
Roof Appurtenances				Gener	ral Condition	
Item	Acceptable	Findings	N/I	N/A	Comments	
Bolting condition	\boxtimes					
Condition of hatch(s), manway(s)	\boxtimes					
Condition of pressure/vacuum vents	\boxtimes					
Condition of screens on vents	\boxtimes					
Emergency venting	\boxtimes					
Insulation seal condition				\boxtimes		
Mixer agitator	\boxtimes					
Normal venting	\boxtimes					
Appurtenances				Gener	ral Condition	
Item	Acceptable	Findings	N/I	N/A	Comments	
Anchors	\boxtimes					
Gauges, Sight glass (damage)	\boxtimes					
Grounding (tightness & corrosion)	\boxtimes					



Handrails		General Condition					
Item	Acceptable	cceptable Findings N/I N/A Comments					
Attachment welds	\boxtimes						
Coating condition	\boxtimes						
Corrosion, pitting	\boxtimes						
Safety drop bar	\boxtimes						

Platforms/Stairs/Ladders		General Condition				
Item	Acceptable	Findings	N/I	N/A	Comments	
Attachment weld condition	\boxtimes					
Bolting condition	\boxtimes					
Cage condition	\boxtimes					
Coating condition	\boxtimes					
Concrete base condition	\boxtimes					
Corrosion, pitting	\boxtimes					
Rung condition	\boxtimes					
Stairway tread condition	\boxtimes					

Grating		General Condition				
Item	Acceptable	Acceptable Findings N/I N/A Comments				
Coating condition	\boxtimes					
Condition of grating welds	\boxtimes					
Thinning on grating bars	\boxtimes					
Tie down clips	\boxtimes					



"People and Technology Creating a Better Environment"

Measured Thicknesses Summary

Shell Courses				
Course	Minimum	Average	Maximum	Standard Deviation
1	0.212"	0.225"	0.232"	0.006"
2	0.177"	0.205"	0.232"	0.016"
3	0.152"	0.214"	0.247"	0.026"

		Cone		
Plate	Minimum	Average	Maximum	Standard Deviation
1	0.354"	0.355"	0.356"	0.001"
2	0.354"	0.355"	0.356"	0.001"
3	0.349"	0.35"	0.352"	0.001"
4	0.36"	0.362"	0.364"	0.002"

		Roof		
Plate	Minimum	Average	Maximum	Standard Deviation
1	0.289"	0.322"	0.338"	0.019"

Measured Thicknesses

	Shell Courses				
Course #	0 °	90°	180°	270°	
	0.232"	0.224"	0.232"	0.212"	
1	0.222"	0.226"	0.232"	0.216"	
	0.227"	0.229"	0.229"	0.218"	
	0.232"	0.189"	0.226"	0.206"	
2	0.196"	0.177"	0.225"	0.197"	
	0.192"	0.199"	0.216"	0.203"	
	0.214"	0.200"	0.219"	0.212"	
3	0.247"	0.228"	0.152"	0.219"	
	0.244"	0.232"	0.176"	0.220"	



	Cone
Plate #	0°
	0.354"
1	0.356"
	0.355"
	0.356"
2	0.355"
	0.354"
	0.350"
3	0.349"
	0.352"
	0.364"
4	0.360"
	0.361"
	Roof
Plate #	
	0.325"
1	0.338"
1	0.289"
	0.334"



"People and Technology Creating a Better Environment"


Images



Foundation - Concrete condition



Foundation Support - Coating



Platforms/Stairs/Ladders - Cage condition



Platforms/Stairs/Ladders - Coating condition



Roof Appurtenances - Condition of hatch(s), manway(s)



Shell - Coating condition



"People and Technology Creating a Better Environment"

Inspection Certification Statement

Tony Gutierrez under direct supervision of Taylor Sudol (Certified Inspector) has performed an STI SP001 Formal External Inspection of Tank# 105. The tank is located at the BW - Bartow, FL Facility facility in Bartow, FL.

The thickness on the upper shell course falls below the Clean Harbors Florida RCRA permit minimum thickness which requires notification to FLDEP, but does not fall below the calculated minimum required thickness to remain in operation. As determined by the condition found during the inspection of # 105, the appears to be in suitable condition at the time of this inspection for continued operation under normal operating parameters that the was designed and manufactured to.

The services performed, documentation of inspection, identification of deterioration, and the generation of a report was performed within the generally accepted principles and practices of STI SP001 Standard for the inspection of above ground storage tanks 6th Edition January 2018, and Clean Harbors' Written Practice and Inspection procedures.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of the individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fines and imprisonment. My status as a Certified Inspector can be verified on the American Petroleum Institute and Steel Tank Institute websites.

API: http://directorysearch.api.org/Search.aspx

STI: https://www.steeltank.com/SP001StandardFAQs/tabid/463/Default.aspx Within question #9.

Taylor Sudol API 510# 61515 API 570# 71792

Taylor Sudal

API 653# 56977

STI SP001# AC44096 Designated Corporate Level III



"People and Technology Creating a Better Environment"

Warranty

Clean Harbors Inspection Services, Inc ("Company") has performed inspection services on the equipment designated by BW - Bartow, FL Facility (owner/operator) and has evaluated its condition based on observations and measurements made by Company's inspectors. While our evaluation accurately describes the condition of the equipment at the time of inspection, the owner/operator must independently assess the inspection information/report provided by Company and any conclusions reached by owner/operator and any action taken or omitted to be taken are the sole responsibility of the owner/operator. With respect to inspection and testing, Company warrants only that the services have been performed in accordance with accepted industry practice. If any such services fail to meet the foregoing warranty, Company shall reperform the service to the same extent and on the same conditions as the original service.

Company makes no warranty, express or implied, regarding goods or services provided by Company other than those warranties set forth herein. The preceding paragraph sets forth the exclusive remedy for claims based on failure or of defect in materials or services, whether such claim is made in contract or tort (including negligence) and however instituted, and, upon expiration of the warranty period, all such liability shall terminate. The foregoing warranty is exclusive and in lieu of all other warranties, whether written, oral, implied or statutory. NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE SHALL APPLY, nor shall Company be liable for any loss or damage whatsoever by reason of its failure to discover, report, repair or modify latent defects or defects inherent in the design of any equipment inspected. In no event, whether a result of breach of contract, warranty or tort (including negligence) shall Company be liable for any consequential or incidental damages including, but not limited to, loss of profit or revenues, loss of use of equipment tested or services by Company or any associated damage to facilities, down-time costs or claims of other damages.



"People and Technology Creating a Better Environment"

BW - Bartow, FL Facility Bartow, FL

STI SP001 Formal External Inspection of Tank 107

Inspection Date: February 13, 2019





"People and Technology Creating a Better Environment"

	Tank Information									
Unit #:	Tank Farm	Tank #:	107							
Construction Date:	2006	Design Temperature:	200°F							
In Service Date:	2006	Operating Temperature:	Ambient							
Manufacturer:	Bethlehm Steel Corp.	Bottom Material:	Carbon Steel							
Manufacturer Serial #:	Unknown	Ring Material:	N/A							
Design Standard:	UL	Shell Material:	Carbon Steel Gr Unknown							
Cont. Release Detection Method:	RPB	Roof Material:	Carbon Steel							
Release Prevention Barrier:	Concrete	Shell Diameter:	8' 0"							
Spill Control:	Dike/Berm	Tank Height:	15' 5"							
Type of Foundation:	Concrete	Max. Design Liquid Level:	14' 0"							
Orientation:	Vertical	Product Type:	Hazardous Waste							
Bottom Type:	Cone	Specific Gravity:	1.000							
Tank Insulated:	No	Est. Capacity:	6,601 gal (US)							
CML's in Insulation:	NA	Name Plate Condition:	None							
No. of Shell Courses:	4	Plates per Shell Course:	1							

Next External Inspection: 1 year Next Internal Inspection: 4 years

Summary

Conclusion:

The thickness on the upper shell course falls below the Clean Harbors Florida RCRA permit minimum thickness which requires notification to FLDEP, but does not fall below the calculated minimum required thickness to remain in operation. As determined by the condition found during the inspection of # 107, the appears to be in suitable condition at the time of this inspection for continued operation under normal operating parameters that the was designed and manufactured to.

Recommendations:

1. Facility personnel should perform periodic inspections in accordance with STI SP001.



"People and Technology Creating a Better Environment"

Corrision Rates

*The below calculations are based on the average measured thickness and previous inspection thicknesses. If there is no previous measured thickness then an assumed or nominal thickness is utilized to establish a corrosion rate. The assumed thickness is based upon industry standard thickness for rolled plate steel. Remaining life could not be determined on courses where the actual thickness was greater than or equal to the past thickness readings.

*Please note that without established Condition Monitoring Location (CML) points, data collection locations may vary between inspections.

	Shell Courses										
Course	ourse Year Of Construction Year Of Thickness Thickness				Corrosion Allowance	Minimum Required	Remaining Life (yrs.)				
1	2006	0.241"	0.237"	0.00031"	0.137"	0.1"	221				
2	2006	0.242"	0.22"	0.00169"	0.120"	0.1"	36				

	Cone											
Plate	Year Of Construction	2015 Measured Thickness	2019 Measured Thickness	Corrosion Rate (in./yr.)	Corrosion Allowance	Minimum Required	Remaining Life (yrs.)					
1	2006	0.364"	0.354"	0.00077"	0.254"	0.1"	165					
2	2006	0.377"	0.353"	0.00185"	0.253"	0.1"	69					
3	2006	0.373"	0.343"	0.00231"	0.243"	0.1"	53					
4	2006	0.357"	0.344"	0.00100"	0.244"	0.1"	122					

	Roof										
Plate	ατο Ι Νοαςιιτοι Ινιααςιιτοι Ι Ι Ι Ι						Remaining Life (yrs.)				
1	2006	2006 0.357" 0.318" 0.003" 0.218" 0.1" 3									



"People and Technology Creating a Better Environment"

External Visual Inspection

Foundation	General Condition						
Item	Acceptable	Acceptable Findings N/I N/A Comments					
Coating condition	\boxtimes						
Concrete condition	\boxtimes						
Concrete pad				\boxtimes			
Dike walls / Containment	\boxtimes						
Drain opening in ring	\boxtimes						
Elastomeric liner				\boxtimes			
Levelness	\boxtimes						
Seal	\boxtimes						
Signs of settlement around tank				\boxtimes			
Site drainage	\boxtimes						

Foundation Support		General Condition				
Item	Acceptable	Findings	N/I	N/A	Comments	
Base Support Type					Concrete Pylons	
Coating	\boxtimes					
Corrosion	\boxtimes					
Fireproofing				\boxtimes		
Welds	\boxtimes					

Shell	General Condition						
Item	Acceptable	Acceptable Findings N/I N/A Comments					
Attachments	\boxtimes						
Bottom projection plate				\boxtimes			
Coating condition	\boxtimes						
Corrosion / Pitting		\boxtimes			Minor corrosion or pitting		
Deformation (bulges/buckling)		\boxtimes			Minor Deformation		
Floor to shell weld				\boxtimes			
Insulation				\boxtimes			
Overflow vents / piping	\boxtimes						
Repair(s)				\boxtimes			
UT measurements	\boxtimes						
Weld condition	\boxtimes						



	Реоріе апа	тесппоюду	Cream	ıg a bei	ter Environment	
Cathodic Protection				Gener	ral Condition	
Item	Acceptable	Findings	N/I	N/A	Comments	
Galvanized anode system				×		
Impressed current system				\boxtimes		
Manways / Nozzles				Gener	ral Condition	
Item	Acceptable	Findings	N/I	N/A	Comments	
Bolting condition						
Coating condition	\boxtimes					
Corrosion, pitting	\boxtimes					
Flange condition	\boxtimes					
Insulation				\boxtimes		
Repad condition				\boxtimes		
UT measurements	\boxtimes					
Weld condition	\boxtimes					
Roof				Gener	ral Condition	
Item	Acceptable	Findings	N/I	N/A	Comments	
Coating condition	\boxtimes					
Corrosion, pitting	\boxtimes					
Insulation				\boxtimes		
Proper drainage	\boxtimes					
UT measurements	\boxtimes					
Weld condition	×					
Roof Appurtenances				Gene	ral Condition	
Item	Acceptable	Findings	N/I	N/A	Comments	
Bolting condition	\boxtimes					
Condition of hatch(s), manway(s)	\boxtimes					
Condition of pressure/vacuum vents	⊠					
Condition of screens on vents						
Emergency venting	\boxtimes					
Insulation seal condition				⊠		
Mixer agitator	\boxtimes					
Normal venting	×					
Appurtenances	General Condition					
Item	Acceptable	Findings	N/I	N/A	Comments	
Anchors						
Gauges, Sight glass (damage)	\boxtimes					
Grounding (tightness & corrosion)	\boxtimes					
	•			•		



Handrails		General Condition					
Item	Acceptable	Findings	N/I	N/A	Comments		
Attachment welds	\boxtimes						
Coating condition	\boxtimes						
Corrosion, pitting	\boxtimes						
Safety drop bar	\boxtimes						

Platforms/Stairs/Ladders		General Condition						
Item	Acceptable	Acceptable Findings N/I N/A Comments						
Attachment weld condition	\boxtimes							
Bolting condition	\boxtimes							
Cage condition	\boxtimes							
Coating condition	\boxtimes							
Concrete base condition	\boxtimes							
Corrosion, pitting	\boxtimes							
Rung condition	\boxtimes							
Stairway tread condition	\boxtimes							

Grating		General Condition					
Item	Acceptable	Acceptable Findings N/I N/A Comments					
Coating condition	\boxtimes						
Condition of grating welds	\boxtimes						
Thinning on grating bars	\boxtimes						
Tie down clips	\boxtimes						



0.176"

Inspection Services

"People and Technology Creating a Better Environment"

Measured Thicknesses Summary

Shell Courses											
Course	Minimum	Average	Maximum	Standard Deviation							
1	0.228"	0.237"	0.24"	0.004"							
2	0.176"	0.22"	0.24"	0.021"							

Cone					
Plate	Minimum	Average	Maximum	Standard Deviation	
1	0.352"	0.354"	0.356"	0.002"	
2	0.351"	0.353"	0.354"	0.001"	
3	0.34"	0.343"	0.344"	0.002"	
4	0.341"	0.344"	0.348"	0.003"	

Roof				
Plate	Minimum	Average	Maximum	Standard Deviation
1	0.312"	0.318"	0.321"	0.003"

Measured Thicknesses						
Shell Courses						
Course #	0 °	90°	180°	270°		
	0.229"	0.238"	0.236"	0.228"		
1	0.239"	0.240"	0.238"	0.240"		
1	0.240"	0.234"	0.240"	0.237"		
	0.237"	0.240"	0.240"	0.238"		
	0.238"	0.236"	0.234"	0.234"		
2	0.238"	0.238"	0.230"	0.212"		
	0.200"	0.240"	0.215"	0.200"		

0.240"

0.204"

0.180"



Cone				
Plate #	0°			
	0.356"			
1	0.353"			
	0.352"			
	0.354"			
2	0.353"			
	0.351"			
	0.344"			
3	0.340"			
	0.344"			
	0.341"			
4	0.348"			
	0.342"			
Roof				
Plate #				
	0.312"			
1	0.319"			
1	0.319"			
	0.321"			



"People and Technology Creating a Better Environment"


Images



Foundation Support - Coating



Roof Appurtenances - Condition of hatch(s), manway(s)



Shell - Coating condition



Shell - Corrosion / Pitting



"People and Technology Creating a Better Environment"

Inspection Certification Statement

Tony Gutierrez under direct supervision of Taylor Sudol (Certified Inspector) has performed an STI SP001 Formal External Inspection of Tank# 107. The tank is located at the BW - Bartow, FL Facility facility in Bartow, FL.

The thickness on the upper shell course falls below the Clean Harbors Florida RCRA permit minimum thickness which requires notification to FLDEP, but does not fall below the calculated minimum required thickness to remain in operation. As determined by the condition found during the inspection of # 107, the appears to be in suitable condition at the time of this inspection for continued operation under normal operating parameters that the was designed and manufactured to.

The services performed, documentation of inspection, identification of deterioration, and the generation of a report was performed within the generally accepted principles and practices of STI SP001 Standard for the inspection of above ground storage tanks 6th Edition January 2018, and Clean Harbors' Written Practice and Inspection procedures.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of the individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fines and imprisonment. My status as a Certified Inspector can be verified on the American Petroleum Institute and Steel Tank Institute websites.

API: http://directorysearch.api.org/Search.aspx

STI: https://www.steeltank.com/SP001StandardFAQs/tabid/463/Default.aspx Within question #9.

Taylor Sudol API 510# 61515 API 570# 71792

API 653# 56977 STI SP001# AC44096

Taylor Sudal

Designated Corporate Level III



"People and Technology Creating a Better Environment"

Warranty

Clean Harbors Inspection Services, Inc ("Company") has performed inspection services on the equipment designated by BW - Bartow, FL Facility (owner/operator) and has evaluated its condition based on observations and measurements made by Company's inspectors. While our evaluation accurately describes the condition of the equipment at the time of inspection, the owner/operator must independently assess the inspection information/report provided by Company and any conclusions reached by owner/operator and any action taken or omitted to be taken are the sole responsibility of the owner/operator. With respect to inspection and testing, Company warrants only that the services have been performed in accordance with accepted industry practice. If any such services fail to meet the foregoing warranty, Company shall reperform the service to the same extent and on the same conditions as the original service.

Company makes no warranty, express or implied, regarding goods or services provided by Company other than those warranties set forth herein. The preceding paragraph sets forth the exclusive remedy for claims based on failure or of defect in materials or services, whether such claim is made in contract or tort (including negligence) and however instituted, and, upon expiration of the warranty period, all such liability shall terminate. The foregoing warranty is exclusive and in lieu of all other warranties, whether written, oral, implied or statutory. NO IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE SHALL APPLY, nor shall Company be liable for any loss or damage whatsoever by reason of its failure to discover, report, repair or modify latent defects or defects inherent in the design of any equipment inspected. In no event, whether a result of breach of contract, warranty or tort (including negligence) shall Company be liable for any consequential or incidental damages including, but not limited to, loss of profit or revenues, loss of use of equipment tested or services by Company or any associated damage to facilities, down-time costs or claims of other damages.