



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

DADE CITY (352) 523-2411
LAND O' LAKES (813) 996-2411
NEW PORT RICHEY (727) 847-8902
FAX (727) 847-8112

UTILITIES SERVICES BRANCH
ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DR.
NEW PORT RICHEY, FL 34654
E-MAIL: cmulhern@pascocountyfl.net

Dept. Of Environmental Protection

APR 13 2012

Southwest District

April 9, 2012

Mr. John Morris
Waste Management Section
Florida Department of
Environmental Protection
13051 N. Telecom Pkwy.
Temple Terrace, FL 33637

RE: Hays Road Class I and III Landfill
Quarter II, 2012
Gas Monitoring

Dear Mr. Morris:

Enclosed please find the results of gas monitoring conducted at the Hays Road Class I and III Landfill as required in the permit for this facility. The gas monitoring was conducted using a CES Landtec GEM2000 Gas Meter. Calibration of the instrument was conducted prior to field analysis using a 40% methane gas and 50% LEL methane gas. The meter was allowed to run for two minutes and the highest reading obtained was recorded. All wells recorded 0.00% LEL at this site.

This completes the Quarter II, 2012 gas monitoring requirement at this facility. If you have any questions please feel free to contact me.

Sincerely,

Candia E. Mulhern
Laboratory Manager

cc: MS 4565 Solid Waste Section, Florida DEP, 2600 Blair Stone Rd., Tallahassee, FL 32399-2400
Aamod Sonawane, CDM, Westshore Center Suite 875, 1715 North Westshore Blvd., Tampa, FL 33607
Robert J. Sigmond, Utilities Fiscal Services/Special Projects Director
John Power, Solid Waste Facility Manager



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, Fl
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78441 SAMPLE ID 2MW1 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 8:45
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	8:45	WM	0.0	D	% LEL	0
METER	4/4/2012	8:45	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	8:45	WM	DRY	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78442 SAMPLE ID 4MW1 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 8:50
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	.DET. LIMIT
METER	4/4/2012	8:50	WM	0.0	D	% LEL	0
METER	4/4/2012	8:50	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	8:50	WM	20.96	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, Fl
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78443 SAMPLE ID 2MW2 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 9:07
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	9:07	WM	0.0	D	% LEL	0
METER	4/4/2012	9:07	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	9:07	WM	26.76	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78444 SAMPLE ID 4MW2 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 9:10
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	9:10	WM	0.0	D	% LEL	0
METER	4/4/2012	9:10	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	9:10	WM	27.06	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78445 SAMPLE ID 2MW4 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 9:41
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	9:41	WM	0.0	D	% LEL	0
METER	4/4/2012	9:41	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	9:41	WM	DRY	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78446 SAMPLE ID 4MW4 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 9:50
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	9:50	WM	0.0	D	% LEL	0
METER	4/4/2012	9:50	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	9:50	WM	29.17	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78447 SAMPLE ID 2MW5 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 13:40
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	13:40	WM	0.0	D	% LEL	0
METER	4/4/2012	13:40	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	13:40	WM	DRY	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY

8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123

CONTACTS:

GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78448 SAMPLE ID 4MW5 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 13:50
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	13:50	WM	0.0	D	% LEL	0
METER	4/4/2012	13:50	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	13:50	WM	26.58	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, Fl
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78449 SAMPLE ID 2MW6 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 9:15
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	9:15	WM	0.0	D	% LEL	0
METER	4/4/2012	9:15	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	9:15	WM	DRY	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78450 SAMPLE ID 4MW6 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 9:20
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	9:20	WM	0.0	D	% LEL	0
METER	4/4/2012	9:20	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	9:20	WM	29.88	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

West Pasco
Class III Landfill
Hays Road
Shady Hills, Fl
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78451 SAMPLE ID 2MW7 @ CLASS III
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 13:30
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	13:30	WM	0.0	D	% LEL	0
METER	4/4/2012	13:30	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	13:30	WM	DRY	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY

8864 GOVERNMENT DRIVE

NEW PORT RICHEY, FL 34654

PHONE 727-847-8902

NELAC E44123

CONTACTS:

GLORIA KRUEGER

CHRIS CHILDRESS

REPORT OF ANALYSES

West Pasco
Class III Landfill
Hays Road
Shady Hills, Fl
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78452 SAMPLE ID 2MW8 @ CLASS III
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 13:10
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	13:10	WM	0.0	D	% LEL	0
METER	4/4/2012	13:10	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	13:10	WM	DRT	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class III Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78453 SAMPLE ID 2MW10 @ CLASS III
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 13:00
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	13:00	WM	0.0	D	% LEL	0
METER	4/4/2012	13:00	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	13:00	WM	DRY	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78454 SAMPLE ID 4MW11D @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 10:40
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	10:40	WM	0.0	D	% LEL	0
METER	4/4/2012	10:40	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	10:40	WM	39.78	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78455 SAMPLE ID 4MW12D @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 10:50
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS	ANALYSIS							DET. LIMIT
	METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	
Percent Lower Explosive Limit	METER	4/4/2012	10:50	WM	0.0	D	% LEL	0
Percent Volume Methane	METER	4/4/2012	10:50	WM	0.0	D	% VOL	0
Water Level	DEP-SOP	4/4/2012	10:50	WM	30.25	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY

8864 GOVERNMENT DRIVE

NEW PORT RICHEY, FL 34654

PHONE 727-847-8902

NELAC E44123

CONTACTS:

GLORIA KRUEGER

CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78456 SAMPLE ID 2MW13 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 11:05
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	11:05	WM	0.0	D	% LEL	0
METER	4/4/2012	11:05	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	11:05	WM	DRY	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78457 SAMPLE ID 4MW13D @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 11:00
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	11:00	WM	0.0	D	% LEL	0
METER	4/4/2012	11:00	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	11:00	WM	29.64	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78458 SAMPLE ID 4MW14D @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 11:15
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	11:15	WM	0.0	D	% LEL	0
METER	4/4/2012	11:15	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	11:15	WM	26.72	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78459 SAMPLE ID 2MW15 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 8:59
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	8:59	WM	0.0	D	% LEL	0
METER	4/4/2012	8:59	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	8:59	WM	26.49	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78460 SAMPLE ID 2MW17S @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 10:00
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	10:00	WM	0.0	D	% LEL	0
METER	4/4/2012	10:00	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	10:00	WM	31.83	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78461 SAMPLE ID 2MW18D @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 10:10
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	10:10	WM	0.0	D	% LEL	0
METER	4/4/2012	10:10	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	10:10	WM	31.23	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78462 SAMPLE ID 2MW19 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 10:20
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane
Water Level

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	10:20	WM	0.0	D	% LEL	0
METER	4/4/2012	10:20	WM	0.0	D	% VOL	0
DEP-SOP	4/4/2012	10:20	WM	29.96	D	Feet	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78463 SAMPLE ID GMP1 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 10:05
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	10:05	WM	0.0	D	% LEL	0
METER	4/4/2012	10:05	WM	0.0	D	% VOL	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, Fl
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78464 SAMPLE ID GMP2 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 9:35
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	9:35	WM	0.0	D	% LEL	0
METER	4/4/2012	9:35	WM	0.0	D	% VOL	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78465 SAMPLE ID GMP3 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 9:30
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	9:30	WM	0.0	D	% LEL	0
METER	4/4/2012	9:30	WM	0.0	D	% VOL	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, Fl
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78466 SAMPLE ID GMP4 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 10:25
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS	ANALYSIS							DET. LIMIT
	METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	
Percent Lower Explosive Limit	METER	4/4/2012	10:25	WM	0.0	D	% LEL	0
Percent Volume Methane	METER	4/4/2012	10:25	WM	0.0	D	% VOL	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78467 SAMPLE ID GMP5 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 10:15
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	10:15	WM	0.0	D	% LEL	0
METER	4/4/2012	10:15	WM	0.0	D	% VOL	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

Resource Recovery
Class I Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78468 SAMPLE ID GMP6 @ RESREC
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:30 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 9:25
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	9:25	WM	0.0	D	% LEL	0
METER	4/4/2012	9:25	WM	0.0	D	% VOL	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

West Pasco
Class III Landfill
Hays Road
Shady Hills, FL
John Power

Date: 4/9/2012

SAMPLE NUMBER	AB78469	SAMPLE ID	LF OPERATIONS OFF @ CLASS III	SAMPLE MATRIX	GAS
DATE SAMPLED	4/4/2012			TIME SAMPLED	13:15
DATE RECEIVED	4/4/2012	SAMPLER	WMM	RECEIVED BY	AC
TIME RECEIVED	15:30	DELIVERED BY	WMM	SAMPLE TYPE	Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	13:15	WM	0.0	D	% LEL	0
METER	4/4/2012	13:15	WM	0.0	D	% VOL	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123



PASCO COUNTY, FLORIDA

"Bringing Opportunities Home"

ENVIRONMENTAL LABORATORY
8864 GOVERNMENT DRIVE
NEW PORT RICHEY, FL 34654
PHONE 727-847-8902

NELAC E44123
CONTACTS:
GLORIA KRUEGER
CHRIS CHILDRESS

REPORT OF ANALYSES

West Pasco
Class III Landfill
Hays Road
Shady Hills, Fl
John Power

Date: 4/9/2012

SAMPLE NUMBER AB78471 SAMPLE ID SCALE HOUSE @ CLASS III
DATE SAMPLED 4/4/2012
DATE RECEIVED 4/4/2012 SAMPLER WMM
TIME RECEIVED 15:00 DELIVERED BY WMM

SAMPLE MATRIX GAS
TIME SAMPLED 13:20
RECEIVED BY AC
SAMPLE TYPE
Pumped

ANALYSIS

Percent Lower Explosive Limit
Percent Volume Methane

ANALYSIS

METHOD	DATE	TIME	BY	RESULT	QUAL.	UNIT	DET. LIMIT
METER	4/4/2012	13:20	WM	0.0	D	% LEL	0
METER	4/4/2012	13:20	WM	0.0	D	% VOL	0

ANALYSIS COMMENTS:

LABORATORY DIRECTOR

THIS DOCUMENT MEETS NELAC STANDARDS

NELAC Certification # E44123