REVISIONS
A-7/22/92-PRELIMINARY ISSUE FOR INFORMATION ONLY
B-8/7/92-70%-ISSUED FOR OMS REVIEW
Ø-8/25/92-ISSUED FOR CONSTRUCTION

08-25-1992 16:58:4 CIVILGA.DGN TR

SURVEY NORTH

PREVAILING WIND

CIVIL PLOT PLAN

LEE COUNTY SOLID WASTE RESOURCE RECOVERY FACILITY

United Engineers & Constructors
A Raytheon Company

OGDEN MARTIN SYSTEMS OF LEE, INC.

DRAWN	DATE	DESIGNED	DATE
T.R.	8/24/92		
CHECKED	DATE	PROJECT NO.	SCALE
CJD	8/25/92	C-1033	1"=100'-0"
APPROVED	DATE	DRAWING NO.	SHT. # / OF / REV.
[illegible]	8/25/92	7102-E-110000	1 / 1 / Ø

MICROSTATION

Joseph M. Bennett 8/25/92

CERTIFICATE OF AUTHORIZATION NO. 4344 STATE OF OHIO

OCULUS-INSERTED-RELEASED

COMPANY CONFIDENTIAL
This drawing and all information contained herein are the property of Ogden Martin Systems, Inc. and are not to be used except as expressly authorized in writing by said company.

NOTES

1. SITE AREA IS 46.4 ACRES.
2. FOR DEWATERING PLAN, SECTIONS, OTHER NOTES & DETAILS SEE DWG. 7102-E-110001.
3. FOR ADDITIONAL DETAILS, SEE DWG. 7102-E-110003.
4. QUARTER SECTION INFORMATION IS TAKEN FROM "MAP OF BOUNDARY SURVEY OF PART OF SECTIONS 24 & 25, T44S, R26E LEE COUNTY, FLORIDA", PROJECT No. 467, FILE No. 248, BY ANDERSEN, TUTTLE & BRINDLE DATED JUNE 24, 1990.

LEGEND

- CONCRETE ROAD
- GRAVEL ROAD
- ASPHALT ROAD
- REINFORCED CONCRETE PIPE
- FLOW DIRECTION
- 25'-0 SETBACK FOR JURISDICTIONAL WETLANDS
- EXISTING CONTOUR
- G.T. #3 GREASE TRAP
- FINISH GRADE ELEVATION
- FENCE
- HEADWALL

BUILDING INDEX

- (A) TIPPING AREA
- (B) REFUSE PIT AREA
- (C) BOILER AREA
- (D) TURBINE/GENERATOR AREA
- (E) FACILITY ADMINISTRATION AREA
- (F) GRIZZLY BUILDING
- (G) RESIDUE HANDLING BUILDING
- (H) COOLING TOWER
- (K) STACK
- (L) SETTLING BASIN
- (M) APC AREA
- (N) SCALE HOUSE
- (P) FIRE WATER TANK & PUMP HOUSE
- (Q) AMMONIA STORAGE
- (R) PROPANE STORAGE
- (S) SWITCHYARD
- (T) CHLORINATION BUILDING
- (U) WATER TREATMENT BUILDING
- (Y) AMMONIA UNLOADING STATION
- (W) PROPANE UNLOADING STATION

GRAPHIC SCALE 0 50 100 150 200 250'

TYP. SECTION B-B

SCALE: 3/16"=1'-0"

TYP. SECTION A-A

SCALE: 3/16"=1'-0"

PROVIDE A FLATTER SLOPE WEST OF APC ENCL. NORTH OF BOILER AND APC ENCL. EAST AND NORTH OF RESIDUE ENCLOSURE AND OTHER LOCATIONS.

BUILDING AND ENCLOSURE FLOORS ARE ELEVATED WITH RESPECT TO OUTSIDE GRADES AS REQUIRED TO DRAIN AWAY FROM BUILDINGS AND ENCLOSURES AND STORAGE TANKS.

SECTION C-C

TYPICAL BERM DETAIL
(NOT TO SCALE)

CKD BY	DISCIPLINE	CKD BY	DISCIPLINE	CKD BY
	STRUCTURAL		INST & CONTROL	
	MECH POWER		MECH SERVICES	
	ELECTRICAL		CONSTRUCTION	
	PROCESS		CADD	
Ø	REV			