

October 4, 2014

John E. Manning District One

Cecil L Pendergrass District Two

Larry Kiker District Three

Brian Hamman District Four

Frank Mann District Five

Roger Desjarlais County Manager

Richard Wesch County Attorney

Donna Marie Collins Hearing Examiner Mr. James Standiford Florida Department of Environmental Protection 2295 Victoria Avenue P. O. Box 2549

Fort Myers, FL 33902-2549

SUBJECT: ANNUAL FIRE SAFETY SURVEY

Dear Mr. Standiford:

In accordance with Chapter 62-711.540.1.d.F.A.C. Waste Tire Rule, the Fire Safety Survey was performed on October 4, 2014 by Brigitte Kantor, Operations Manager for the Division.

Results of the survey are as follows:

- There are no activities involving the use of open flames being conducted within 25 feet of a waste tire pile.
- An emergency management plan is maintained on site, which contains the procedures to be followed in the event of a fire. This plan includes names and numbers of persons to be contacted in the event of fires, floods, or other emergencies. Adequate emergency response and communication equipment is available on site and locations are noted in the emergency plan.
- The site is bermed in order to ensure adequate protection to keep liquid runoff from a potential tire fire from entering water bodies.
- A 50-foot wide fire lane is maintained around the perimeter of the outdoor waste tire pile and access to the fire lane is unobstructed at all times.
- The site is paved and is kept free of grass and other potentially flammable vegetation.

If you have any questions regarding this survey, please call me at (239) 533-8000.

Sincerely,

**SOLID WASTE DIVISION** 

Lindsey J. Sampson, Director

cc: Mike Duff, Covanta Brigitte Kantor VIII A306

> P.O. Box 398, Fort Myers, Florida 33902-0398 (239) 533-2111 Internet address http://www.lee-county.com AN EQUAL OPPORTUNITY AFFIRMATIVE ACTION EMPLOYER