

Occupancy Name: Liberty Fire Reaching
Building Location: 9688 Rangeline Rd
Agent Owner: _____
Date of Inspection: 7-15-16

Occupancy Type: BN
Contact Person: _____
Business Phone: _____
After Hours Phone: _____

Monitoring Company: — ST LUCIE COUNTY
Sprinklers/Standpipes: — FIRE MARSHAL'S OFFICE
Number of Floors: 1 5160 NW Milner Drive
Inspector: Brian Pufmann Port St. Lucie, FL 34983
772-621-3322 FAX 772-621-3604

1. EXITS

Insufficient number
Exit signs not illuminated
Doors inoperable
Improper locks/latches
Obstructed access
Access width not adequate
No emergency egress lights

8. STANDPIPES/HOSE STATION/RISERS

Signs of rust or leaking
Fire Department Connection obstructed
Fire hose out of date
Valves not secured or tampered
Hose station doors
a. Sticking closed
b. Glass broken
Fire hose pressure reducing washers missing
Signs of rust or leaking

2. ELECTRICAL

Improper use of extension cords
Panel box/meter not accessible
Panel box - open penetrations
Electrical Room - improper storage
Improper wiring or fixtures

9. FIRE PUMPS

Not being run by drop in pressure
Piping showing signs of rust/leaking
Not maintaining maintenance records
Packing leaking excessively/need adjustment
No storage allowed in pump room

3. BUILDING AND CONTENTS

Housekeeping/improper trash
Improper storage of flammables
Unprotected openings in firewalls
Penetrations in ceilings or walls
Pressurized cylinders not secure

10. GENERATORS

Not maintaining maintenance records
Not being run weekly for 30 minute period
No storage allowed in room

4. DAY CARE FACILITIES

Adequate staff not present
Improper locks on closets/bath doors
Electrical receptacles uncovered
Teaching/artwork over 20%
Improper storage of clothing

11. STAIRWELLS

Doors not self closing and/or positive latching
Floor level sign missing
Roof access sign missing

5. FIRE PROTECTION EQUIPMENT

Fire extinguishers - improper #
Annual inspection tag
Improper type/size of extinguisher
Poor condition of cylinder
Improper location
Extinguisher cabinets and brackets

13. FIRE ALARM SYSTEM

Chute door not self closing or positive latching
Waste chute terminal room hopper door not self closing and/or positive latching
Fusible link missing/wrong temperature rating
Inspection Tag
Inspection Reports
Fire Alarm Permit #
Devices
Pull station horn/strobe inspections

6. HOOD SYSTEM

Semi annual inspection complete
Improper use of UL listed filters
Grease accumulation
Improper coverage

14. ALF/GROUP HOMES

License current
Secondary egress
Evacuation capabilities complete
Adequate staff
Improper number of clients

7. SPRINKLERS

System flow test completed
Maintain minimum of 18" clearance
Valves opened and supervised
Fire Department Connection
Fire sprinkler riser
Annual inspection tag

NO VIOLATIONS NOTED X

no violations

Failure to correct these violations by compliance date may result in the filing of civil and/or criminal charges according to Florida State Statute 633.

Signature Represents
Receipt of Notification

Reinspection Date