

October 26, 2016

Department of Environmental Protection
South District Office
Solid Waste Compliance Section
2295 Victoria Avenue, Suite 364
Fort Myers, FL 33901


RE: Sarasota County Central County Solid Waste Disposal Complex
Permit No.: 126775-003-W1/02
Waste Tire Processing Facility Permit – Annual Fire Safety Inspection Report

To Whom It May Concern:

Submitted in accordance with Part C - 9.b. of the permit is a copy of the annual fire safety inspection report with noted deficiencies and documentation of approval of the corrections by the local fire authority. The documentation for these items was not submitted within the timeframe specified in the permit and I sincerely apologize for this delay.

If you have any questions or concerns, please contact at (941) 861-1589 or lerose@scgov.net.

Sincerely,



Lois E. Rose
Manager, Solid Waste

Attachments



SARASOTA COUNTY FIRE DEPARTMENT

Serving our community with **PRIDE**
Professionalism - Responsibility - Integrity - Devotion to Duty - Excellence

5875 Hummingbird Avenue
Sarasota, FL 34241
PH (941) 861-2290
FAX (941) 925-7472

Occupant Name:	Sarasota County Tire Pile	Inspection Date:	6/13/2016
Address:	4000 Knights Trail Road	InspectionType:	Inspection - Industrial
City:	Nokomis	Inspected By:	Jim Donten 941-861-2290 jdonten@scgov.net
Zip Code:	34275		
Structure Name:	Tire Pile		
Suite:			
Occ. Sq. Ft.:	2000		

FL NFPA 01 13

Chapter 33 Outside Storage of Tires

33.1.10 Excerpt: Tires shall be removed from rims immediately upon arrival...
Tires shall be removed from rims immediately upon arrival at the storage site.

33.4.1.1 Excerpt: At a minimum, the following items shall be maintained...
At a minimum, the following items shall be maintained on site and in working order:

- (1) One 2-A:10-B:C fire extinguisher*
- (2) One 2.5 gal (10 L) water extinguisher*
- (3) One 10 ft (3 m) long pike pole*
- (4) One rigid rake*
- (5) One round point shovel*
- (6) One square point shovel*

Inspector Comments:

Inspection of exterior tire pile

We will return on or after **7/13/2016**

FAILURE TO CORRECT & PENALTIES - Pursuant to Sarasota County Code Enforcement Ordinances No. 93-006, and Chapter 162, Florida Statutes, empowered by County Ordinance 2000-052, you are notified that items noted in this report are in violation of Florida Fire Prevention Code, or Superseding Ordinances, or other County Ordinances as referenced. Failure to correct the deficiencies on the date specified can result in an affidavit or statement of violation to be filed with the Code Enforcement Special Master, charging you with the violation set out above, upon which a hearing will be held which you may attend. If the Code Enforcement Special Master finds a violation exists, penalties may be imposed in the amount of \$250.00 per day, for each day the violation exists



SARASOTA COUNTY FIRE DEPARTMENT

Serving our community with **PRIDE**
Professionalism - Responsibility - Integrity - Devotion to Duty - Excellence

5875 Hummingbird Avenue
Sarasota, FL 34241
PH (941) 861-2290
FAX (941) 925-7472

Occupant Name:	Sarasota County Tire Pile	Inspection Date:	8/25/2016
Address:	4000 Knights Trail Road	InspectionType:	Reinspection
City:	Nokomis	Inspected By:	Jim Donten 941-861-2290 jdonten@scgov.net
Zip Code:	34275		
Structure Name:	Tire Pile		
Suite:			
Occ. Sq. Ft.:	2000		

FL NFPA 01 13

Chapter 33 Outside Storage of Tires

33.1.10 Excerpt: Tires shall be removed from rims immediately upon arrival...
Tires shall be removed from rims immediately upon arrival at the storage site.

OK Violation cleared on 8/25/2016

33.4.1.1 Excerpt: At a minimum, the following items shall be maintained...
At a minimum, the following items shall be maintained on site and in working order:

- (1) One 2-A:10-B:C fire extinguisher
- (2) One 2.5 gal (10 L) water extinguisher
- (3) One 10 ft (3 m) long pike pole
- (4) One rigid rake
- (5) One round point shovel
- (6) One square point shovel

OK Violation cleared on 8/25/2016

Inspector Comments:

Operations are transitioning from open tire piles to trailer storage

Thank you for your cooperation in keeping your business and our community safe! If you have any questions, please contact the fire inspector listed at the top of this report.