

From: Lois Rose
To: [Roudebush, Rick](#)
Cc: [South District](#); [Lawrence Alexander](#); [Darrell Garrett](#); [Christopher Murray](#); [Joseph Going III](#); [James Suter](#); [Ryan S. Davidson](#); [Lois Rose](#)
Subject: WACS 51614 - Central County Solid Waste Disposal Complex - Sarasota County
Date: Friday, June 09, 2017 3:48:35 PM
Attachments: [Scanned from a Xerox Multifunction Printer.pdf](#)

Rick – a quick follow up to my call to you on Wednesday concerning the release that we had onsite during a recent rain event. The total amount of rain we received during the 2-hour period for this incident was over 3". Once the rain had subsided, staff took multiple conductivity and pH readings in the stormwater ditch where the discharge occurred. I have included a handwritten map and the results with this email. The readings were actually better downstream of the discharge area compared to the upstream readings – probably a result of the amount of stormwater coming through the system at the time. Currently everything has been contained to either Phase II Cell 4 or the stormwater ditch as the level in the ditch to discharge into SW Pond 1 did not go above the discharge weir. The water that was diverted to the Phase II Cell 4 area was sampled yesterday for surface water parameters. Laboratory testing and results have been expedited and are expected to be available this coming Tuesday. I have included photos that show the area of the discharge. Once I have the analytical data back, I will send a formal letter to the Department that will include the corrective actions taken or are in process to prevent this situation from reoccurring in the future and a plan for the Department to review and approve on how to process the water that remains in the stormwater ditch and the Phase II Cell 4 area.

*Lois Rose, Manager
Sarasota County Solid Waste
Solid Waste Operations
4000 Knights Trail Road
Nokomis, FL 34275
941.861.1589*