STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION		
C O N V E	ERSATION	RECORD
Northw	vest Distr	i c t
A. INITIAL CON	TACT:	
Department Repro	esentative: Dana Vestal	
Calling Party's Na	ame: Dave Marell	
Representing: Reg	gional Utilities, Seacrest WWTF	Permit # FLA183555 Called
Date: 12/4/2013 Water Facilities	Time: 2:44 PM CST	County: Walton Program:
Phone: (850) 699-0	0712	Contact needed: No
Callers Address: 6	6 miles west of Bay County Line	
City: Santa Rosa E	Beach	
Est. Gallons: 500	Surface Waters affected? No	Name of Water Body: None
Cleaned/Disinfected?	Lime Discharge Eliminated? Yes	Sampling requested? No

Details of Conversation: Dave Marell called to report a 500 gallon spill on 12/04/2013 at the intersection of Moonlight Beach Lane and Blue Crab Loop East in Seacrest Beach due to a contractor boring into the sewer line. The contractor was putting in a gas line for a new home. A repair clamp is being placed now to complete the repairs of the line and lime will be applied when the repairs are complete.

B. AGENCY CONTACTED AFTER CONVERSATION:

Health Department: Walton Number: (850) 892-8021 Name: Bethany Time: 2:47 PM CST Date: 12/4/2013

Shellfish: N/A

Other: N/A

C. CONVERSATION RESOLUTION:

Description of Resolution: Spill ceased and cleaned up, left notification at (850) 892-8021.

Date: 12/4/2013

D. FINAL DISPOSITION:

No further action needed. The Health Department will send an inspector to the spill location.

