

From: Comer, Laura
Sent: Friday, April 26, 2013 8:49 AM
To: 'Cranmer, Loretta'
Subject: RE: FPL Facility ID No. FLD000807370 - Response to Compliance Inspection Report

Ms. Cranmer,
Thank you for your comments and timely response to our letter.

You have indicated that the secondary containment you are using for the tanker is a temporary solution because of issues with the length of the containment. I would also point out that rain events may create issues with this solution as any rainwater that is collected in the containment will reduce the containment capacity and increase any disposal costs should you have a release. However, as long as you keep sufficient capacity available in the temporary containment you are in compliance with the requirements and I will be following up with a case closed letter shortly. With rainy season approaching I encourage you to fully evaluate the operational aspects of this method of containment. As we discussed on the phone you could also consider emptying the truck to meet the 24 hour storage time or store it inside a building (with no floor drains).

Please let us know if we can be of any further assistance. It was a pleasure working with Mr. Andreason and his crew at the facility. We appreciate FPL's commitment to environmental compliance and continuous improvement.



Laura Comer
Environmental Specialist III
SOUTH DISTRICT

**FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION**
2295 VICTORIA AVENUE, SUITE 364
P. O. BOX 2549
FORT MYERS, FL 33902-2549

Direct: 239-344-5626
Main: 239-344-5600
Fax: 850-412-0590
Laura.Comer@dep.state.fl.us