

Dregne, James

From: Rice, Timyn
Sent: Thursday, July 07, 2011 11:58 AM
To: Henry, Danielle D.
Cc: Dregne, James; Pelz, Susan; Honey, Kelly; Greenwell, Jeff; Angulo, Yanisa; Nichols, Jerry; Kelly, Steven Michael; Gibbs, Ana; Vazquez, Pamala; Douthirt, Ashley
Subject: Re: Aqua Clean
Attachments: IMG00104-20110707-1119.jpg

The fire has been extinguished and all runoff controlled. A Clean Harbors vac truck was unloading PCW into the open delivery sump when sparks from a welder ignited the vapors. The fire engulfed the delivery sump and flashed back to the vac truck. Electrical equipment and piping around the sump was destroyed. The western most treated water tank (not required to be registered) was burned but appears to be intact. All contaminated runoff appears to be contained within the delivery sump and another sump that collects all runoff from the asphalt pad. Aqua Clean is using their own vac trucks and personnel to collect the contaminated water and process on site. There are some registered tanks that did not appear to be impacted by the fire. Facility contact is W. D. Miller, 863-644-0655 or 863-712-6630 (cell). Please let me know if you need any additional info.

Timyn

Sent from my BlackBerry Wireless Device

From: Henry, Danielle D.
To: Rice, Timyn
Cc: Dregne, James; Pelz, Susan; Honey, Kelly; Greenwell, Jeff; Angulo, Yanisa; Nichols, Jerry; Kelly, Steven Michael; Gibbs, Ana; Vazquez, Pamala; Douthirt, Ashley
Sent: Thu Jul 07 10:04:23 2011
Subject: Aqua Clean
Timyn,

Once you receive word on the fire occurring now at Aqua Clean please copy the individuals noted above.

Thanks,
Danielle