

Figure 11.1-2
Safety-Kleen Sanford, Florida-Daily Inspection of Tank Equipment

INSPECTORS NAME/TITLE:

INSPECTORS SIGNATURE				
MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY

DATE (MM/DD/YY)

TIME

Pump, Flange, or Valve Number	MON	TUES	WED	THURS	FRI
1. 1½" Ball Valve	A N	A N	A N	A N	A N
2. 2" Gate Valve	A N	A N	A N	A N	A N
3. 1½" Ball Valve	A N	A N	A N	A N	A N
4. Barrel wash pump	A N	A N	A N	A N	A N
5. 1½" Ball Valve	A N	A N	A N	A N	A N
6. 1½" Ball Valve	A N	A N	A N	A N	A N
7. 2" Gate Valve	A N	A N	A N	A N	A N
8. Barrel wash pump	A N	A N	A N	A N	A N
9. 2" Flanged union	A N	A N	A N	A N	A N
10. 2" Flanged union	A N	A N	A N	A N	A N
11. 2" Flanged Valve	A N	A N	A N	A N	A N
12. Strainer	A N	A N	A N	A N	A N
13. Used solvent pump	A N	A N	A N	A N	A N
14. 2" Check Valve	A N	A N	A N	A N	A N
15. 3/8" Vacuum Breaker	A N	A N	A N	A N	A N
16. 3" Ball Valve	A N	A N	A N	A N	A N
17. 3" Emergency Gate Valve	A N	A N	A N	A N	A N
18. 3" Check Valve	A N	A N	A N	A N	A N
19. 3" Ball Valve	A N	A N	A N	A N	A N
20. 3" Camlock	A N	A N	A N	A N	A N
21. 3" Ball Valve	A N	A N	A N	A N	A N
22. 3" Emergency Gate Valve	A N	A N	A N	A N	A N
23. 3" Camlock	A N	A N	A N	A N	A N
24. 3" Ball Valve	A N	A N	A N	A N	A N
25. 3" Emergency Gate Valve	A N	A N	A N	A N	A N
26. 3" Camlock	A N	A N	A N	A N	A N
27. 3" Vacuum breaker-tank vent	A N	A N	A N	A N	A N
28. Tee and Cap	A N	A N	A N	A N	A N
29. Tee and Cap	A N	A N	A N	A N	A N
30. 2" Flanged union	A N	A N	A N	A N	A N
31. 2" Gate Valve	A N	A N	A N	A N	A N
32. 3" Flange	A N	A N	A N	A N	A N
33. 3" Flange	A N	A N	A N	A N	A N
34. Manway	A N	A N	A N	A N	A N

If "N" enter pump or valve # _____ and circle appropriate problem: potential leak, active leak, sticking, wear, does not operate smoothly, or other: _____

For all leaks and potential leaks, the Leak Detection and Repair Record (Figure 11.1-3) must be completed.

A = Acceptable N = Not Acceptable

Drinking Water Wells Listed In Public Records or Otherwise Known to the Applicant Within One-Quarter Mile of the Facility Property Boundary

After reviewing information from FDEP's GIS application Map Direct at <http://ca.dep.state.fl.us/mapdirect/gateway.isp> it was determined that there are no public or private drinking water wells located within one-quarter mile of the site.

Intake and Discharge Structures Within One Mile

There are no known intake or discharge structures within one mile.

Run-Off Control System

The facility's paved areas are sloped such that rainwater run-off is directed to the retention swales on the north and south sides of the property. Figure 2.2-5 illustrates the contours and anticipated surface water run-off direction. Overflow will discharge into the Smith Canal. Seepage from the swales percolates into the ground water and then into the same canal.

Access Control (fences, gates, etc.)

Figure 2.1-1 shows access control features.

Injection and Withdrawal Wells Both On Site and Off Site

There are no injection or withdrawal wells on site. To the best of Safety-Kleen's knowledge, there are no known injection or withdrawal wells within one-quarter mile of the facility.

Buildings and Other Structures

Buildings and other structures are shown in Figure 2.1-1.

Contours Sufficient to Show Surface Water Flow

Figure 2.2-5 shows surface water flow direction at the facility. The site is nearly flat, with surface elevations in unpaved areas. Paved areas are at slightly higher elevations. Surface water flow is directed toward the drainage catchment basins shown in Figure 2.2-5.

Drinking Water Wells Listed In Public Records or Otherwise Known to the Applicant Within One-Quarter Mile of the Facility Property Boundary

After reviewing information from FDEP's GIS application Map Direct at <http://ca.dep.state.fl.us/mapdirect/gateway.isp> it was determined that there are no public or private drinking water wells located within one-quarter mile of the site.

Intake and Discharge Structures Within One Mile

There are no known intake or discharge structures within one mile.

Run-Off Control System

The facility's paved areas are sloped such that rainwater run-off is directed to the retention swales on the north and south sides of the property. Figure 2.2-5 illustrates the contours and anticipated surface water run-off direction. Overflow will discharge into the Smith Canal. Seepage from the swales percolates into the ground water and then into the same canal.

Access Control (fences, gates, etc.)

Figure 2.1-1 shows access control features.

Injection and Withdrawal Wells Both On Site and Off Site

There are no injection or withdrawal wells on site. To the best of Safety-Kleen's knowledge, there are no known injection or withdrawal wells within one-quarter mile of the facility.

Buildings and Other Structures

Buildings and other structures are shown in Figure 2.1-1.

Contours Sufficient to Show Surface Water Flow

Figure 2.2-5 shows surface elevations at the facility. The site is nearly flat, with surface elevations in unpaved areas. Paved areas are at slightly higher elevations. Surface water flow is directed toward the drainage catchment basins shown in Figure 2.2-5.