

**From:** [Curtis, Jeff](#)  
**To:** [Russell, Merlin](#)  
**Subject:** RE: "SK Tallahassee"  
**Date:** Monday, December 01, 2014 12:51:21 PM  
**Attachments:** [image001.png](#)

---

Hi Merlin,

Thanksgiving was great and I hope you and your family enjoyed the holiday too. In regards to rainwater being discharged from the secondary containment, it would be pumped out with a handheld pump. There is no drain in the secondary containment system.

Thanks, Jeff

**Jeff Curtis** EHS Manager | Safety-Kleen | A Clean Harbors Company | Boynton Beach, FL  
| [jeff.curtis@safety-kleen.com](mailto:jeff.curtis@safety-kleen.com)

561.738.3026 (o) | 561.523.4719 (c) | 561.731.1696 (f) | [safety-kleen.com](http://safety-kleen.com)



*Safety Starts With Me! Live it 3-6-5*

---

**From:** Russell, Merlin [<mailto:Merlin.Russell@dep.state.fl.us>]  
**Sent:** Monday, December 01, 2014 12:43 PM  
**To:** Curtis, Jeff  
**Subject:** RE: "SK Tallahassee"

Good Afternoon Jeff,

Hope you had a nice Thanksgiving.

Would you check on your response to Contingency Plan comment 20? It's your response to the location of the drain when water is discharged onto the ground. I don't see where this is addressed.

I'll be here until 4:00 today if it would be easier to call. Thanks Jeff.

merlin

---

**From:** Curtis, Jeff [<mailto:Jeff.Curtis@safety-kleen.com>]  
**Sent:** Wednesday, November 26, 2014 10:22 AM  
**To:** Russell, Merlin  
**Cc:** Tripp, Anthony; Byer, James  
**Subject:** RE: "SK Tallahassee"

Good Morning Merlin,

The response for comments 24 and 25 are:

- 24. A revised copy of Figure 8.4-1 with an inspection line for any containers located on trucks during the 72-hour load and unload timeframe is enclosed.
- 25. Revised copies of these pages are enclosed.

Happy Thanksgiving to everyone.

Thanks,

**Jeff Curtis** EHS Manager | Safety-Kleen | A Clean Harbors Company | Boynton Beach, FL  
| [jeff.curtis@safety-kleen.com](mailto:jeff.curtis@safety-kleen.com)

561.738.3026 (o) | 561.523.4719 (c) | 561.731.1696 (f) | [safety-kleen.com](http://safety-kleen.com)



*Safety Starts With Me! Live it 3-6-5*

---

**From:** Russell, Merlin [<mailto:Merlin.Russell@dep.state.fl.us>]  
**Sent:** Tuesday, November 25, 2014 8:16 AM  
**To:** Curtis, Jeff  
**Cc:** Tripp, Anthony; Byer, James  
**Subject:** FW: "SK Tallahassee"

Good Morning Jeff,

As we are nearing the end of reviewing your response, Jim noticed that there is no response for comments 24 and 25. Please address those comments as quickly as possible. You can simply provide the answers in an e-mail or separate letter. You need not resubmit the entire package.

Also, Happy Thanksgiving to you and your family. Enjoy your time together.

merlin

---

**From:** Curtis, Jeff [<mailto:Jeff.Curtis@safety-kleen.com>]  
**Sent:** Tuesday, November 18, 2014 3:24 PM  
**To:** Russell, Merlin  
**Subject:** "SK Tallahassee"

Good Afternoon Merlin,

Attached is a pdf of the NOD response that is going out today via Fedex overnight to yourself. Once everything is approved I will have a complete copy of the application scanned to pdf and send a copy to your attention.

Thanks,

**Jeff Curtis** EHS Manager | Safety-Kleen | A Clean Harbors Company | Boynton Beach, FL  
| [jeff.curtis@safety-kleen.com](mailto:jeff.curtis@safety-kleen.com)

561.738.3026 (o) | 561.523.4719 (c) | 561.731.1696 (f) | [safety-kleen.com](http://safety-kleen.com)



*Safety Starts With Me! Live it 3-6-5*

