# DEPARTMENTAL DECILE

#### Florida Department of Environmental Protection

Twin Towers Office Bldg. 2600 Blair Stone Road, Tallahassee, Florida, 32399-2400

# Division of Waste Management

#### Petroleum Storage Systems

Storage Tank Facility Component Installation Site Inspection Report

# **Facility Information:**

Facility ID: 9814413 County: ST. JOHNS Inspection Date:04/21/2025

Facility Type: A - Retail Station

Facility Name: FIRST COAST ENERGY #1113 # of inspected ASTs: 0

40 SETTLEMENT DR USTs: 3

PONTE VEDRA BEACH, FL 32082 Mineral Acid Tanks: 0

Kuthkal

Latitude: 30° 6' 38.439" Longitude: 81° 25' 3.6805"

LL Method: DPHO

# **Inspection Result:**

Result: Major Out of Compliance

#### Signatures:

TKDVES - CITY OF JACKSONVILLE - ENVIRONMENTAL QUALITY DIV. (904) 255-7137

#### Storage Tank Program Office and Phone Number

James Robbins Keith Kral

Inspector Name Representative Name

Inspector Signature Representative Signature

Principal Inspector Foreman

CITY OF JACKSONVILLE - ENVIRONMENTAL UPSI

**QUALITY DIV.** 

Owners of UST facilities are reminded that the Federal Energy Policy Act of 2005 and 40 CFR 280 Subpart J requires Operator Training at all facilities by October 13, 2018. For further information please visit: https://floridadep.gov/waste/permitting-compliance-assistance/content/underground-storage-tank-operator-training

#### **Financial Responsibility:**

Financial Responsibility: INSURANCE

Insurance Carrier: NAUTILUS INSURANCE COMPANY

Effective Date: 04/23/2025 Expiration Date: 04/23/2026

# **Completed System Tests**

Туре	Date Completed	Results	Reviewed	Next Due Date	Comment
Annual Operability - Line Leak Detector	11/14/2024	Passed	04/22/2025	11/30/2025	Regular, Plus, Premium, Diesel & Non-ethanol Mechanical by Tanknology / JLR
Annual Operability - Line Leak Detector	11/01/2023	Passed	07/09/2024	11/01/2024	Regular, Plus, Premium, Diesel & Non-ethanol Mechanical by Tanknology / JLR
Annual Operability - Line Leak Detector	11/22/2021	Passed	09/13/2022	11/22/2022	Regular, Plus, Premium, Diesel & Non-ethanol Mechanical by Clemens Fuel systems / JLR
Annual Operability - Overfill Protection	11/14/2024	Passed	04/22/2025	11/30/2025	The Reg, Plus, Prem, DSL & Non-Ethanol ball floats by Tanknology / JLR
Annual Operability - Overfill Protection	11/01/2023	Passed	07/09/2024	11/01/2024	The Reg, Plus, Prem, DSL & Non-Ethanol ball floats by Tanknology / JLR
Annual Operability - Overfill Protection	12/12/2022	Passed	12/14/2022	12/12/2023	The Plus & Non-Ethanol Ball floats by UPSI / JLR
Annual Operability - Overfill Protection	10/25/2022	Passed	12/13/2022	10/25/2023	The Regular, Premium.  Diesel ball floats by AET /  JLR
Annual Operability - Release Detection	04/22/2025	Passed	04/29/2025	04/30/2026	New install Reg, Non-ethanol & plus spill visual gauges by UPSI / JLR
Annual Operability - Release Detection	11/14/2024	Passed	04/22/2025	11/30/2025	3 Interstitial sensors and 5 STP sump sensors & Visual spill bucket gauges by Tanknology / JLR
Annual Operability - Release Detection	11/01/2023	Passed	07/09/2024	11/01/2024	3 Interstitial sensors and 5 STP sump sensors & Visual spill bucket gauges by Tanknology / JLR
Annual Operability - Release Detection	10/25/2022	Passed	12/13/2022	10/25/2023	3 Interstitial sensors and 5 STP sump sensors by AET / JLR
Integrity Test - Dispenser Sump	11/22/2021	Passed	09/13/2022	11/22/2024	Disp 1/2-3/4-5/6-7/8-9/10-11 /12-13/14-15/16-17/18-19/20 hydro tested by AET / JLR
Integrity Test - Double- walled Spill Bucket	04/22/2025	Passed	04/29/2025	04/30/2028	New Install Reg, Non- ethanol, plus vacuum tested by UPSI / JLR
Integrity Test - Double- walled Spill Bucket	04/22/2025	Passed	04/29/2025	04/30/2028	Premium after gasket replacement by UPSI / JLR

Facility ID: 9814413

Integrity Test - Double- walled Spill Bucket	11/14/2024	Passed	04/22/2025	11/30/2027	Diesel DW by Tanknology / JLR
Integrity Test - Double- walled Spill Bucket	11/14/2024	Failed	04/22/2025	11/30/2024	The Regular and Plus DW spill buckets failed testing the Non-ethanol & Premium were unable to be tested by Tanknology / JLR
Integrity Test - Double- walled Spill Bucket	10/25/2022	Passed	12/13/2022	10/25/2025	The Regular, Plus, Premium, Diesel, & Non-ethanol spill buckets by AET / JLR
Integrity Test - STP Sump	11/22/2021	Passed	09/13/2022	11/22/2024	Regular, Plus, Premium, Diesel, & Non-ethanol hydro tested by AET / JLR

#### **Reviewed Records**

Record Category	Record type	From Date	To Date	Reviewed Record Comment
Three Years	Certificate of Financial Responsiblity	04/23/2025	04/23/2026	Part P / JLR

#### **Existing Violations:**

Type: Violation
Significance: SNC-B
Rule: 62-761.430(2)

Violation Text: Incident investigation not initiated within 24-hours (or by next business day) to determine if

discharge occurred.

Explanation: The Regular and Plus double walled spill buckets failed integrity testing 11/14/2024 by

Tanknology. The Premium and Non-ethanol were unable to be tested by Tanknology 11/14

/2024.

Corrective Action: Investigate issue to determine if a discharge could have occurred. Repair and or replace

failed components. Conduct testing of the Regular, Plus, Premium and non-ethanol double walled spill buckets and provide passing documentation to the EQD Inspector. Sampling

may be required.

Type: Violation Significance: SNC-B

Rule: 62-761.700(1), 62-761.700(1)(a), 62-761.700(1)(a)1, 62-761.700(1)(a)2

Violation Text: Not repaired or isolated component or piping which has not caused a discharge or release.

Explanation: The Regular and Plus double walled spill buckets failed integrity testing 11/14/2024 by

Tanknology. The Premium and Non-ethanol were unable to be tested by Tanknology 11/14

/2024.

Corrective Action: Facility must repair or replace the Regular, Plus, Premium & non-ethanol double walled spill

buckets and provide passing testing documentation to the EQD inspector. Sampling may be

required.

#### **Site Visit Comments**

04/21/2025

This is a Component Installation Inspection for the installation of Regular, Plus, and Non-ethanol Double Walled Spill Buckets at First Coast Energy #1113.

Facility ID: 9814413

General Contractor: Universal Petroleum Services Inc, CPSCC# PCC056782,

Environmental: Sampling: ECOTECH Environmental Services

30-45 day/48-72-hour notifications: Provided

On 4/21/2025, EQD inspector James Robbins met with Keith Kral with Universal Petroleum Services Inc. to conduct the inspection. The Regular, Plus, and Non-ethanol Double Walled Spill Buckets were installed. The new Regular, Plus, and Non-ethanol double walled spill buckets appeared to be in new and good condition.

SPILL CONTAINMENTs INSTALLED: Regular, Plus, and Non-ethanol EMCO Wheaton A1007, Double-walled Spill Buckets, (EQ-753).

\*\*\*NOTE: All testing for all tanks must be up to date at the time of the next Compliance Inspection.

The inspection report was completed off site and emailed to Jonathan Williams at jwilliams@firstcoastenergy.com , Karl Estock at kestock@firstcoastenergy.com , and Eddie West at ewest@universalpetro.com

# **Inspection Photos**

Added Date 04/29/2025

Facility overview



Added Date 04/29/2025

Non-ethanol test



Added Date 04/29/2025

Tank field after new spill buckets installed



Added Date 04/29/2025


Plus testing



Facility ID: 9814413

# Added Date 04/29/2025

# Regular testing



# Added Date 04/29/2025

# Testing for all 3 spill buckets

