

# JONES EDMUNDS

December 19, 2008

Ms. Susan J. Pelz, P.E.  
Florida Department of Environmental Protection  
Southwest District  
13051 North Telecom Parkway  
Temple Terrace, Florida 33637-0926

Dept. of Environmental  
Protection  
DEC 23 2008  
Southwest District


RE: Effluent/Leachate Storage Tank Calculations and Drawings Submittal  
Construction Permit No. 35435-015-SC/08,  
Effluent/Leachate Storage Tank Construction  
Southeast County Landfill, Hillsborough County, Florida  
Jones Edmunds Project No.: 08449-030-02 Task 5200

Dear Ms. Pelz:

On behalf of the Hillsborough County Solid Waste Management Department (SWMD), Jones Edmunds has prepared this submittal as required in Permit No. 35435-015-SC/08, to satisfy Specific Condition No. Part B 4.b.3). This submittal provides signed and sealed calculations and drawings for the flat-bottom, self-supporting aluminum dome-roofed effluent/leachate storage tank, as provided by Tampa Tank, Inc.

Please call me at 813-258-0703 if you have any questions or require additional information.

Sincerely,



Jason Timmons, P.E.  
Project Engineer

cc: Patricia Berry, SWMD  
Larry Ruiz, SWMD  
Megan Miller, SWMD

T:\08449 - Hillsborough\030-02 SCLF General Services\5000 - Leachate Storage Tank ERP\5200 - Effluent\_Leachate Storage Tank  
Construction Services\3150 CORR\OUT\DEP\FDEP Tank Calcs Submittal\_12\_19\_08.doc

324 South Hyde Park Avenue  
Suite 250  
Tampa, FL 33606

813.258.0703 Phone  
813.254.6860 Fax  
www.jonesedmunds.com

DEC 23 2008

Southwest District


**Flat-Bottom, Self-Supporting Aluminum  
Dome-Roof Tank Calculations  
Designed in accordance with API STD 650**

Job Number: 5350  
Tank Diameter: 70 feet  
Tank Height: 20 feet  
Service: Effluent/Leachate Tank  
Location: Woodruff and Sons, Inc.  
SE County Landfill  
Lithia, Florida  
  
Revision: 1 (10 / 17 / 08 - For Record)

THESE CALCULATIONS ARE THE PROPERTY OF TAMPA TANK, THE  
INFORMATION CONTAINED IN THESE CALCULATIONS IS PROPRIETARY  
AND IS NOT TO BE REPRODUCED OR DISTRIBUTED WITHOUT WRITTEN  
PERMISSION OF TAMPA TANK, INC.

TIMOTHY F. MULLIGAN  
5205 ADAMO DRIVE  
TAMPA, FLORIDA

FLORIDA P.E. REGISTRATION No. 54736



Design Criteria - API STD 650, 11th Edition, with applicable Appendices

The scope of API STD 650 is limited to tanks, whose bottoms are entirely and uniformly supported, designed to store liquids at approximately atmospheric pressure and at design temperatures not greater than 200°F. Appendix F provides rules for the design of tanks with internal pressures up to 2.5 psi. Appendix V provides rules for the design of tanks with external pressures up to 1.0 psi. Appendix M provides rules for the design of tanks at design temperatures not greater than 500°F. These calculations do not include any provisions for the design of tanks outside the scope of API STD 650. Tanks outside the scope of API STD 650, should be designed in accordance with a different design code.

Site Specific Data

Site Location: SE County Landfill

Lithia, Florida

Seismic Site Data: Peak Ground Acceleration:  $S_p := 3.1\%$   
(From USGS website)

0.2s Spectral Response Acceleration:  $S_S := 7.8\%$

1.0s Spectral Response Acceleration:  $S_1 := 3.1\%$

Transition Period:  
(for longer period ground motion)  $T_L := 8\text{sec}$

Seismic Site Class: SiteClass := "D"

Wind Design Data: Basic Wind Speed:  $V_{\text{wind}} := 120\text{mph}$

Exposure Category: Exposure := "C"

Snow Load: Ground Snow Load:  $S_{\text{ground}} := 0\text{psf}$

Minimum One-Day Mean Temperature: MIDT := 35°F  
(From API STD 650, Figure 4-2)

## Tank Specific Data

Product Stored: Product := "Effluent/Leachate" Design Specific Gravity:  $G_p := 1.00$

Design Internal Pressure:  $P_{int} := 0 \text{ inH}_2\text{O}$   $P_{test} := 1.25 \cdot P_{int}$   $P_{test} = 0 \cdot \text{inH}_2\text{O}$

Design External Pressure:  $P_{ext} := 1 \text{ inH}_2\text{O}$

Maximum Design Temperature:  $T_{max} := 200^\circ\text{F}$

Minimum Design Metal Temperature:  $MDMT := M1DT + 15^\circ\text{F}$   $MDMT = 50^\circ\text{F}$

Seismic Tank Data: Seismic Use Group:  $SUG := 1$

Seismic Importance Factor:  $I_E := \begin{cases} 1.0 & \text{if } SUG = 1 \\ 1.25 & \text{if } SUG = 2 \\ 1.50 & \text{otherwise} \end{cases}$   $I_E = 1$

Wind Design Data: Wind Importance Factor:  $I_W := 1.15$

Roof Loads: Roof Type:  $RoofType := \text{"SELF-SUPPORTING ALUMINUM DOME"}$

Roof Live Load:  $LL_{rf} := 20 \text{ psf}$

Roof Snow Load:  $SL_{rf} := 0.84 \cdot (S_{ground})$   $SL_{rf} = 0 \cdot \text{psf}$

Superimposed Roof Dead Load:  
(from insulation, etc.)  $SDL_{rf} := 0 \text{ psf}$

Corrosion Allowance: Unless noted otherwise the corrosion allowance will be applied to the interior surface of the bottom, shell plates and nozzles, and roof plates only.

$CA_{bt} := \frac{1}{16} \text{ in}$

$CA_{sh} := \frac{1}{16} \text{ in}$

$CA_{rf} := 0 \text{ in}$

Assumed Anchorage Type:  
(check status at end page)

$Tank\_Is\_ASSUMED\_to\_be\_Self\_Anchored := \text{"TRUE"}$

$Tank\_Is\_Self\_Anchored := Tank\_Is\_ASSUMED\_to\_be\_Self\_Anchored$

DEC 23 2008

Southwest District

Tank Shell Design

Nominal Shell Diameter:

$$D_{nom} := 70\text{ft} + 0\text{in}$$

Nominal Shell Height:

$$\text{Height} := 20\text{ft}$$

Select Rim Angle based on API STD 650, 5.1.5.9.e:

$$\text{RimAngle} := \begin{cases} \text{"L2x2x3/16"} & \text{if } D_{nom} \leq 35\text{ft} \\ \text{"L2x2x1/4"} & \text{if } 35\text{ft} < D_{nom} \leq 60\text{ft} \\ \text{"L3x3x3/8"} & \text{otherwise} \end{cases}$$

USE ==>> RimAngle := "None" <<== USE



Height of Rim Angle:  $h_{rim} = 0\text{in}$

Rim Angle Section Properties:  $A_{rim} = 0\text{in}^2$   $x_{rim} = 0\text{in}$

$t_{rim} = 0\text{in}$   $y_{rim} = 0\text{in}$

Rim Angle Diameter:  $D_{rim} := \begin{cases} D_{nom} + 2 \cdot x_{rim} & \text{if Shell_Plates\_are} = \text{"Flush-Stacked Inside"} \\ D_{nom} + 2 \cdot x_{rim} - t_{rim} & \text{if Shell_Plates\_are} = \text{"Centerline-Stacked"} \\ D_{nom} + 2 \cdot (x_{rim} - t_{rim}) & \text{if Shell_Plates\_are} = \text{"Flush-Stacked Outside"} \end{cases}$

$D_{rim} = 70\text{ft}$

Rim Angle Weight:  $DL_{rim} := \pi \cdot D_{rim} \cdot A_{rim} \cdot \gamma_s$   $DL_{rim} = 0\text{lbft}$

Shell Courses:

Number of Shell Courses:

$$n_{sh} := 2$$

Thicknesses Overrides  
(0 in. indicates no override)

Top Shell Course:

$$h_1 := 120\text{in}$$

$$t_1 := 0\text{in}$$

Bottom Shell Course

$$h_2 := 120\text{in}$$

$$t_2 := 0\text{in}$$

Shell Height:  
(including Rim Angle)

$$H_{sh} := \sum_{i=1}^{n_{sh}} h_i + h_{rim}$$

$$H_{sh} = 20\text{-ft}$$

$$H_{sh} = 240\text{-in}$$

Minimum Shell Plate Thickness:  
(per 5.6.1.1)

$$t_{min} = 0.25\text{-in}$$

$$t_{min} := \begin{cases} 0.1875\text{in} & \text{if } D_{nom} < 50\text{ft} \\ 0.25\text{in} & \text{if } 50\text{ft} \leq D_{nom} < 120\text{ft} \\ 0.3125\text{in} & \text{if } 120\text{ft} \leq D_{nom} \leq 200\text{ft} \\ 0.375\text{in} & \text{if } 200\text{ft} < D_{nom} \end{cases}$$

## Tank Bottom Design

Minimum Thickness per 5.4.1:

$$t_{bt.min} := \frac{1}{4} \text{ in} + CA_{bt}$$

Bottom Plate Thickness:

$$t_{bt} := t_{bt.min}$$

$$t_{bt} = 0.313 \cdot \text{in}$$

Bottom Plate Yield Strength:

$$F_{y_{bt}} := 36000 \text{ psi}$$

Is there an Annular Plate?:

$$\text{Tank\_Has\_Annular\_Plate} := \text{"FALSE"}$$

Annular Plate Thickness:

$$t_{annpl} := \frac{5}{16} \text{ in}$$

Annular Plate Yield Strength:

$$F_{y_{annpl}} := 36000 \text{ psi}$$

Bottom Configuration:

$$\text{Bottom\_Is} := \text{"Cone Down"}$$

Bottom Slope:

$$\text{Slope}_{bt} = -1 \cdot \frac{\text{in}}{10 \text{ ft}}$$

$$\text{Slope}_{bt} := \begin{cases} \frac{1 \text{ in}}{10 \text{ ft}} & \text{if Bottom\_Is = "Crown Up"} \\ 0 & \text{if Bottom\_Is = "Flat"} \\ \frac{-1 \text{ in}}{10 \text{ ft}} & \text{if Bottom\_Is = "Cone Down"} \end{cases}$$

Height of Bottom Slope:

$$H_{bt.slope} := \frac{D_{nom}}{2} \cdot \text{Slope}_{bt}$$

$$H_{bt.slope} = -3.5 \cdot \text{in}$$



Self-Supporting Aluminum Dome Roof Design per Appendix G

$$D_{rf} := D_{nom} \quad D_{rf} = 70 \cdot ft$$

Roof Gravity Loads:

$$LL_{design} := \max\left[\left(\max(LL_{rf}, SL_{rf}) + 0.4 \cdot P_{ext}\right), \left(P_{ext} + 0.4 \cdot \max(LL_{rf}, SL_{rf})\right)\right] \quad LL_{design} = 22.08 \cdot psf$$

Roof Design:

Roof\_Design\_is := "by Dome Roof Manufacturer"



## Tank Nominal Capacity

<u>Product Height:</u>	Freeboard Height:	$H_{frbd} := 1.375 \text{ in}$	
	Overfill Protection Height:	$H_{ofp} := 6 \text{ in}$	
	Minimum Fill Level:	$H_{min} := 6 \text{ in}$	
	Design Product Height:	$H_P := H_{sh} - H_{frbd}$	$H_P = 19.885 \text{ ft}$

<u>Maximum Capacity:</u>	Capacity at Design Liquid Level:	$V_{max} := \left(\frac{\pi}{4}\right) \cdot D_{nom}^2 \cdot \left(H_P - \frac{H_{bt.slope}}{3}\right)$	
		$V_{max} = 76.902 \times 10^3 \cdot \text{ft}^3$	$V_{max} = 575.268 \times 10^3 \cdot \text{gal}$

Minimum Operating Volume:

$$V_{min} := \begin{cases} \left(\frac{\pi}{4}\right) \cdot D_{nom}^2 \cdot \left(H_{min} - \frac{H_{bt.slope}}{3}\right) & \text{if } H_{min} \geq H_{bt.slope} \\ \left(\frac{\pi}{4}\right) \cdot D_{nom}^2 \cdot \left(H_{min} - \frac{H_{bt.slope}}{3}\right) - \frac{\pi \cdot (H_{bt.slope} - H_{min})^3}{6 \cdot \text{Slope}_{bt}^2} & \text{otherwise} \end{cases}$$

$$V_{min} = 2.298 \times 10^3 \cdot \text{ft}^3 \quad V_{min} = 17.193 \times 10^3 \cdot \text{gal}$$

Overfill Protection Volume:

$$V_{ofp} := \left(\frac{\pi}{4}\right) \cdot D_{nom}^2 \cdot H_{ofp}$$
$$V_{ofp} = 1.924 \times 10^3 \cdot \text{ft}^3 \quad V_{ofp} = 14.394 \times 10^3 \cdot \text{gal}$$

Net Working Capacity:

$$V_{net} := V_{max} - V_{ofp} - V_{min}$$
$$V_{net} = 72.680 \times 10^3 \cdot \text{ft}^3 \quad V_{net} = 543.681 \times 10^3 \cdot \text{gal}$$

Nominal Weight of Product:

$$W_P := V_{max} \cdot G_P \cdot \gamma_w \quad W_P = 4.799 \times 10^6 \cdot \text{lb}$$

Tank Shell Plate Design (Top Shell Course)

$i := 1$

Material Specification: (ASTM - UON)

$PL\_spec_i := \text{"Appendix A (E=0.70)"}$

Mechanical Properties:

Specified Yield Strength:

$Fy_i := FY(PL\_spec_i)$

$Fy_i = 31500 \cdot \text{psi}$

Design Yield Strength:

$Fy_{dsn_i} := FY_{Mod}(PL\_spec_i)$

$Fy_{dsn_i} = 31500 \cdot \text{psi}$

Specified Tensile Strength:

$Fu_i := FU(PL\_spec_i)$

$Fu_i = 55000 \cdot \text{psi}$

Allowable Tensile Stress:

Specified Allowable Stress:  
(per Table 5-2)

$Sd(PL\_spec_i) = 21000 \cdot \text{psi}$

Design Allowable Stress:  
(per Appendix M)

$S_{d_i} := \min\left(\frac{2}{3} \cdot Fy_{dsn_i}, Sd(PL\_spec_i)\right)$   $S_{d_i} = 21000 \cdot \text{psi}$

Testing Allowable Stress:  
(per Table 5-2)

$S_{t_i} := St(PL\_spec_i)$

$S_{t_i} = 21000 \cdot \text{psi}$

Joint Efficiency:

$JE_i := 0.70$

Liquid Height:

$h_{p_i} := H_P - \sum_{j=i+1}^{n_{sh}} h_j$

$h_{p_i} = 9.885 \cdot \text{ft}$

Design Required Thickness:  
(incl. corrosion allowance)

$t_{d_i} := \frac{2.6 \left( \frac{h_{p_i} + \frac{P_{int}}{\gamma_w \cdot G_P}}{\text{ft}} - 1 \right) \cdot \left( \frac{D_{nom}}{\text{ft}} \right) \cdot G_P}{\left( \frac{S_{d_i}}{\text{psi}} \right) \cdot JE_i} \cdot \text{in} + CA_{sh}$

$t_{d_i} = 0.173 \cdot \text{in}$

Testing Required Thickness:

$t_{t_i} := \frac{2.6 \left( \frac{h_{p_i} + \frac{P_{test}}{\gamma_w}}{\text{ft}} - 1 \right) \cdot \left( \frac{D_{nom}}{\text{ft}} \right)}{\left( \frac{S_{t_i}}{\text{psi}} \right) \cdot JE_i} \cdot \text{in}$

$t_{t_i} = 0.11 \cdot \text{in}$

Nominal Thickness Used:

$t_i := \frac{\text{ceil} \left( \max \left( \frac{t_{d_i}}{\text{in}}, \frac{t_{t_i}}{\text{in}}, \frac{t_{min}}{\text{in}}, \frac{t_i}{\text{in}} \right) \cdot 16 \right)}{16} \cdot \text{in}$

$t_i = 0.25 \cdot \text{in}$

Check maximum thickness for material specified:

$t_{max}(PL\_spec_i) = 0.5 \cdot \text{in}$

$(t_i \leq t_{max}(PL\_spec_i)) = 1$

$1 = \text{TRUE}, \implies \text{OK}$

Tank Shell Plate Design (Bottom Shell Course)

$$i := n_{sh}$$

$$i = 2$$

Material Specification: (ASTM - UON)

$$PL\_spec_i := "Appendix A (E=0.70)"$$

Mechanical Properties:

Specified Yield Strength:

$$F_{y_i} := F_Y(PL\_spec_i)$$

$$F_{y_i} = 31500 \cdot \text{psi}$$

Design Yield Strength:

$$F_{y\_dsn_i} := F_{Y\_Mod}(PL\_spec_i)$$

$$F_{y\_dsn_i} = 31500 \cdot \text{psi}$$

Specified Tensile Strength:

$$F_{u_i} := F_U(PL\_spec_i)$$

$$F_{u_i} = 55000 \cdot \text{psi}$$

Allowable Tensile Stress:

Specified Allowable Stress:  
(per Table 5-2)

$$S_d(PL\_spec_i) = 21000 \cdot \text{psi}$$

Design Allowable Stress:  
(per Appendix M)

$$S_{d_i} := \min\left(\frac{2}{3} \cdot F_{y\_dsn_i}, S_d(PL\_spec_i)\right) \quad S_{d_i} = 21000 \cdot \text{psi}$$

Testing Allowable Stress:  
(per Table 5-2)

$$S_{t_i} := S_t(PL\_spec_i)$$

$$S_{t_i} = 21000 \cdot \text{psi}$$

Joint Efficiency:

$$J_{E_i} := 0.70$$

Liquid Height:

$$h_{p_i} := H_P$$

$$h_{p_i} = 19.885 \cdot \text{ft}$$

Design Required Thickness:  
(incl. corrosion allowance)

$$t_{d_i} := \frac{2.6 \left( \frac{h_{p_i} + \frac{P_{int}}{\gamma_w \cdot G_P}}{\text{ft}} - 1 \right) \left( \frac{D_{nom}}{\text{ft}} \right) \cdot G_P}{\left( \frac{S_{d_i}}{\text{psi}} \right) \cdot J_{E_i}} \cdot \text{in} + CA_{sh}$$

$$t_{d_i} = 0.296 \cdot \text{in}$$

Testing Required Thickness:

$$t_{t_i} := \frac{2.6 \left( \frac{h_{p_i} + \frac{P_{test}}{\gamma_w}}{\text{ft}} - 1 \right) \left( \frac{D_{nom}}{\text{ft}} \right)}{\left( \frac{S_{t_i}}{\text{psi}} \right) \cdot J_{E_i}} \cdot \text{in}$$

$$t_{t_i} = 0.234 \cdot \text{in}$$

Nominal Thickness Used:

$$t_i := \frac{\text{ceil} \left( \max \left( \frac{t_{d_i}}{\text{in}}, \frac{t_{t_i}}{\text{in}}, \frac{t_{min}}{\text{in}}, \frac{t_i}{\text{in}} \right) \cdot 16 \right)}{16} \cdot \text{in}$$

$$t_i = 0.3125 \cdot \text{in}$$

Check maximum thickness for material specified:

$$t_{max}(PL\_spec_i) = 0.5 \cdot \text{in}$$

$$(t_i \leq t_{max}(PL\_spec_i)) = 1$$

$$1 = \text{TRUE}, \text{====> OK}$$

Tank Shell Plate Recap

Number of Shell Course:  $n_{sh} = 2$

Widths and Thicknesses of Shell Plates:  $t = \begin{pmatrix} 0.25 \\ 0.313 \end{pmatrix} \cdot \text{in}$   $h = \begin{pmatrix} 120 \\ 120 \end{pmatrix} \cdot \text{in}$   $PL\_spec = \begin{pmatrix} \text{"Appendix A (E=0.70)"} \\ \text{"Appendix A (E=0.70)"} \end{pmatrix}$

Weights of Shell Plate:

Centerline Diameters:  $d := \begin{cases} D_{nom} + t & \text{if Shell\_Plates\_are} = \text{"Flush-Stacked Inside"} \\ D_{nom} + 0 \cdot t & \text{if Shell\_Plates\_are} = \text{"Centerline-Stacked"} \\ D_{nom} - t & \text{if Shell\_Plates\_are} = \text{"Flush-Stacked Outside"} \end{cases}$   $d = \begin{pmatrix} 840.25 \\ 840.313 \end{pmatrix} \cdot \text{in}$

Weight of each Course:  $wt := \begin{cases} \text{for } i \in 1..n_{sh} \\ \quad shwt_i \leftarrow \pi \cdot d_i \cdot h_i \cdot t_i \cdot \gamma_s \\ \quad \text{return shwt} \end{cases}$   $wt = \begin{pmatrix} 22.438 \times 10^3 \\ 28.049 \times 10^3 \end{pmatrix} \cdot \text{lbf}$

New and Uncorroded Shell Weight:  
(including Rim Angle)

$$DL_{sh} := \sum_{i=1}^{n_{sh}} wt_i + DL_{rim} \quad DL_{sh} = 50.487 \times 10^3 \cdot \text{lbf}$$

Corroded Shell Weight:

$$CDL_{sh} := DL_{sh} - \pi \cdot D_{nom} \cdot H_{sh} \cdot CA_{sh} \cdot \gamma_s \quad CDL_{sh} = 39.271 \times 10^3 \cdot \text{lbf}$$

## Tank Shell Moments and Centroids

Shell Plate Centroids:

Centroid of each Course:

$$y := \begin{cases} \text{for } i \in 1..n_{sh} \\ \quad cg_i \leftarrow \sum_{j=i}^{n_{sh}} h_j - \frac{h_i}{2} \\ \text{return } cg \end{cases} \quad y = \begin{pmatrix} 180 \\ 60 \end{pmatrix} \cdot \text{in}$$

Moments:

$$my := \begin{cases} \text{for } i \in 1..n_{sh} \\ \quad shmy_i \leftarrow wt_i \cdot y_i \\ \text{return } shmy \end{cases} \quad my = \begin{pmatrix} 336.565 \times 10^3 \\ 140.246 \times 10^3 \end{pmatrix} \cdot \text{lb} \cdot \text{ft}$$

Rim Angle:

Rim Angle Moment:

$$my_{rim} := DL_{rim} \cdot (H_{sh} - y_{rim}) \quad my_{rim} = 0.000 \times 10^0 \cdot \text{lb} \cdot \text{ft}$$

Tank Shell Centroid:

$$y_{sh} := \frac{\sum_{i=1}^{n_{sh}} my_i + my_{rim}}{DL_{sh}} \quad y_{sh} = 9.444 \cdot \text{ft}$$

## Tank Bottom Weight

Bottom Outside Diameter:

$$D_{bt} := d_{n_{sh}} + t_{n_{sh}} + 4 \text{in} \quad D_{bt} = 70.385 \cdot \text{ft}$$

Plate Lap:

$$PLap := 1.5 \text{in}$$

Factor to account for plate laps:

$$LapFactor := \frac{96 \text{in}}{96 \text{in} - PLap} \cdot \frac{240 \text{in}}{240 \text{in} - PLap} \quad LapFactor = 1.022$$

New and Uncorroded:

$$DL_{bt} := \left( \frac{\pi}{4} \right) \cdot D_{bt}^2 \cdot t_{bt} \cdot \gamma_s \cdot LapFactor \quad DL_{bt} = 50714.0 \cdot \text{lb} \cdot \text{ft}$$

Corroded Bottom Weight:

$$CDL_{bt} := DL_{bt} \cdot \frac{t_{bt} - CA_{bt}}{t_{bt}} \quad CDL_{bt} = 40571.2 \cdot \text{lb} \cdot \text{ft}$$

## Tank Roof Weight

Roof Gravity Loads:  
(DL- new - uncorroded)

$$DL_{rfPL} := 10000 \text{ lbf}$$

$$DL_{rfPL} = 10.000 \times 10^3 \cdot \text{lbf}$$

$$DL_{rfstr} := 0 \text{ lbf}$$

$$DL_{rfstr} = 0.000 \times 10^0 \cdot \text{lbf}$$

$$DL_{rfstrsh} := 0 \text{ lbf}$$

$$DL_{rfstrsh} = 0.000 \times 10^0 \cdot \text{lbf}$$

$$DL_{rfsh} := DL_{rfPL}$$

$$DL_{rfsh} = 10.000 \times 10^3 \cdot \text{lbf}$$

$$DL_{rfPLsh} := DL_{rfsh} - DL_{rfstrsh}$$

$$DL_{rfPLsh} = 10.000 \times 10^3 \cdot \text{lbf}$$

Roof Gravity Loads:  
(DL - corroded)

$$CDL_{rfPL} := 10000 \text{ lbf}$$

$$CDL_{rfPL} = 10.000 \times 10^3 \cdot \text{lbf}$$

$$CDL_{rfstr} := 0 \text{ lbf}$$

$$CDL_{rfstr} = 0.000 \times 10^0 \cdot \text{lbf}$$

$$CDL_{rfstrsh} := 0 \text{ lbf}$$

$$CDL_{rfstrsh} = 0.000 \times 10^0 \cdot \text{lbf}$$

$$CDL_{rfsh} := CDL_{rfPL}$$

$$CDL_{rfsh} = 10.000 \times 10^3 \cdot \text{lbf}$$

$$CDL_{rfPLsh} := CDL_{rfsh} - CDL_{rfstrsh}$$

$$CDL_{rfPLsh} = 10.000 \times 10^3 \cdot \text{lbf}$$

Roof Gravity Loads:  
(Live Load)

$$LL_{design} = 22.08 \cdot \text{psf}$$

$$LL_{rfPL} := \frac{\pi}{4} \cdot D_{rf}^2 \cdot LL_{design}$$

$$LL_{rfPL} = 84.974 \times 10^3 \cdot \text{lbf}$$

$$LL_{rfsh} := LL_{rfPL}$$

$$LL_{rfsh} = 84.974 \times 10^3 \cdot \text{lbf}$$

### Wind Loads per 5.2.1.j

$$V_{\text{wind}} = 120 \cdot \text{mph} \quad \text{Exposure} = "C"$$

Importance Factor:

$$I_W = 1.15$$

Design Pressure on Cylindrical Surfaces:

$$q_{\text{sh}} := 18 \frac{\text{lb}}{\text{ft}^2} \cdot \left( \frac{V_{\text{wind}}}{120 \text{mph}} \right)^2 \cdot I_W \quad q_{\text{sh}} = 20.70 \cdot \text{psf}$$

Design Uplift Pressure on Roof Surfaces:

$$q_{\text{rf}} := 30 \frac{\text{lb}}{\text{ft}^2} \cdot \left( \frac{V_{\text{wind}}}{120 \text{mph}} \right)^2 \cdot I_W \quad q_{\text{rf}} = 34.50 \cdot \text{psf}$$

Wind on Shell:

$$F_{\text{sh}} := D_{\text{nom}} \cdot H_{\text{sh}} \cdot q_{\text{sh}} \quad F_{\text{sh}} = 28.980 \times 10^3 \cdot \text{lb}$$

$$M_{\text{sh}} := F_{\text{sh}} \cdot \frac{H_{\text{sh}}}{2} \quad M_{\text{sh}} = 289.800 \times 10^3 \cdot \text{lb} \cdot \text{ft}$$

Wind Uplift on Roof:

$$F_{\text{uplift}} := \frac{\pi}{4} \cdot D_{\text{rf}}^2 \cdot q_{\text{rf}} \quad F_{\text{uplift}} = 132.772 \times 10^3 \cdot \text{lb}$$

$$M_{\text{uplift}} := F_{\text{uplift}} \cdot \frac{D_{\text{nom}}}{2} \quad M_{\text{uplift}} = 4.647 \times 10^6 \cdot \text{lb} \cdot \text{ft}$$

Total Wind:

$$F_W := F_{\text{sh}} \quad F_W = 28.980 \times 10^3 \cdot \text{lb}$$

$$M_W := M_{\text{sh}} + M_{\text{uplift}} \quad M_W = 4.937 \times 10^6 \cdot \text{lb} \cdot \text{ft}$$

### Internal Pressure Loads

Uplift Force:

$$F_{\text{pi}} := \frac{\pi}{4} \cdot D_{\text{rf}}^2 \cdot P_{\text{int}} \quad F_{\text{pi}} = 0.000 \times 10^0 \cdot \text{lb}$$

Uplift Moment:

$$M_{\text{pi}} := \frac{\pi}{8} \cdot D_{\text{rf}}^3 \cdot P_{\text{int}} \quad M_{\text{pi}} = 0.000 \times 10^0 \cdot \text{lb} \cdot \text{ft}$$

### Moments Resisting Overturning per 3.11

Total Corroded DL Resisting Uplift:

$$CDL_{\text{up}} := CDL_{\text{sh}} + CDL_{\text{rfstrsh}} + CDL_{\text{rfPLsh}} \quad CDL_{\text{up}} = 49.271 \times 10^3 \cdot \text{lb}$$

Dead Load Overturning Resistance:

$$M_{\text{DL}} := CDL_{\text{up}} \cdot \frac{D_{\text{nom}}}{2} \quad M_{\text{DL}} = 1.724 \times 10^6 \cdot \text{lb} \cdot \text{ft}$$

Fluid Load Overturning Resistance:

$$M_F := \left( 4.67 \cdot \frac{\text{lb}}{\text{ft}} \right) \cdot \left( \frac{t_{\text{bt}} - CA_{\text{bt}}}{\text{in}} \right) \cdot \left( \sqrt{\frac{F_{\text{ybt}} \cdot H_{\text{p}}}{\text{psi} \cdot \text{ft}}} \right) \cdot \frac{\pi \cdot D_{\text{nom}}^2}{2}$$

$$M_F = 7.603 \times 10^6 \cdot \text{lb} \cdot \text{ft}$$

### Check Overturning Stability per 5.11.2

$$\text{Wind\_Anchors} := \begin{cases} \text{"ARE REQUIRED"} & \text{if } (0.6 \cdot M_w + M_{pi}) \geq \frac{M_{DL}}{1.5} \\ \text{"ARE NOT REQUIRED"} & \text{otherwise} \end{cases}$$

$$\text{Wind\_Anchors} := \begin{cases} \text{"ARE REQUIRED"} & \text{if } \left[ (M_w + 0.4 \cdot M_{pi}) \geq \left( \frac{M_{DL} + M_F}{2.0} \right) \right] \vee (\text{Wind\_Anchors} = \text{"ARE REQUIRED"}) \\ \text{"ARE NOT REQUIRED"} & \text{otherwise} \end{cases}$$

Factor of Safety for Overturning: 
$$FS_{Ovr} := \min \left( \frac{M_{DL}}{0.6 \cdot M_w + M_{pi}}, \frac{M_{DL} + M_F}{M_w + 0.4 \cdot M_{pi}} \right) \quad FS_{Ovr} = 0.582$$

### Check Sliding per 5.11.4

Maximum Allowable Sliding Friction: 
$$F_r := (CDL_{sh} + CDI_{bt} + CDL_{rfpl} + CDI_{rfstr}) \cdot 0.4 \quad F_r = 35.937 \times 10^3 \cdot \text{lb}f$$
  
(per 5.11.4)

$$F_w = 28.980 \times 10^3 \cdot \text{lb}f$$

$$\text{Wind\_Anchors} := \begin{cases} \text{"ARE REQUIRED"} & \text{if } (F_w \geq F_r) \vee (\text{Wind\_Anchors} = \text{"ARE REQUIRED"}) \\ \text{"ARE NOT REQUIRED"} & \text{otherwise} \end{cases}$$

### Check Anchor Status

Wind\_Anchors = "ARE REQUIRED"

$$\text{Tank\_Is\_Self\_Anchored} := \begin{cases} \text{"FALSE"} & \text{if Wind\_Anchors} = \text{"ARE REQUIRED"} \\ \text{Tank\_Is\_Self\_Anchored} & \text{otherwise} \end{cases}$$

Tank\_Is\_Self\_Anchored = "FALSE"



Check for Intermediate Wind Girder per 5.9.7

Maximum Height of Unstiffened Shell:

$$h_{\max} := 600000 \cdot \left( \frac{t_1}{\text{in}} \right) \cdot \left( \frac{\frac{t_1}{\text{in}}}{\frac{D_{\text{nom}}}{\text{ft}}} \right)^{\frac{3}{2}} \cdot \left( \frac{120 \text{mph}}{V_{\text{wind}}} \right)^2 \cdot \left( \frac{1}{l_w} \right) \cdot \text{ft}$$

$$h_{\max} = 27.839 \cdot \text{ft}$$

Transposed Shell Height:

$$h_T := \sum_{i=1}^{n_{\text{sh}}} \left[ h_i \left( \frac{t_1}{t_i} \right)^{2.5} \right] \quad h_T = 15.724 \cdot \text{ft}$$

Check Status:

$$\text{Intermediate\_Windgirder} := \begin{cases} \text{"is NOT REQUIRED"} & \text{if } h_T \leq h_{\max} \\ \text{"ONE REQUIRED"} & \text{if } h_T > h_{\max} \\ \text{"TWO REQUIRED"} & \text{if } \frac{h_T}{2} > h_{\max} \\ \text{"THREE REQUIRED"} & \text{if } \frac{h_T}{3} > h_{\max} \\ \text{"MODIFY THE SHELL DESIGN"} & \text{if } \frac{h_T}{4} > h_{\max} \end{cases}$$

$$\text{Intermediate\_Windgirder} = \text{"is NOT REQUIRED"}$$

Required Section Modulus:  
(if windgirder is required)

$$h_{\text{wg}} := \begin{cases} 0 \text{ft} & \text{if } h_T \leq h_{\max} \\ \frac{h_T}{2} & \text{if } h_T > h_{\max} \\ \frac{h_T}{3} & \text{if } \frac{h_T}{2} > h_{\max} \\ \frac{h_T}{4} & \text{if } \frac{h_T}{3} > h_{\max} \end{cases} \quad h_{\text{wg}} = 0 \cdot \text{ft}$$

$$S_{\text{iwg}} := 0.0001 \cdot \frac{h_{\text{wg}}}{\text{ft}} \cdot \left( \frac{D_{\text{nom}}}{\text{ft}} \right)^2 \cdot \left( \frac{V_{\text{wind}}}{120 \text{mph}} \right)^2 \cdot \text{in}^3 \quad S_{\text{iwg}} = 0 \cdot \text{in}^3$$

Top Wind Girder Design (for aluminum dome - designed as an open-top tank)

Minimum Required Section Modulus:  $S_{\text{twg}} := 0.0001 \cdot \frac{H_{\text{sh}}}{\text{ft}} \cdot \left( \frac{D_{\text{nom}}}{\text{ft}} \right)^2 \cdot \left( \frac{V_{\text{wind}}}{120\text{mph}} \right)^2 \cdot (l_{\text{W}}) \cdot \text{in}^3$   $S_{\text{twg}} = 11.27 \cdot \text{in}^3$

Use L6x4x1/2 (LLH) rolled toe-in and welded to the shell PL.

Seismic Design per Appendix E

Check if Seismic Design is Required (see exception in E.1):

$$\text{Seismic\_Design\_Is} := \begin{cases} \text{"NOT REQUIRED"} & \text{if } [(S_1 \leq 4\%) \wedge (S_S \leq 15\%)] \vee (S_p \leq 5\%) \\ \text{"REQUIRED"} & \text{otherwise} \end{cases}$$

Seismic\_Design\_Is = "NOT REQUIRED"



## Anchor Design per 5.12

Tank\_Is\_Self\_Anchored = "FALSE"



Minimum Number of Anchors Required:

$$n_{ab} := \max\left(4, \frac{\pi \cdot D_{nom}}{10ft}\right)$$

$$n_{ab} = 21.991$$

Number of Anchors Used:

$$n_{ab} := 24$$

Anchor Uplift Forces per 5.12 (Table 5-21b)

Anchor Uplift for Wind Forces:

$$P_W := \frac{\max\left[0, \left[\frac{4 \cdot M_W}{D_{nom}} - (CDL_{sh} + CDL_{rfsh})\right]\right]}{n_{ab}}$$

$$P_W = 9.701 \times 10^3 \cdot \text{lb}f$$

Anchor Uplift for Seismic Forces:

$$P_S := \frac{\max\left[0, \left[\frac{4 \cdot M_{rw}}{D_{nom}} - (CDL_{sh} + CDL_{rfsh})\right]\right]}{n_{ab}}$$

$$P_S = 0.000 \times 10^0 \cdot \text{lb}f$$

Anchor Uplift for Design Pressure + Wind:

$$P_{PW} := \frac{\max\left[0, \left[\left(\frac{4 \cdot M_W}{D_{nom}}\right) + \left[\left(\frac{\pi}{4} \cdot D_{nom}^2\right) \cdot P_{int} - CDL_{rfPL}\right] - (CDL_{sh} + CDL_{rfstrsh})\right]\right]}{n_{ab}}$$

$$P_{PW} = 9.701 \times 10^3 \cdot \text{lb}f$$

Anchor Uplift for Design Pressure + Seismic:

$$P_{PS} := \frac{\max\left[0, \left[\left(\frac{4 \cdot M_{rw}}{D_{nom}}\right) + \left[\left(\frac{\pi}{4} \cdot D_{nom}^2\right) \cdot P_{int} - CDL_{rfPL}\right] - (CDL_{sh} + CDL_{rfstrsh})\right]\right]}{n_{ab}}$$

$$P_{PS} = 0.000 \times 10^0 \cdot \text{lb}f$$

Anchor Material Specification:

Anch\_Matl := "ASTM A193, Gr. B8M"

Fy\_ab := 30000psi

Anchor Diameter:

d\_ab := 1in

A\_ab = 0.537·in<sup>2</sup>

A_ab :=	0.537in <sup>2</sup> if d_ab = 1in
	0.740in <sup>2</sup> if d_ab = 1.125in
	0.942in <sup>2</sup> if d_ab = 1.25in
	1.12in <sup>2</sup> if d_ab = 1.375in
	1.37in <sup>2</sup> if d_ab = 1.5in
	0in <sup>2</sup> otherwise

Anchor Stresses:

Wind Load

$$\sigma_W := \frac{P_W}{A_{ab}}$$

$\sigma_W = 18065.8 \cdot \text{psi}$

Wind Load & Design Pressure

$$\sigma_{PW} := \frac{P_{PW}}{A_{ab}}$$

$\sigma_{PW} = 18065.8 \cdot \text{psi}$

Seismic Load

$$\sigma_S := \frac{P_S}{A_{ab}}$$

$\sigma_S = 0.0 \cdot \text{psi}$

Seismic Load & Design Pressure

$$\sigma_{PS} := \frac{P_{PS}}{A_{ab}}$$

$\sigma_{PS} = 0.0 \cdot \text{psi}$

Anchor_Design_is :=	"NO GOOD" if $\sigma_W > 0.8 \cdot Fy_{ab}$
	"NO GOOD" if $\sigma_S > 0.8 \cdot Fy_{ab}$
	"NO GOOD" if $\sigma_{PW} > 20000 \text{psi}$
	"NO GOOD" if $\sigma_{PS} > 0.8 \cdot Fy_{ab}$
	"Acceptable" otherwise

Anchor\_Design\_is = "Acceptable"



## Foundation Loads

### Area Loads:

Uniform Pressure on Bottom:  
(for operating condition)

$$q_{\text{bot}} := H_p \cdot G_p \cdot \gamma_w + t_{\text{bt}} \cdot \gamma_s + P_{\text{int}}$$

$$q_{\text{bot}} = 1253.6 \cdot \text{psf}$$

Uniform Pressure on Bottom:  
(for hydrostatic testing)

$$q_{\text{bt}} := H_{\text{sh}} \cdot \gamma_w + t_{\text{bt}} \cdot \gamma_s + P_{\text{test}}$$

$$q_{\text{bt}} = 1260.75 \cdot \text{psf}$$

### Shell Loads:

(per foot of circumference)

Dead Load at Base of Shell:  
(New and Uncorroded)

$$DL := \frac{DL_{\text{sh}} + DL_{\text{rfsh}}}{\pi \cdot D_{\text{nom}}}$$

$$DL = 275.1 \cdot \frac{\text{lbft}}{\text{ft}}$$

Dead Load at Base of Shell:  
(Fully Corroded)

$$CDL := \frac{CDL_{\text{sh}} + CDL_{\text{rfsh}}}{\pi \cdot D_{\text{nom}}}$$

$$CDL = 224.1 \cdot \frac{\text{lbft}}{\text{ft}}$$

Live Load at Base of Shell:

$$LL := \frac{LL_{\text{rfsh}}}{\pi \cdot D_{\text{nom}}}$$

$$LL = 386.4 \cdot \frac{\text{lbft}}{\text{ft}}$$

### Wind Loads: (at Base of Shell)

$$V_{\text{wind}} = 120 \cdot \text{mph}$$

Wind Base Shear:

$$F_w = 28.980 \times 10^3 \cdot \text{lbft}$$

Wind Moment:

$$M_w = 4.937 \times 10^6 \cdot \text{ft} \cdot \text{lbft}$$

### Seismic Loads: (at Base of Shell)

Seismic Base Shear:

$$V_E = 0.000 \times 10^0 \cdot \text{lbft}$$

Seismic Shell Moment:  
(for Shell and Ringwall Design)

$$M_{\text{rw}} = 0.000 \times 10^0 \cdot \text{ft} \cdot \text{lbft}$$

Seismic Base Moment:  
(for Slab and Pile Foundations)

$$M_s = 0.000 \times 10^0 \cdot \text{ft} \cdot \text{lbft}$$

Tank\_Is\_Self\_Anchored = "FALSE"

## Design Recap Sheet

### Roof Design

RoofType = "SELF-SUPPORTING ALUMINUM DOME"

Roof\_Design\_is = "by Dome Roof Manufacturer"

RimAngle = "None"

### Shell Design

Number of Shell Course:

$$n_{sh} = 2$$

Intermediate\_Windgirder = "is NOT REQUIRED"

Widths and Thicknesses of Shell Plates:

$$h = \begin{pmatrix} 120 \\ 120 \end{pmatrix} \cdot \text{in}$$

$$PL\_spec = \begin{pmatrix} \text{"Appendix A (E=0.70)"} \\ \text{"Appendix A (E=0.70)"} \end{pmatrix} \quad t = \begin{pmatrix} 0.2500 \\ 0.3125 \end{pmatrix} \cdot \text{in}$$

$$t_d = \begin{pmatrix} 0.173 \\ 0.296 \end{pmatrix} \cdot \text{in}$$

$$t_t = \begin{pmatrix} 0.110 \\ 0.234 \end{pmatrix} \cdot \text{in}$$

### Bottom Design

Bottom\_Is = "Cone Down"

$$\text{Slope}_{bt} = -1 \cdot \frac{\text{in}}{10\text{ft}}$$

Tank\_Has\_Annular\_Plate = "FALSE"

$w_{annpl} = \text{"N/A"} \cdot \text{in}$

$t_{annpl} = \text{"N/A"} \cdot \text{in}$

Bottom Plate Thickness:

$$t_{bt} = 0.313 \cdot \text{in}$$

### Anchor Design

Tank\_Is\_Self\_Anchored = "FALSE"

Number of Anchors:

$$n_{ab} = 24$$

Anch\_Mat = "ASTM A193, Gr. B8M"

Anchor Diameter:

$$d_{ab} = 1 \cdot \text{in}$$

$$A_{ab} = 0.537 \cdot \text{in}^2$$

Maximum Anchor Force:

$$T_{ab} = 9701 \cdot \text{lbf}$$

Anchor\_Design\_is = "Acceptable"

St	Input	Name	Output	Unit	Comment
					Ringwall Analysis
		u_wt_conc	150	pcf	Unit weight of concrete ( default = 150 pcf )
		u_wt_soil	120	pcf	Unit weight of soil ( default = 120 pcf )
		phi_soil	19.47122	deg	Soil friction angle ( default = 19.47122 deg )
		Ka	.5		Coefficient of Rankine's active earth pressure
70		D_ring		ft	Diameter of ringwall at centerline
2		b_ring		ft	Width of ringwall
3		d_ring		ft	Depth of ringwall
1		G			Product specific gravity
20		H		ft	Product height
3125		t_bot		in	Thickness of bottom plate
		q_prod	1260.75	psf	Bearing pressure due to product + bottom plate
		q_soil	1620.75	psf	Soil bearing pressure under tank product at elevation of bottom of ri
70		D_shell		ft	Diameter of shell
48071		W_shell		lbf	Total weight of shell and shell supported items
		w_shell	218.5925	plf	Weight of shell and supported items per foot
		e_shell	0	ft	Eccentricity of shell ( + toward center )
		b_prod	1	ft	Width of ring wall loaded by product
		e_prod	.5	ft	Eccentricity of product ( + toward center )
		q_brg_normal	1189.671	psf	Soil bearing under ringwall from normal operation
24		N_anch			Number of anchor bolts
70.5		D_anch		ft	Diameter of anchor bolt circle
9701		P_anch		lbf	Tension in one anchor bolt
		e_anch	-.25	ft	Eccentricity of anchor bolts ( + toward center )
289800		M_wind		ft*lbf	Wind moment at base of shell
28980		V_wind		lbf	Wind shear at base of shell
		q_brg_wind	1238.618	psf	
		w_wind	97.89393	lbf / ft	
0		M_seismic		ft*lbf	Seismic moment at base of shell
0		V_seismic		lbf	Seismic shear at base of shell
		q_brg_seismic	1189.671	psf	
		w_seismic	0	lbf / ft	
2000		q_allow_norm		psf	Allowable soil bearing with FS = 2.5
2666.667		q_allow_wind		psf	Allowable soil bearing with FS = 1.875 ( 3/4 of 2.5 )
		P_hoop	73478.25	lbf	Hoop Forces in ringwall
		T_ecc	895.0542	ft*lbf / ft	Torque due to eccentricities
					Job No. 5350 - Woodruff & Sons, Inc.
					70' Dia. x 20' FB Alum Dome Roof Leachate Storage Tank
					Lithia, Florida
					September 8, 2008 - TFM
					Sheet _____ of _____




St	Input	Name	Output	Unit	Comment
					Ringwall Design
	73478	P_hoop		lbf	Hoop force in ringwall (from ringwall analysis)
	895.05	T_ecc		ft*lbf / ft	Torque due to eccentricities (from ringwall analysis)
	1.6	L_Factor			Load factor for concrete design
		phi	.9		Resistance factor for concrete design
	70	D_ring		ft	Diameter of ringwall at centerline
	2	b_ring		ft	Width of ringwall
	3	d_ring		ft	Depth of ringwall
		A_g	864	in^2	Gross area of concrete
		A_s_min	2.16	in^2	Minimum area of reinforcing steel per ACI 318, 14.3.3
	4000	fc		psi	Compressive strength of concrete
		Fy	60000	psi	Yield strength of reinforcing steel
	10	N_bars			Quantity of reinforcing bars used for hoop reinforcing
	#6	BarSize			Reinforcing bar size used for hoop reinforcing
		d_b	.75	in	Bar diameter
		A_b	.441786467	in	Cross-sectional area of a single bar
		A_s	4.41786467	in^2	Area of reinforcing steel provided
		I_s	608.961227	in^4	"Moment of Inertia" of steel WRT horizontal neutral axis
	14.625	c		in	Vertical distance from horizontal neutral axis to bottom steel
		P_bar	7347.825	lbf	Hoop force in each reinforcing bar
		P_ecc	3988.57052	lbf	Hoop force increase ( in extreme bar ) due to eccentricity
		Pu_bar	18138.2328	lbf	Required strength ( factored force ) in extreme bar
		phi_Pn_bar	23856.4692	lbf	Design strength of each reinforcing bar
	2.5	cc		in	Smallest value of clear cover over, side cover, or 1/2 c/c spacing
		alpha	1.3		Reinforcement location factor ( = 1.3 for "top" bars )
		beta	1		Coating factor ( = 1.0 for uncoated bars )
		gamma	.8		Bar size factor ( = 0.8 for #6 and smaller, = 1.0 for others )
		lambda	1		Lightweight aggregate factor ( = 1.0 for normalweight concrete )
		L_d	22.1991892	in	Basic development length for hoop steel per ACI 318-99, 12.2
		LapLength	29	in	Minimum length of Class B splice per ACI 318-99, 12.15.1
		A_s_vert_min	.3456	in^2 / ft	Minimum area of vertical steel required by ACI 318-99, 14.3.2
	#4	Vert_BarSize			Reinforcing bar size for vertical reinforcing
	2	N_faces			Number of vertical bars per spacing
	13.5	s		in	Spacing of vertical bars ( each face )
		A_s_vert	.34906585	in^2 / ft	Calculated area of vertical reinforcing supplied
					Job No. 5350 - Woodruff & Sons, Inc.
					70' Dia. x 20' FB Alum Dome Roof Leachate Storage Tank
					Lithia, Florida
					September 8, 2008 - TFM
					Sheet _____ of _____

DESIGN SHELL THICKNESSES							
RING No.	API MAT'L GROUP	DESIGN FOR PRODUCT		DESIGN FOR TEST		CORROSION ALLOWANCE THK. (IN)	ACTUAL THK. (IN)
		ALLOWABLE STRESS (PSI)	CALCULATION THK. (IN)	ALLOWABLE STRESS (PSI)	CALCULATION THK. (IN)		
1	I	21000	0.285"	21000	0.223"	0.3125"	
2	I	21000	0.162"	21000	0.099"	0.25"	


CHORD ON INSIDE SHELL PLATES		
MARK	CHORD	M. O.
1A, 1B	30'-5 1/4"	3'-5 13/16"
1AA	29'-11 3/4"	3'-4 1/2"
1BA	29'-11 5/8"	3'-4 7/16"

TANK DATA	
DESIGNED AND FABRICATED PER: API STD 650 ELEVENTH EDITION WITH APPLICABLE APPENDICES	
NUMBER OF TANKS REQ'D.: ONE	TANK CONTENTS: EFFLUENT/LEACHATE
NOMINAL CAPACITY: 550,000 GAL	DESIGN SPECIFIC GRAVITY: 1
DESIGN INTERNAL PRESSURE: ATMOSPHERIC	OPERATING PRESSURE: ATMOSPHERIC
DESIGN EXTERNAL PRESSURE: 1 IN H2O	OPERATING TEMPERATURE: AMBIENT
DESIGN TEMPERATURE: 200° F	MIN. DESIGN METAL TEMPERATURE (WDMT): 50° F
SEISMIC DESIGN PARAMETERS: S <sub>g</sub> : 7.8% S <sub>1</sub> : 3.1% T <sub>L</sub> : 8 Sec.	CORROSION ALLOWANCE: 1/8" BOTTOM & SHELL
SITE CLASS: D	JOINT EFFICIENCY FACTOR: 70% (NO XRAY)
BASIC WIND SPEED: 120 MPH	ROOF LIVE LOAD: 20 PSF
IMPORTANCE FACTOR: 1.15	EMPTY WEIGHT: 114,600 LBS
EXPOSURE CATEGORY: C	FLOODED W/WATER WEIGHT: 4,900,000 LBS
RADIOGRAPHY: NONE	OPERATING WEIGHT: 4,700,600 LBS


BILL OF MATERIAL				
PART	QTY	DESCRIPTION	MATERIAL	WT EA. TOTAL
1A	6	PL 5/16" x 120" x 31'-6" LG ROLL TO 70'-0" I.D.	A36	4058 24344
1AA	1	PL 5/16" x 120" x 30'-11 15/16"± LG ROLL TO 70'-0" I.D.	A36	3993
1B	6	PL 1/4" x 120" x 31'-6" LG ROLL TO 70'-0" I.D.	A36	3245 19467
1BA	1	PL 1/4" x 120" x 30'-11 3/4"± LG ROLL TO 70'-0" I.D.	A36	3193
1C	13	WIND GIRDER SECTIONS L6" x 4" x 1/2" x 17'-6" (LLH) ROLL TO 71'-0 1/2" I. D. (LONG LEG TOE IN) FIELD TRIM LAST PIECE AT TIME OF ASSEMBLY	A36	291 3775
1D	13	WIND GIRDER BACK-UP PL BAR 2" x 3/16" x 0'-8 13/16" LG BENT 5 5/16" + 3 1/2"	A36	1 12
1E	3	GROUNDING LUG PL 1/4" x 2 1/2" x 0'-3" LG	304 S/S	0.5 2
				54786




SHELL PLATE TO BOTTOM PLATE CONNECTION



SECTION "A-A"




WIND GIRDER WELD DETAIL (13 PLACES)



ELEVATION  
SEE PLAN VIEW SHIT. 2 FOR TRUE NOZZLE ORIENTATION

- NOTES:
- TANK IS DESIGNED IN ACCORDANCE WITH API STANDARD 650 APPENDIX "A", FLORIDA BUILDING CODE 2004 (AS APPLICABLE), AND THE ORDINANCES OF HILLSBOROUGH COUNTY.
  - SHELL NOZZLE FLANGE BOLTS TO STRADDLE VERTICAL TANK CENTERLINES.
  - TANK TO BE INSPECTED PER API STD. 650. TANK BOTTOM WELDS TO BE VACUUM BOX TESTED.
  - T.I. TO FURNISH & INSTALL NOZZLE BLANK OFFS W/ GASKETS AND PERFORM THE HYDROTEST. PIPING, PUMPING TRANSFER AND/OR DISPOSAL OF THE HYDROTEST WATER IS BY OTHERS. HYDROTEST WATER SHALL BE FILLED TO A POINT NOT LESS THAN 6" FROM TOP OF SHELL FOR 48 HOURS.
  - FOR NAMEPLATE SEE DWG. NO. B-5350-01



Timothy F. Mulligan, PE  
2710 5th Avenue  
Tampa, Florida 33605  
Florida PE Registration No. 54736  
Florida Cert. of Auth. No. 27234

DATE	DESCRIPTION	BY	REV.
9-12-08	1		0

MATERIAL OF CONSTRUCTION (UNLESS OTHERWISE NOTED)	
PLATE:	A36
SHAPES:	A36
PIPE:	A106, GR. B 2" & BELOW ABOVE 2" A53, GR. B
FLANGES:	A105
GASKETS:	EPDM
NUTS:	A194 8M
BOLTS:	A193 8M

INTERIOR FINISH:	PS-5350-01
EXTERIOR FINISH:	PS-5350-01

STATUS	BY	DATE	REV.	DESCRIPTION
RELEASED TO FIELD				
RELEASED FOR FABRICATION	RSU	9-24-08		
APPROVAL RECEIVED				
ISSUED FOR APPROVAL			2	ADDED GASKET MATERIAL
CHECKED	RSU	9-05-08	1	RELEASE FOR FABRICATION
DRAWING	JRN	8-12-08	0	FOR APPROVAL


**TAMPA TANK, INC.**  
TAMPA, FLORIDA

ELEVATION AND DETAILS FOR  
70'-0" DIA. x 20'-0" SHELL TANK


CUSTOMER: WOODRUFF & SONS, INC.  
6450 31st STREET EAST  
BRADENTON, FL, 3403

JOB SITE: HILLSBOROUGH COUNTY S.E. LANDFILL  
LITHIA, FL.

CUSTOMER'S P.O. No.:	2517
FIELD WORK No.:	5350F
CONTRACT No.:	TTI-5350S
SHEET No.:	1 OF 3
DRAWING No.:	D-5350-01
REV.:	2



(TOP OF BOTTOM PLATE.)	NOZZLE SCHEDULE						
	ELEVATION	MARK	QTY.	PIPE SIZE & SCHEDULE	FLANGE & FACING	REPAD MARK	COMMENTS
	18'-6"	N1	ONE	6" EXTRA HEAVY	6" 150# RFSO		LEACHATE INLET
	18'-6"	N2	ONE	4" EXTRA HEAVY	4" 150# RFSO		EFFLUENT INLET
	19'-0"	N3	ONE	1 1/2" EXTRA HEAVY	1 1/2" 150# RFSO		FILL AND DIP PIPE
	17'-9"	N4	ONE	8" EXTRA HEAVY	8" 150# RFSO		OVERFLOW
	1'-2"	N5	ONE	4" EXTRA HEAVY	4" 150# RFSO	4N5A	EFFLUENT OUTLET (TO SUMP)
	3'-6"	M1	ONE	36" SCH. 40	36" AWWA C207	4M1A	36" SHELL MANWAY W/ DAVIT
	19'-2"	N8	ONE	3/4" 3000# CPL'G THREADED	-		CATHODIC PROTECTION
ALUMA DOME COVER ROOF FITTINGS							
	-	M2	ONE	30" SQ.			ROOF MANWAY (ALUMN.)
	-	N6	ONE	24" ROOF VENT			GRAVITY VENT (ALUMN.)
	-	N7	ONE	1 1/2"			LEVEL GAUGE



DATE:	9-12-08	9-24-08
CUST:	1	1
SHOP:	-	-
FIELD:	-	-
REV:	0	1

DEGREE	FT-IN
1°	0'-7 1/8"
2°	1'-2 11/16"
5°	3'-0 11/16"
10°	6'-1 1/8"
20°	12'-2 11/16"
30°	18'-4 1/8"
35°	21'-4 3/8"
45°	27'-6 1/8"

STATUS	BY	DATE	REV.	DESCRIPTION
RELEASED TO FIELD				
RELEASED FOR FABRICATION	RSU	9-24-08		
APPROVAL RECEIVED				
ISSUED FOR APPROVAL			2	ROOF MANWAY WAS 36" SQ., ADDED "N8"
CHECKED	RSU	9-17-08	1	RELEASE FOR FABRICATION
DRAWING	JRN	8-12-08	0	FOR APPROVAL


**TAMPA TANK, INC.**  
TAMPA, FLORIDA

ASSEMBLY PLAN AND DETAILS FOR  
70'-0" DIA. x 20'-0" SHELL TANK


CUSTOMER: WOODRUFF & SONS, INC.  
6450 31st STREET EAST  
BRADENTON, FL, 3403

JOB SITE: HILLSBOROUGH COUNTY S.E. LANDFILL  
LITHIA, FL

CUSTOMER'S P.O. No.: 2517  
FIELD WORK No.: 5350F  
CONTRACT No.: TTI-5350S  
SHEET No.: 2 OF 3  
DRAWING No.: D-5350-01  
REV.: 2




48 REQ'D - PART 102



24 ANCHOR CHAIRS REQUIRED - MK 1F  
(SEE PLAN FOR LOCATION)


RELEASE FOR FABRICATION  
9-20-08

BILL OF MATERIAL					
PART	QTY	DESCRIPTION	MATERIAL	WT EA	TOTAL
1F	24	ANCHOR CHAIR ASSEMBLIES			
101	24	PL., 3/4" x 5 3/8" x 0'-7 1/2"	A36	9	206
102	48	PL., 5/8" x 5 3/8" x 1'-1 1/4"	A36	9	418
1H	24	ANCHOR ROD ASSEMBLIES			
106	24	ROD, 1" DIA. x 3'-6" (1-BUNC x 4" LONG ONE END AND 1-BUNC x 1 1/2" LONG ONE END.)	A193 Gr. B8M	10.2	247
107	72	1-BUNC HEAVY HEX. NUTS	A194 Gr. 8M	0.4	31
1J	24	PLATE WASHER			
	24	PL 3/8" x 2 5/8" O.D. x 1 1/16" I.D.	316 S/S	.5	12
					914



ELEVATION VIEW

24-ANCHOR ROD - MK 1H  
(SEE PLAN VIEW FOR ANCHOR LOCATIONS  
PER DWG D-5350-01, SHT. NO. 2)



DATE	9-12-08	9-20-08	9-24-08
CUST.	1	1	1
SHOP	-	-	-
FIELD	-	-	-
REV.	0	1	2

Timothy F. Mulligan, PE  
2710 5th Avenue  
Tampa, Florida 33605  
Florida PE Registration No. 54736  
Florida Cert. of Auth. No. 27234

STATUS	BY	DATE	REV.	DESCRIPTION	DATE
RELEASED TO FIELD					
RELEASED FOR FABRICATION	RSU	9-20-08			
APPROVAL RECEIVED					
ISSUED FOR APPROVAL			2	RELEASE REMAINDER ITEM FOR FABRICATION	9-24-08
CHECKED	RSU	9-12-08	1	RELEASE ANCHOR ROD ASSEMBLY FOR FABRICATION	9-20-08
DRAWING	MM	9-12-08	0	FOR APPROVAL	-

**TAMPA TANK, INC.**  
TAMPA, FLORIDA

ANCHOR CHAIR & ANCHOR ROD DETAILS

CUSTOMER: WOODRUFF & SONS, INC.  
6450 31st STREET EAST  
BRADENTON, FL, 3403  
JOB SITE: HILLSBOROUGH COUNTY S.E. LANDFILL  
LITHIA, FL.

CUSTOMER'S P.O. No.:	2517
FIELD WORK No.:	5350F
CONTRACT No.:	TTI-5350S
SHEET No.:	3 OF 3
DRAWING No.:	D-5350-01
REV.:	2