

XI. General Conditions 20.

The permittee shall report to the Department's Southwest District Office any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24-hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided with five (5) days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate and prevent recurrence of the noncompliance.

NONCOMPLIANCE ACTIVITY Name per COB (from 24-Hour Report)

Sewer Backup and Manhole overflow

NONCOMPLIANCE FDEP-Tampa INCIDENT Number

N/A

If assigned, NONCOMPLIANCE SWO-Tallahassee Number

N/A

[WasteWater@Bradenton FL.gov](mailto:WasteWater@BradentonFL.gov)

[Acting Director Lance Williams](#)
[1411 9th Street West, Bradenton FL, 34205](#)
[\(941\) 708-6300](#)

a description of the noncompliance and its cause;

DESCRIPTION

The cleanout and manhole at 1710 Pointe Pleasant Avenue, had an overflow of about 750 gallons of sewage due to a line blockage. About 400 gallons were recovered into the Vac truck.

CAUSE

A large mass of rags blocked the line at the manhole at the intersection of 15th Street and 1st Ave West. The flow out of the manhole was at a rate of about 10 gal/min.

the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue;

| | | |
|--|-----------|---------------------|
| START DATE | 28-Mar-24 | |
| START TIME | 10:00 AM | |
| NONCOMPLIANCE CORRECTED? | YES | NO, it is on-going. |
| If corrected, END DATE | 28-Mar-24 | |
| If corrected END TIME | 11:15 | |
| If NOT corrected, anticipate days for NONCOMPLIANCE to continue. | | |

steps taken or planned to reduce, eliminate and prevent recurrence of the noncompliance.

The source of the blockage on 15th Street and 1st Ave West will be checked bi-monthly by Collections technicians for the next year since this is the second time within a quarter that there has been a sewer overflow from a blockage in the area.

Attach record of 24-Hour record.

Attach Public Notice of Pollution document.

If applicable, attach SWO-Tallahassee documents.

If applicable, attach available water quality sample collection documents. If applicable, attach pertinent SSORP documents.