



Date: March 12, 2014

Re: #57 (3/4") River Gravel

This letter is to certify the above referenced materials Conrad Yelvington will supply in has been tested in accordance with applicable ASTM methods and found to have typical results of those listed below.

Sieve Analysis (ASTM C-136)

<u>Sieve Size</u>	<u>% Passing</u>
1 1/2"	100
1"	97
3/4"	80
1/2"	35
3/8"	19
#4	4

Bulk Specific Gravity (ASTM C-127) -	2.582
Absorption (ASTM C-127) -	0.9%
Soundness (ASTM C-88) -	1.0%
Unit Weight (ASTM C-29)-	97 lb/ft ³

***Average of tests performed at the quarry/terminal, and may not be indicative of any one test. In place material may vary from submittal due to degradation and segregation caused by handling, spreading and compaction.**

Should you have any questions or need any additional information, please do not hesitate to contact this office.

Respectfully,

Conrad Yelvington Distributors Inc.

Donald Reilly
Technical Services Manager