



Date: March 12, 2014

RE: #4 Prattville River Gravel Material Specifications

This letter is to certify, the materials Conrad Yelvington Distributors proposes to supply with the applicable ASTM standards and found to have the typical results listed below:

<u>Sieve Size</u>	<u>% Passing</u>	<u>FDOT 901 Specs</u>
2"	100	100
1 1/2"	92	90-100
1"	30	20-55
3/4"	3	0-15
3/8"	0	0-5

Specific Gravity - 2.630, Absorption – 0.4%, Sodium Soundness Sulfate Loss 0.6%

Unit Weight 93 lb/ft³

Should you have any questions or need any additional information, please contact me at your earliest convenience.

Regards,

A handwritten signature in black ink, appearing to read "Don Reilly", written in a cursive style.

Donald Reilly
Technical Services Manager