



Sumter County Fire Rescue Fire & Life Safety Inspection

53122
PC

Date <u>11/13/08</u>		Time		Date of Last Inspection			
Address <u>1201 Industrial Drive Wildwood Fl. 34785</u>							
Name of Business <u>Global Tire Recycling</u>							
Contact Person <u>Mark Bentley</u>		Phone No. <u>(352) 330-2213</u>					
Type of Occupancy <u>Industrial</u>		NFPA 101 Chap.					
Type of Construction		Number of Stories					
1. General	Yes	No	N/A	9. Protection of Vertical Openings	Yes	No	N/A
Bldg. Altered or renovated since last Insp.?		<input checked="" type="checkbox"/>		Ceiling tiles missing or broken?		<input checked="" type="checkbox"/>	
Is building mixed occupancy?		<input checked="" type="checkbox"/>		Ducts and pipes properly sealed at ceiling?	<input checked="" type="checkbox"/>		
What other occupancies?			<input checked="" type="checkbox"/>	10. Interior Finish			
Building construction acceptable?	<input checked="" type="checkbox"/>			Wall and ceiling materials per code?	<input checked="" type="checkbox"/>		
2. Occupant Load and Exits				Is interior finish per code?	<input checked="" type="checkbox"/>		
Are exits per code?	<input checked="" type="checkbox"/>			Fixed Seating			<input checked="" type="checkbox"/>
Number of exits? 1 2 3 4 or more <u>(4)</u>				Are curtains and drapes per code?			<input checked="" type="checkbox"/>
Is egress capacity adequate?	<input checked="" type="checkbox"/>			Floor finish per code?	<input checked="" type="checkbox"/>		
Fire rating of exit stair enclosure 1 hr 2 hr			<input checked="" type="checkbox"/>	11. Operating Features			
Fire rating of exit stair door 1 hr 1 1/2 hr			<input checked="" type="checkbox"/>	Is there a written emergency plan?	<input checked="" type="checkbox"/>		
Doors self-closing?	<input checked="" type="checkbox"/>			Are fire drills conducted?		<input checked="" type="checkbox"/>	
Latching door hardware?		<input checked="" type="checkbox"/>		Number of fire drills conducted per year		<input checked="" type="checkbox"/>	
Exit enclosures free of storage?	<input checked="" type="checkbox"/>			Are employees instructed in fire ext. use?	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Do 100% of exits discharge directly outside?		<input checked="" type="checkbox"/>		Has evacuation / relocation been established?	<input checked="" type="checkbox"/>		
Do 50% of exits discharge directly outside?	<input checked="" type="checkbox"/>			Is there daily inspection of exits?	<input checked="" type="checkbox"/>		
Is exit discharge level?			<input checked="" type="checkbox"/>	12. Alarm and Detection			
Is exit discharge sprinklered?			<input checked="" type="checkbox"/>	Is there a manual alarm system?		<input checked="" type="checkbox"/>	
Is stair entry per code?			<input checked="" type="checkbox"/>	Is there a fire detection system?	<input checked="" type="checkbox"/>		
3. Doors				Smoke detectors		<input checked="" type="checkbox"/>	
Are doors blocked?		<input checked="" type="checkbox"/>		Heat detectors		<input checked="" type="checkbox"/>	
Are doors locked?		<input checked="" type="checkbox"/>		Audible alarm	<input checked="" type="checkbox"/>		
Is ≤15-lb force required to release latch?	<input checked="" type="checkbox"/>			Visual alarm	<input checked="" type="checkbox"/>		
Doors open in direction of travel?	<input checked="" type="checkbox"/>			Alarm system within certification?	<input checked="" type="checkbox"/>		
Is there panic hardware per code?			<input checked="" type="checkbox"/>	Is alarm system monitored 24 hours a day?	<input checked="" type="checkbox"/>		
4. Egress Arrangement				Number and location of pull stations per code?			<input checked="" type="checkbox"/>
Is egress clear and unobstructed?	<input checked="" type="checkbox"/>			13. Extinguishment			
Are dead-end corridors within limits?	<input checked="" type="checkbox"/>			Is the building sprinklered throughout?	<input checked="" type="checkbox"/>		
Is common path of travel within limits?	<input checked="" type="checkbox"/>			Partial sprinklers			<input checked="" type="checkbox"/>
Is travel through intervening rooms okay?	<input checked="" type="checkbox"/>			Is there a water flow alarm?	<input checked="" type="checkbox"/>		
Is egress blocked?		<input checked="" type="checkbox"/>		Are the valves supervised?	<input checked="" type="checkbox"/>		
Is aisle width adequate?	<input checked="" type="checkbox"/>			Is there a standpipe?	<input checked="" type="checkbox"/>		
Is travel distance per code?	<input checked="" type="checkbox"/>			Is the sprinkler system within certification?	<input checked="" type="checkbox"/>		
5. Emergency Lighting				Is there a fire pump?		<input checked="" type="checkbox"/>	
Is emergency lighting per code?	<input checked="" type="checkbox"/>			Date of last pump test			<input checked="" type="checkbox"/>
Is it tested monthly?			<input checked="" type="checkbox"/>	Number of fire extinguishers within code?	<input checked="" type="checkbox"/>		
6. Exit Marking				Travel distance for fire extinguisher per code?	<input checked="" type="checkbox"/>		
Is exit marking per code?	<input checked="" type="checkbox"/>			Are fire extinguishers within certification?		<input checked="" type="checkbox"/>	
7. Corridors				Are fire extinguishers mounted properly?	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Is 1 - hr rating required?	<input checked="" type="checkbox"/>			Are fire extinguishers accessible?	<input checked="" type="checkbox"/>		
Is rating 1-hr corridor walls w/ 20 min. doors?	<input checked="" type="checkbox"/>			14. Building HVAC & Utilities			
8. Protection of Hazards				Are Utilities in good working order?	<input checked="" type="checkbox"/>		
Hazards protected by fire rate enclosure?		<input checked="" type="checkbox"/>		Emergency shut-offs/circuit breakers labeled?	<input checked="" type="checkbox"/>		
Hazards protected by ext. sys.?	<input checked="" type="checkbox"/>			Is there an emergency generator?	<input checked="" type="checkbox"/>		
Hazards protected by self-closing door?	<input checked="" type="checkbox"/>			Date last tested <u>Quarterly</u>			
Is kitchen cooking protected?			<input checked="" type="checkbox"/>	LP Gas Tanks, Location & Condition	<input checked="" type="checkbox"/>		
Kitchen hood and duct last cleaned			<input checked="" type="checkbox"/>	LP Gas Meter & Shutoff	<input checked="" type="checkbox"/>		
9. Protection of Vertical Openings				Electrical MDP per code?	<input checked="" type="checkbox"/>		
Are vertical openings enclosed?	<input checked="" type="checkbox"/>			Electrical wiring	<input checked="" type="checkbox"/>		
Are elevators enclosed?			<input checked="" type="checkbox"/>	Acceptable Use of Electrical Extension Cords	<input checked="" type="checkbox"/>		
Is atrium per code?			<input checked="" type="checkbox"/>	Acceptable Use of Power Strips	<input checked="" type="checkbox"/>		
Are ≤ 3 levels open per code?	<input checked="" type="checkbox"/>			Elevator recall (phase I)?			<input checked="" type="checkbox"/>

14. Building HVAC & Utilities cont.	Yes	No	N/A
Fire Dept. elevator control (phase II)?			✓
Are stages per code?			✓
Are platforms / risers per code?	✓		W
HVAC system in good working order?	✓		
Interior air intakes cond.?	✓		
Exterior air intakes cond.?	✓		
Smoke removal system function			✓

	Yes	No	N/A
Are Janitor's closets sprinklered?			✓
Are rescue windows in each classroom per code?			✓
Are smoke barriers per code?			✓
Proper handling of trash and rubbish?	✓		
Proper storage of hazardous materials	✓		
Proper storage of flammable / combustible liquids?	✓		

Comments

① Exit lights need repair

② Fire Extinguishers need to be certified and brought up to code

Inspection performed by: William Richards SCFR Insp. # 127692

Signature [Signature] Date: 10/13/08

Inspection Passed on _____ Inspector's Initials _____

Inspection Failed on 10/13/08 Inspector's Initials WCR

Re-Inspection scheduled for 11/18/08 Time: 10:30

Re-Inspection Passed on 12/30/08 Inspector's Initials WCR

Re-Inspection Failed on 12/18/08 Inspector's Initials WCR

I have received a copy of the results of this inspection. I understand the nature of deficiencies noted during this inspection and that they need to be corrected in the specified time allowed.

Authorized Representative Mary Bailey Date: 10-13-08