

HERNANDO COUNTY DEVELOPMENT DEPARTMENT  
789 Providence Blvd  
Brooksville, FL 34601  
352-754-4050

**Business Use Permit Inspection Report**

Application No.: 1307560

Date of Inspection: 3-18-15

Address: 10311 Cement Plant Rd

Business on Right Side \_\_\_\_\_ Left Side \_\_\_\_\_

Fire Department Comments:

- ① FIRE PUMP ROOM NOT LABELED "FIRE PUMP ROOM"
- ② NO REPORT FOR FIRE PUMP INSPECTION @ LOCATION - MUST HAVE A COPY IN ROOM
- ③ FIRE ALARM / ELECTRICAL ROOM NOT LABELED "FACP" MUST BE LABELED ON BUILDING OR DOORS
- ④ FIRE ALARM SYSTEM PAST DUE FOR SERVICE NO REPORTS IN BOX
- ⑤ ALL MONITOR FIRE HYDRANTS MUST BE SERVICED AND TAGGED.
- ⑥ WAREHOUSE N/W EXIT EMERGENCY LIGHT NOT WORKING
- ⑦ N/E PIV CLOSED WHY?

Building Department Comments:

No change in use or classification, NO Alterations  
Change in name and ownership

**No work required to be done. OK to occupy.** Certificate of Occupancy can be picked up from the Building Department or sent to you upon payment of all fees.

**Work to be done does not require a permit.** OK to proceed with above items. Do Not Occupy until Certificate of Occupancy is received.

**Work to be done requires a permit.** DO NOT proceed with work until Supplemental Information Sheet provided to Building Department and Business Use Permit issued; or separate permit for remodel issued. Do Not Occupy until Certificate of Occupancy received.

Fire: [Signature]  
Building: Chris Poole

Date 3-18-15  
Date 3-18-15

Phone No.: 352 540 6262  
Phone No.: Ext. 29155