

This email shall serve as a continuation of the previous emails regarding Phase 3 and Phase 2 secondary flow rates. Attached please find the September flow data for the Citrus County Central Landfill. The landfill received 6.65 inches of rain for the month creating the exceedances as indicated. Therefore, the issue called out in previous emails from Solid Waste Management and SCS Engineers and the Phase 3 Detection Zone report issued by SCS Engineers dated April 17, 2014 persists. This email shall serve as a continuation of our initial notification. As always, we will continue to keep informed of any developments related to this situation. If you have any questions or comments on the SCS report, please do not hesitate to contact me or Ed Hilton, SCS Engineers.

CITRUS COUNTY LANDFILL			PHASE 2			PHASE 3		
DATE	DAY	RAIN IN INCHES	80-3 (S) LS METER	POC	Secondary 80-3 (S) FLOW GAL	80 (P-2) LS METER	POC	Secondary 80 (P-2) FLOW GAL
09/01/15	Tue	0.02	569280	A	489	4832423	A	518
09/02/15	Wed	0.00	569769	A	469	4832941	A	520
09/03/15	Thu	0.00	570238	A	0	4833461	A	262
09/04/15	Fri	0.88	570238	A	3	4833723	A	527
09/05/15	Sat	1.31	570241	A	9	4834250	A	1822
09/06/15	Sun	0.05	570250	A	11	4836072	A	2004
09/07/15	Mon	0.03	570261	A	976	4838076	A	1361
09/08/15	Tue	0.00	571237	A	5	4839437	A	1630
09/09/15	Wed	0.00	571242	A	3	4841067	A	1542
09/10/15	Thu	0.01	571245	A	3	4842609	A	758
09/11/15	Fri	0.00	571248	A	4	4843367	A	757
09/12/15	Sat	0.29	571252	A	4	4844124	A	519
09/13/15	Sun	0.30	571256	A	1028	4844643	A	509
09/14/15	Mon	0.01	572284	A	1	4845152	A	266
09/15/15	Tue	0.10	572285	A	1	4845418	A	526
09/16/15	Wed	0.44	572286	A	3	4845944	A	262
09/17/15	Thu	0.06	572289	A	1	4846206	A	258
09/18/15	Fri	0.00	572290	A	5	4846464	A	256
09/19/15	Sat	0.90	572295	A	6	4846720	A	512
09/20/15	Sun	0.01	572301	A	6	4847232	A	261
09/21/15	Mon	0.00	572307	A	4	4847493	A	267
09/22/15	Tue	0.00	572311	A	1	4847760	A	513
09/23/15	Wed	0.00	572312	A	79	4848273	A	134
09/24/15	Thu	0.00	572391	A	528	4848407	A	258
09/25/15	Fri	0.01	572919	A	640	4848665	A	271
09/26/15	Sat	1.51	572919	A	607	4848936	A	743
09/27/15	Sun	0.25	573526	A	4	4849679	A	1016
09/28/15	Mon	0.21	573530	A	5	4850695	A	767
09/29/15	Tue	0.25	573535	A	4	4851462	A	999
09/30/15	Wed	0.01	573539	A	0	4852461	A	513
TOTAL		6.65			4899			20551

Phase 2 - 600 gpd

Phase 3 - 680 gpd