

Smith, George

From: Brent C Steele <brentc.steele@cemex.com>
Sent: Wednesday, January 10, 2018 6:00 PM
To: SWD_Waste
Subject: Cemex Brooksville South cement plant - Tire fluff fire 7-day notification

Good afternoon,

On the evening of January 4, we had a fire break out on the tire fluff pile at the Cemex Brooksville South cement plant. The fire was caused by self-combustion of the material in the pile. We have revised our practices to include regular turnover of material in the pile (targeting every 10 days) to prevent future occurrences. No remedial actions or repairs are necessary, as no soil, water, or structures were impacted by the fire.

Thanks,
Brent Steele



Brent Steele

Environmental Manager – Brooksville South - United States of America
Office: (352) 799-7881 ext.109 Fax: (352) 799-6088 Mobile: (352) 514-3683
Address: 10311 Cement Plant Road, Brooksville, FL 34601
e-Mail: brentc.steele@cemex.com
www.cemexusa.com

CONFIDENTIALITY: The information contained in this transmission may contain privileged and confidential information. It is intended only for the use of the person(s) named above. If you are not the intended recipient, you are hereby notified that any review, dissemination, distribution or duplication of this communication, and the information contained in it, is strictly prohibited. If you are not the intended recipient, please contact the sender and immediately destroy all copies of the original message. CONFIDENTIALITY: The information contained in this transmission may contain privileged and confidential information. It is intended only for the use of the person(s) named above. If you are not the intended recipient, you are hereby notified that any review, dissemination, distribution or duplication of this communication, and the information contained in it, is strictly prohibited. If you are not the intended recipient, please contact the sender and immediately destroy all copies of the original message.